

City of Houston Houston Public Works

**Standard Construction
Specifications for
Wastewater Collection
Systems, Water Lines,
Storm Drainage,
Street Paving, and Traffic**

**Carol Ellinger Haddock, P.E.,
Director**

**Suhail Kanwar, P.E.,
City Engineer**



**HOUSTON
PUBLIC WORKS**

**HOUSTON
PERMITTING CENTER**

**Division 01: General
Requirements 2023
Standard Specifications**

NEW IN THE 2023 REVISION

General Requirements Specifications for Wastewater Collection Systems, Water Lines, Storm Drainage, Street Paving, and Traffic – 2023 Revisions to the 2022 Edition

The City of Houston Standards Review Committee (SRC) was established to review, revise, and update documents and standards for Houston Public Works. Public input and participation was requested by the submittal of proposals for suggested changes, comments, recommendations and other information.

The 2022-2023 City of Houston Review Cycle Committee reviewed Infrastructure Design Manual (IDM) Chapters 15-17 along with their associated standard drawings and standard construction specifications. Refer to the IDM Executive Summary for a summary of major updates to the design requirements made this review cycle. Below is a list of Division 01 specifications and standard drawings that were revised during this review cycle. The specifications have change bars on the left side of the page to indicate a revision has taken place.

Division 01 Specifications Updated*:

- 01554 – Traffic Control and Street Signs
- 01555 – Traffic Control and Regulation
- 01562 – Tree and Plant Protection
- 01582 Build Houston Forward Project Identification Signs

New Division 01 Standard Details:

- 01554-05 – Houston Bikeway Signage

Division 01 Standard Details Updated*:

- 01554-01 (prev. 01509-01) - General Notes and Ground Mounting Sign
- 01554-02 (prev. 01509-01A) - Sign Base Mounting Details
- 01554-04 (prev. 01509-02A)– Custom Signs
- 01555-01 (prev. 01512-01) - TCP Notes Channelizing Devices and Barricades
- 01555-02 (prev. 01512-02) - TCP Overall Traffic Control Layout
- 01555-03 (prev. 01512-03) - Traffic Control Layout
- 01555-04 (prev. 01512-04) - TCP One Lane Closure Phase 1 & 2
- 01555-05 (prev. 01512-05) - TCP One Lane Closure for One Block
- 01555-06 (prev. 01512-06) - TCP Typical 3-Way Intersection Phase 1 of 3
- 01555-07 (prev. 01512-07) - TCP Typical 3-Way Intersection Phase 2 of 3
- 01555-08 (prev. 01512-08) - TCP Typical 3-Way Intersection Phase 3 of 3

Division 01 Standard Details Updated* (cont'd):

- 01555-09 (prev. 01512-09) - TCP 4-Way Intersection Phase 1 of 4
- 01555-10 (prev. 01512-10) - TCP 4-Way Intersection Phase 2 of 4
- 01555-11 (prev. 01512-11) - TCP 4-Way Intersection Phase 3 of 4
- 01555-12 (prev. 01512-12) - TCP 4-Way Intersection Phase 4 of 4
- 01562-02 – Tree Protection and Root Pruning in Sidewalk Repairs in Pedestrian Realm
- 01562-03 - Tree Protection with Sidewalk Repairs in Pedestrian Realm
- 01562-04 - Tree Protection Zero Curb Cut
- 01562-05 (combined 01562-05A & 01562-05B) - Tree Protection Tunneling Requirements
- 01562-06 - Tree Protection Trench Requirements
- 01582-01 - Construction Sign Build Houston Forward

Division 01 Standard Details Retired/Deleted:

- 01580-04 - Construction Sign ReBuild Houston Project Drainage Utility Fee Funding
- 01580-05 - Construction Sign Rebuild Houston Project
- 01580-06 - Construction Sign Thumbs Up for Progress ReBuild Houston Project

*Only specifications and standard details with technical changes have been included in the list.

CHANGES MADE IN THE 2022 REVISION

General Requirements Specifications for Wastewater Collection Systems, Water Lines, Storm Drainage, Street Paving, and Traffic – 2022 Revisions to the 2021 Edition

The 2021-2022 City of Houston Review Cycle reviewed Infrastructure Design Manual (IDM) Chapters 1-5 and 13 along with their associated standard drawings and standard construction specifications. Below are the Division 01 standard specifications and standard drawings that were revised during 2021-2022 review cycle.

New Specifications:

- 01582 – Build Houston Forward Project Identification Signs

New Standard Details:

- 01582-01 – Construction Sign, Build Houston Forward

DIVISION 1 SPECIFICATIONS

GENERAL REQUIREMENTS

<u>Section</u>	<u>Title</u>	<u>Pages</u>
01145	Use of Premises	04
01255	Change Order Procedures.....	05
01270	Measurement and Payment.....	04
01292	Schedule of Values.....	02
01312	Coordination and Meetings	03
01321	Construction Photographs	04
01325	Construction Schedule.....	05
01326	Construction Schedule (Bar Chart)	03
01330	Submittal Procedures.....	04
01340	Shop Drawings, Product Data, and Samples	03
01351	Environmental Safety and Worker Protection	14
01410	TPDES Requirements (with Attachments).....	38
01422	Reference Standards	03
01450	Contractor's Quality Control	02
01452	Inspection Services.....	01
01454	Testing Laboratory Services.....	03
01502	Mobilization	03
01504	Temporary Facilities and Controls	10
01506	Diversion Pumping.....	02
01520	Temporary Field Office.....	03
01554	Traffic Control and Street Signs	07
01555	Traffic Control and Regulation	09
01562	Tree and Plant Protection	10
01570	Storm Water Pollution Prevention Control.....	15
01575	Stabilized Construction Access	04
01576	Waste Material Disposal.....	02
01578	Control of Ground and Surface Water	09
01580	Project Identification Signs	06
01581	Excavation in Public Way Permit Signs.....	02
01582	Build Houston Forward Project Identification Signs	05
01610	Basic Product Requirements.....	03
01630	Product Substitution Procedures.....	04
01725	Field Surveying.....	03
01731	Cutting and Patching	04
01732	Procedure for Water Valve Assistance (with Attachments)	05
01740	Site Restoration	05
01755	Starting Systems.....	02
01770	Closeout Procedures	03
01782	Operations and Maintenance Data.....	03
01785	Project Record Documents.....	02

*Bold Specifications have major changes or are new.

SECTION 01145

USE OF PREMISES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General use of the site including properties inside and outside of rights-of-way, work affecting road, ramps, streets and driveways and notification to adjacent occupants.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01504 – Temporary Facilities and Controls
- C. Section 01555 – Traffic Control and Regulation
- D. Section 02317 – Excavation and Backfill for Utilities
- E. Section 02512 – Water Tap and Service Line Installation
- F. Section 02911 – Topsoil
- G. Section 02922 – Sodding
- H. Section 02951 – Pavement Repair and Restoration

1.03 RIGHTS-OF-WAY

- A. Confine access, and operations and storage areas to rights-of-way provided by the City as stipulated in Document 00700 - General Conditions; trespassing on abutting lands or other lands in the area is not allowed.
- B. Make arrangements, at no cost to the City, for temporary use of private properties. Submit a copy of agreements between private property owners and Contractor prior to use of the area. Agreements between private property owners and Contractor shall be notarized or bear the signatures of two witnesses.
- C. Obtain written permission from City of Houston Parks and Recreation Department for storage of materials on esplanades and other areas within rights-of-way under that department's jurisdiction. Submit copies of written permission prior to use of the area.
- D. Restrict total length of distributed materials along the route of construction to 1,000 linear feet unless otherwise approved in writing by City Engineer.

1.04 PROPERTIES OUTSIDE OF RIGHTS-OF-WAY

- A. Do not alter the condition of properties adjacent to and along rights-of-way.
- B. Do not use ways, means, methods, techniques, sequences, or procedures that result in damage to properties or improvements.
- C. Restore damaged properties outside of rights-of-ways at no cost to the city

1.05 USE OF SITE

- A. Obtain approvals from Project Manager and governing authorities prior to impeding or closing public roads and streets. Do not close more than two consecutive intersections at one time.
- B. Notify Project Manager and Houston Public Works Traffic Management at least five working days prior to closing a street or street crossing. Obtain permits for street closures in advance.
- C. Maintain 10-foot-wide minimum access lanes for emergency vehicles including access to fire hydrants.
- D. Avoid obstructing drainage ditches or inlets. When obstruction is unavoidable due to requirements of the Work, provide grading and temporary drainage structures to maintain unimpeded flow.
- E. Locate and protect private lawn sprinkler systems that may exist within the site. Repair or replace damaged systems to condition existing at start of the Work, or better. Test irrigation system prior to construction.
- F. Conform to daily clean-up requirements of Article 3 of Document 00700 - General Conditions.
- G. Beware of overhead power lines existing in area and in close proximity of the Project. When 10 feet of clearance between energized overhead power line and construction-related activity cannot be maintained, request Center Point Energy (CPE) de-energize or move conflicting overhead power line. Contact CPE representatives at (713) 207-2222. Schedule, coordinate and pay costs associated with de-energizing or moving conflicting overhead power lines. When there is no separate pay item for this effort, include these costs in various items of bid that make such work necessary.
- H. Maintain access to all buildings, driveways and parking lots throughout the Project.

1.06 NOTIFICATION TO ADJACENT OCCUPANTS

- A. Notify individual occupants in areas to be affected by the Work of proposed construction and time schedule. Notify not less than 72 hours or more than two weeks prior to work performed within 200 feet of homes or businesses. Follow form and content of sample door hanger provided by Project Manager.

- B. Include in notification nature of the Work, and names and telephone numbers of two company representatives for resident contact available on 24-hour call.
- C. Submit proposed notification to Project Manager for approval. Consider ethnicity of the neighborhood where English is not the dominant language. Provide notice in an understandable language.
- D. In regard to notifications on all small-diameter water lines (as defined in City of Houston Specification Section 02512 - Water Tap and Service Line Installation), the Contractor must perform all customer notifications and complete a Notice of Customer Communication form provided by the Project Manager that such notice has been given 48-hours in advance of any water disruptions. Notification must also include the approximate duration of planned service outages. The City of Houston Inspector must have the completed Notification of Customer Communication form before the commencement of valve assisted work. Follow the form and content of sample door hanger provided by Project Manager.

1.07 PUBLIC, TEMPORARY, AND CONSTRUCTION ROADS AND RAMPS

- A. Construct and maintain temporary detours, ramps, and roads to provide for normal public traffic flow when it is necessary to close public roads or streets.
- B. Provide mats or other means to prevent overloading or damage to existing roadways from tracked equipment, large tandem axle trucks or equipment that will damage the existing roadway surfaces.
- C. Construct and maintain access roads and parking areas as specified in Section 01504 - Temporary Facilities and Controls.

1.08 EXCAVATION IN STREETS AND DRIVEWAYS

- A. Avoid hindering or inconveniencing public travel on streets or intersecting alleys for more than two blocks at any one time, except by permission of City Engineer.
- B. Obtain Traffic Management and City Engineer's approval when nature of the Work requires closure of an entire street. Permits required for street closure are Contractor's responsibility. Avoid unnecessary inconvenience to abutting property owners.
- C. Remove surplus materials and debris and open each block for public use, as work in that block is complete.
- D. Acceptance of any portion of the Work will not be based on return of street to public use.
- E. Avoid obstructing driveways or entrances to private property.
- F. Provide temporary crossings or complete excavation and backfill in one continuous operation to minimize duration of obstruction when excavation is required across drives or entrances.

- G. Provide barricades and signs in accordance with Section VI of the State of Texas Manual on Uniform Traffic Control Devices.

1.09 TRAFFIC CONTROL

- A. Comply with traffic regulation as specified in Section 01555 - Traffic Control and Regulation.

1.10 SURFACE RESTORATION

- A. Restore the site including landscaping to the condition existing before construction, or better.
- B. Repair paved areas per the requirements of Section 02951 - Pavement Repair and Restoration.
- C. Repair damaged turf areas, level with bank run sand conforming to Section 02317 - Excavation and Backfill for Utilities, or topsoil conforming to Section 02911 - Topsoil, and re-sod in accordance with Section 02922 - Sodding. Water and level newly sodded areas with adjoining turf using appropriate steel wheel rollers for sodding. Do not use spot sodding or sprigging.

1.11 LIMITS OF CONSTRUCTION

- A. Confine operations to lands within construction work limits shown on Drawings. Unless otherwise noted on Drawings adhere to the following:
 - 1. Where utility alignment is within esplanade, and construction limits are shown on Drawings to extend to edge of esplanade, keep equipment, materials, stockpiles a minimum of five feet from back of curb.
 - 2. Where construction limits shown on Drawings extend to property line, keep sidewalks free of equipment, materials, and stockpiles.

1.12 EQUIPMENT AND MATERIAL SALVAGE

- A. Upon completion of the Work, carefully remove salvageable equipment and material. Deliver them to City of Houston as directed by Project Manager. Dispose of equipment offsite at no additional cost to the City when Project Manager deems equipment unfit for further use.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01255

CHANGE ORDER PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for processing Change Orders, including:
 - 1. Assignment of a responsible individual for approval and communication of changes in the Work;
 - 2. Documentation of change in Contract Price and Contract Time;
 - 3. Change procedures, using proposals and Modifications;
 - 4. Execution of Change Orders;
 - 5. Correlation of Contractor submittals.

1.02 RELATED SECTIONS

- A. Document 00410 – Bid Form
- B. Document 00700 – General Conditions
- C. Document 00931 – Request for Information
- D. Document 00932 – Request for Proposal
- E. Document 00940 – Work Change Directive
- F. Document 00941 – Change Order
- G. Document 00942 – Minor Change in the Work
- H. Section 01785 – Project Record Documents

1.03 REFERENCES

- A. Blue Book is defined as the Rental Rate Blue Book for Construction Equipment (a.k.a. Data Quest Blue Book).
- B. Rental Rate is defined as the full-unadjusted base rental rate for the appropriate item of construction equipment.

1.04 RESPONSIBLE INDIVIDUAL

- A. Provide a letter indicating the name and address of the individual authorized to execute Modifications, and who will be responsible for informing others in Contractor's employ and Subcontractors of changes to the Work. Provide this information at the pre-construction meeting.

1.05 DOCUMENTATION OF CHANGE IN CONTRACT PRICE AND CONTRACT TIME

- A. Maintain detailed records of changes in the Work. Provide full information required for identification and evaluation of proposed changes, and substantiate costs of changes in the Work.
- B. Document each proposal for change in Contract Price or Contract Time with sufficient data to allow evaluation of proposal.
- C. Include the following minimum information on proposals:
 - 1. Quantities of items in original Document 00410 – Bid Form with additions, reductions, deletions, and substitutions.
 - 2. Quantities and cost of items in original Schedule of Values with additions, reductions, deletions and substitutions.
 - 3. Provide Unit Prices for new items, with supporting information, for inclusion in Schedule of Unit Price Work.
 - 4. Justification for changes in Contract Time.
 - 5. Additional data upon request.
- D. For changes in the Work performed on a time-and-material basis, provide the following additional information:
 - 1. Quantities and description of Products.
 - 2. Taxes, insurance and Bonds.
 - 3. Overhead and profit as noted in Document 00700 - General Conditions.
 - 4. Dates, times and by who work was performed.
 - 5. Time records and certified copies of applicable payrolls.
 - 6. Invoices and receipts for Products, rental equipment, and subcontracts, similarly documented.
- E. For changes in the Work performed on a time-and-materials basis, rental equipment is paid as follows:

1. Actual invoice cost for duration of time required to complete extra work without markup for overhead and profit. When extra work comprises only a portion of a rental invoice where equipment would otherwise be on site, compute hourly equipment rate by dividing the actual monthly invoice by 176. One day equals eight hours and one week equals 40 hours.
- F. Do not exceed estimated operating costs given in Blue Book for items of equipment. Overhead and profit will be allowed on the operating cost. For changes in the Work performed on a time-and-materials basis using Contractor-owned equipment, use Blue Book rates as follows:
 1. Contractor-owned equipment will be paid at the Blue Book Rental Rate for the duration of time required to complete extra work without markup for overhead and profit. Utilize lowest cost combination of hourly, daily, weekly or monthly rates. Use 150 percent of Rental Rate for double shifts, one extra shift per day, and 200 percent of Rental Rate for more than two shifts per day. Standby rates shall be 50 percent of the appropriate Rental Rate shown in Blue Book. No other rate adjustments apply.
 2. Do not exceed estimated operating costs given in Blue Book. Overhead and profit will be allowed on operating costs. Operating costs will not be allowed for equipment on standby.

1.06 CHANGE PROCEDURES

- A. Changes to Contract Price or Contract Time can only be made by issuance of Document 00941 - Change Order. Issuance of Document 00940 - Work Change Directive will be formalized into a Change Order. Changes will be in accordance with requirements of Document 00700 - General Conditions.
- B. City Engineer will advise of Minor Changes in the Work as authorized by the Document 00700 - General Conditions by issuing Document 00942 – Minor Change.
- C. Request clarification of Drawings, Specifications, Contract documents or other information by using Document 00931- Request for Information. Response by Project Manager to Requests for Information does not authorize Contractor to perform tasks outside scope of the Work. Changes must be authorized as described in this Section.

1.07 PROPOSALS AND CONTRACT MODIFICATIONS

- A. Project Manager may issue Document 00932- Request for Proposal, which includes a detailed description of the proposed change with supplementary or revised Drawings and Specifications. Project Manager may also request a proposal in response to a Request for Information. Prepare and submit the proposal within seven days or as specified in request.
- B. Submit requests for Contract changes to City Engineer describing proposed change and its full effect on the Work, with a statement describing reason for change and effect on Contract Price and Contract Time including full documentation.

- C. Design Consultant may review Change Orders.

1.08 WORK CHANGE DIRECTIVE

- A. City Engineer may issue a signed Work Change Directive instructing Contractor to proceed with a change in the Work. Work Change Directive will subsequently be incorporated into a Change Order.
- B. Work Change Directives will describe changes in the Work and designate the method of determining change in Contract Price or Contract Time.
- C. Proceed promptly to execute changes in the Work in accordance with the Work Change Directive.

1.09 STIPULATED PRICE CHANGE ORDER

- A. A Stipulated Price Change Order will be based on an accepted proposal.

1.10 UNIT PRICE CHANGE ORDER

- A. Where Unit Prices for affected items of the Work are included in Document 00410 – Bid Form, the Change Order will be based on Unit Prices, subject to Articles 7 and 9 of Document 00700 - General Conditions.
- B. Where Unit Prices of the Work are not pre-determined in Document 00410- Bid Form, the Work Change Directive or accepted proposal will specify the Unit Prices to be used.

1.11 TIME-AND-MATERIAL CHANGE ORDER

- A. Provide itemized account and supporting data after completion of change, within time limits indicated for claims in Document 00700 - General Conditions.
- B. City Engineer will determine the change allowable in Contract Price and Contract Time as provided in Document 00700 - General Conditions.
- C. Maintain detailed records for work done on time-and-material basis as specified in section 1.05 above.
- D. Provide full information required for evaluation of changes and substantiate costs for changes in the Work.

1.12 EXECUTION OF CHANGE DOCUMENTATION

- A. City Engineer will issue Change Orders, Work Change Directives, or Minor Change in the Work for signatures of Parties as described in Document 00700 - General Conditions.

1.13 CORRELATION OF CONTRACTOR SUBMITTALS

- A. For Stipulated Price Contracts, promptly revise Schedule of Values and Application for Payment forms to record authorized Change Orders as separate line item.
- B. For Unit Price Contracts, the next monthly estimate of the Work after acceptance of a Change Order will be revised to include new items not previously included with appropriate Unit Prices.
- C. Promptly revise progress schedules to reflect change in Contract Time, and to adjust time for other items of work affected by the change, and resubmit for review.
- D. Promptly enter changes to on-site and record copies of Drawings, Specifications or Contract documents as required in Section 01785 - Project Record Documents.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01270

MEASUREMENT AND PAYMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for measurement and payment plus conditions for nonconformance assessment and nonpayment for rejected Products.

1.02 RELATED SECTIONS

- A. Document 00410 – Bid Form
- B. Document 00700 – General Conditions
- C. Document 00800 – Supplementary Conditions

1.03 AUTHORITY

- A. Measurement methods delineated in Specification sections are intended to complement criteria of this Section. In event of conflict, requirements of the Specification section shall govern.
- B. Project Manager will take all measurements and compute quantities accordingly.
- C. Assist by providing necessary equipment, workers, and survey personnel.
- D. Measurement and Payment paragraphs are included only in those Specification sections of Division 01 where direct payment will be made. Include costs in the total bid price for those Specification sections in Division 01 that do not contain Measurement and Payment paragraphs.

1.04 UNIT QUANTITIES SPECIFIED

- A. Quantity and measurement estimates stated in the Agreement are for contract purposes only. Quantities and measurements supplied or placed in the Work and verified by Project Manager will determine payment as stated in Article 9 of Document 00700 - General Conditions.
- B. When actual work requires greater or lesser quantities than those quantities indicated in Document 00410 – Bid Form, provide required quantities at Unit Prices contracted, except as otherwise stated in Article 9 of Document 00700 - General Conditions.

1.05 MEASUREMENT OF QUANTITIES

- A. Measurement by Weight: Reinforcing steel, rolled or formed steel or other metal shapes are measured by CRSI or AISC Manual of Steel Construction weights. Welded assemblies are measured by CRSI or AISC Manual of Steel Construction or scale weights.
- B. Measurement by Volume:
 - 1. Stockpiles: Measured by cubic dimension using mean length, width, and height or thickness.
 - 2. Excavation and Embankment Materials: Measured by cubic dimension using average end area method.
- C. Measurement by Area: Measured by square dimension using mean length and width or radius.
- D. Linear Measurement: Measured by linear dimension, at item centerline or mean chord.
- E. Stipulated Price Measurement: By unit designated in the Agreement.
- F. Other: Items measured by weight, volume, area, or linear means or combination, as appropriate, as completed item or unit of the Work.
- G. Measurement by Each: Measured by each instance or item provided.
- H. Measurement by Lump Sum: Measure includes all associated work.

1.06 PAYMENT

- A. Payment includes full compensation for all required supervision, labor, Products, tools, equipment, plant, transportation, services, and incidentals; and erection, application or Installation of an item of the Work; and Contractor's overhead and profit.
- B. Total compensation for required Unit Price work shall be included in Unit Price bid in Document 00410 – Bid Form. Claims for payment as Unit Price work, but not specifically covered in the list of Unit Prices contained in Document 00410 – Bid Form, will not be accepted.
- C. Interim payments for stored materials will be made only for materials to be incorporated under items covered in Unit Prices, unless disallowed in Document 00800 - Supplementary Conditions.
- D. Progress payments will be based on Project Manager's observations and evaluations of quantities incorporated in the Work multiplied by Unit Price.

- E. Final payment for work governed by Unit Prices will be made on the basis of actual measurements and quantities determined by Project Manager multiplied by the Unit Price for work which is incorporated in or made necessary by the Work.

1.07 REFERENCES

- A. AISC Manual of Steel Construction, current edition
- B. Concrete Reinforcing Steel Institute (CRSI)

1.08 NONCONFORMANCE ASSESSMENT

- A. Remove and replace work, or portions of the Work, not conforming to the Contract documents.
- B. When not practical to remove and replace work, City Engineer will direct one of the following remedies:
 - 1. Nonconforming work will remain as is, but Unit Price will be adjusted lower at discretion of City Engineer.
 - 2. Nonconforming work will be modified as authorized by City Engineer, and the Unit Price will be adjusted lower at the discretion of City Engineer, when modified work is deemed less suitable than specified.
- C. Specification sections may modify the above remedies or may identify a specific formula or percentage price reduction.
- D. Authority of City Engineer to assess nonconforming work and identify payment adjustment is final.

1.09 NONPAYMENT FOR REJECTED PRODUCTS

- A. Payment will not be made for any of the following:
 - 1. Products wasted or disposed of in an unacceptable manner.
 - 2. Products determined as nonconforming before or after placement.
 - 3. Products not completely unloaded from transporting vehicles.
 - 4. Products placed beyond lines and levels of required work.
 - 5. Products remaining on hand after completion of the Work, unless specified otherwise.
 - 6. Loading, hauling, and disposing of rejected Products.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01292

SCHEDULE OF VALUES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Preparation and submittal of Schedule of Values for Stipulated Price Contracts or for Major Unit Price Work on Unit Price Contracts.

1.02 RELATED SECTIONS

- A. Section 01325 - Construction Schedule
- B. Section 01330 - Submittal Procedures

1.03 PREPARATION

- A. For Stipulated Price Contracts, subdivide the Schedule of Values into logical portions of the Work, such as major work items or work in contiguous construction areas. Use Section 01325 - Construction Schedule as a guide to subdivision of work items. Directly correlate Items in the Schedule of Values with tasks in the Construction Schedule. Organize each portion using the Project Manual Table of Contents as an outline for listing value of the Work by Sections. A pro rata share of mobilization, Bonds, and insurance may be listed as separate items for each portion of the Work.
- B. For Unit Price Contracts, items should include a proportional share of Contractor's overhead and profit so that total of all items will equal Contract Price.
- C. For lump sum equipment items, where submittal of operation and maintenance data and testing are required, include separate items for equipment operation and maintenance data where:
 - 1. submittal of maintenance data is valued at five percent of the lump sum amount for each equipment item and
 - 2. submittal for testing and adjusting is valued at five percent of the lump sum amount for each equipment item.
- D. Round off figures for each item listed to the nearest \$100. Set the value of one item, when necessary, to make total of all values equal the Contract Price for Stipulated Price Contracts or the lump sum amount for Unit Price Work.

1.04 SUBMITTAL

- A. Submit the Schedule of Values, in accordance with requirements of Section 01330 - Submittal Procedures, at least 10 days prior to processing of the first Certificate for Payment.
- B. Submit the Schedule of Values in an approved electronic spreadsheet file and an 8 1/2-inch by 11-inch print on white bond paper.
- C. Revise Schedule of Values for items affected by Contract Modifications. After City Engineer has reviewed changes, resubmit at least 10 days prior to the next scheduled Certificate for Payment date.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01312

COORDINATION AND MEETINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General coordination including pre-construction meeting, site mobilization conference, and progress meetings.

1.02 COORDINATION OF DOCUMENTS

- A. Coordination is required throughout documents. Refer to Contract documents and coordinate as necessary.

1.03 CONTRACTOR COORDINATION

- A. Coordinate scheduling, submittals, and work of various Specification sections to assure efficient and orderly sequence of Installation of interdependent construction elements.
- B. Coordinate completion and clean up of the Work prior to the Date of Substantial Completion and for portions of the Work designated for City's partial occupancy.
- C. Coordinate access to the site for correction of nonconforming work to minimize disruption of the City's activities where the City is in partial occupancy.

1.04 PRE-CONSTRUCTION MEETING

- A. Project Manager will schedule pre-construction meeting.
- B. Attendance Required: City representatives, Design Consultant, special consultants as required by Project Manager, Contractor, and major Subcontractors and Suppliers.
- C. Agenda:
 - 1. Distribution of Contract documents.
 - 2. Designation of personnel representing the Parties and Design Consultant.
 - 3. Review of insurance.
 - 4. Discussion of formats for Schedule of Values and Construction Schedule.
 - 5. Procedures and processing of Shop Drawings, substitutions, pay estimates or Applications for Payment, Requests for Information, Requests for Proposal, Modifications, and the Contract closeout, other submittals.

6. Scheduling of the Work and coordination with other contractors.
7. Review of Subcontractors and Suppliers.
8. Appropriate agenda items listed for the site mobilization conference, Paragraph 1.05.C, when pre-construction meeting and site mobilization conference are combined.
9. Procedures for testing.
10. Procedures for maintaining record documents.

1.05 SITE MOBILIZATION CONFERENCE

- A. When required by Contract documents, Project Manager will schedule a conference at the Project site prior to Contractor mobilization.
- B. Attendance Required: City representatives, Design Consultant, special consultants, Superintendent, and major Subcontractors.
- C. Agenda:
 1. Use of premises by the City and Contractor.
 2. Safety and first aid procedures.
 3. Construction controls provided by the City.
 4. Temporary utilities.
 5. Survey and layout.
 6. Security and housekeeping procedures.
 7. Field office requirements.

1.06 PROGRESS MEETINGS

- A. Hold meetings at Project field office or other location designated by Project Manager. Hold meetings at monthly intervals, or more frequently when directed by Project Manager.
- B. Attendance Required: Superintendent, major Subcontractors and Suppliers, City representatives, Design Consultant and its subconsultants as appropriate for agenda topics for each meeting.
- C. Project Manager will make arrangements for meetings, and for recording minutes.
- D. Project Manager will prepare the agenda and preside at meetings.

- E. Provide required information and be prepared to discuss each agenda item.
- F. Agenda:
 - 1. Review minutes of previous meetings.
 - 2. Review of construction schedule, pay estimates, cash flow curve, payroll and compliance submittals.
 - 3. Field observations, problems, and necessary decisions.
 - 4. Identification of problems that impede planned progress.
 - 5. Review of submittal schedule and status of submittals.
 - 6. Review of RFI and RFP status.
 - 7. Modification status.
 - 8. Review of off-site fabrication and delivery schedules.
 - 9. Maintenance of Construction Schedule.
 - 10. Corrective measures to regain Construction Schedule.
 - 11. Planned progress during the succeeding work period.
 - 12. Coordination of projected progress.
 - 13. Maintenance of quality and work standards.
 - 14. Effect of proposed Modifications on Construction Schedule and coordination.
 - 15. Review Project Record Contract Drawings.
 - 16. Other item relating to the Work.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION -NOT USED

END OF SECTION

SECTION 01321

CONSTRUCTION PHOTOGRAPHS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Photographic requirements for construction photographs and submittals.

1.02 RELATED SECTIONS

- A. Section 01330 – Submittal Procedures

1.03 DEFINITIONS

- A. Pre-construction Photographs: Photographs taken, in sufficient numbers and detail, prior to Date of Commencement of the Work, to show original construction site conditions.
- B. Progress Photographs: Photographs, taken throughout the duration of construction at regular intervals and from fixed vantage points, pre-approved by the City, that document progress of the Work.
- C. Finished Photographs: Photographs, taken by a professional photographer near Date of Substantial Completion and before City Council’s acceptance of the Work, that are suitable for framing and for use in brochures or on the Internet.

1.04 SUBMITTALS

- A. Refer to Section 01330, Submittal Procedures, for submittal requirements.
- B. Format and Media. Film or digital photography may be used. Submit color photographs, unless otherwise specified.
 - 1. Prints. Submit each Progress or Pre-construction Photograph print in a three-hole plastic pocket or sleeve, bound in a three-ring notebook. Produce prints on photographic-quality paper approved by Project Manager. Minimum size for Pre-construction Photograph prints shall be 3-inches by 5-inches. Progress Photograph prints shall be 8-inches by 10-inches.
 - 2. Film. Use 35mm or larger color film. Submit negatives used to make submitted photographs, in 3-hole 8-1/2 inch by 11-inch plastic sheets with sleeves for negatives.

3. Digital Photography. Use 2.1 megapixel density or greater for photographs. Scanned photographs must equal or exceed 400 dots per inch when scanned from 8-inch by 10-inch prints. Submit digital photographic files on computer disks. Format disks for MS-DOS (Microsoft Disk Operating System) filing system and in JPEG (Joint Photographic Experts Group) format.
- C. Submittal Quantities and Frequencies.
1. Pre-construction Photographs:
 - a. For Stipulated Price Contracts, submit two sets of Pre- construction Photographs, if required, prior to first Application for Payment.
 - b. For Unit Price Contracts, submit two sets of Pre-construction Photographs prior to start of construction operations.
 2. Progress Photographs:
 - a. For Stipulated Price Contracts, submit three sets of Progress Photographs with each Application for Payment at the times established for submittal of Applications for Payment. Monthly Applications for Payment shall be deemed incomplete if not accompanied by the required Progress Photographs. Contractor's failure or election to not submit a monthly Application for Payment shall not affect the requirement for monthly Progress Photographs.
 - b. Progress Photographs are not required for Unit Price Contracts unless otherwise specified.
 3. Finished Photographs: For Stipulated Price Contracts submit two sets of Finished Photographs, if required, after Date of Substantial Completion and prior to final payment. Each set shall contain one 11- inch by 14-inch matte finish color photographic print from each of the two vantage points pre-approved by the City. Vantage points for Finished Photographs will be approved separately from vantage points approved for Progress Photographs. Finished Photographs are not required for Unit Price Contracts unless otherwise specified.
- D. Labeling. Place a label on the back of each photographic print, applied so as to not to show through on the front. Labels shall contain the following information:
1. Name of Project, address of Project and GFS Number.
 2. Name and address of Contractor.
 3. Date photograph was taken.
 4. Location photo was taken from and short description of photo subject.

- 5. Name and address of professional photographer who took the photograph, if applicable.
- E. Hand-deliver or transmit prints in standard photographic mailers marked “Photographs - Do Not Bend”.
- F. Photographic prints, negatives, photographic files and disks become the property of the City. Do not be publish photographs without written consent by the City.

1.05 QUALITY ASSURANCE

- A. Contractor shall be responsible for the quality of and timely execution and submittal of photographs.
- B. For Finished Photographs, Contractor shall use a professional photographer, with five years minimum professional experience in the Houston area. Contractor shall submit name, address and credentials of professional photographer for Project Manager’s review and approval.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PRE-CONSTRUCTION PHOTOGRAPHS

- A. Prior to commencement of construction operations, photograph the site to include initial construction corridor, detour routes, and staging or storage areas.
 - 1. For Stipulated Price Contracts, unless specified as a requirement in other Sections, these photographs are optional for Contractor, but are highly recommended for areas bounded by other property owners.
 - 2. Pre-construction photographs are required for Unit Price Contracts. For line projects with scheduled construction segments, take Pre- construction Photographs prior to commencement of work on each segment.
- B. Prepare Pre-construction Photographs as follows:
 - 1. Show the following information on a non-reflective chalkboard placed within the picture frame:
 - a. Job number.
 - b. Project Number.
 - c. Date and time photographs were taken (Automatic date/time in negative is acceptable).

- d. Baseline station, direction of view (i.e. N, S, NW, etc.) and house number or street address and street name.
2. Pre-construction Photographs shall indicate condition of the following:
 - a. Esplanades and boulevards.
 - b. Yards (near side and far side of street).
 - c. House walks and sidewalks.
 - d. Curbs.
 - e. Areas between walks and curbs.
 - f. Particular features (e.g. yard lights, shrubs, fences, trees).
3. Show date photographs were taken on negatives.
- C. Show the location of vantage points and direction of shots on a key plan of the site.

3.02 PROGRESS PHOTOGRAPHS

- A. Progress Photographs document monthly advancement of the Work. Select vantage points for each shot so as to best show status of construction and progress since last photograph submittal. Select camera stations that will require little or no movement or adjustment over the duration of construction.
- B. Take monthly Progress Photographs at regular intervals to coincide with cutoff dates associated with each Application for Payment.

3.03 FINISHED PHOTOGRAPHS

- A. Finished Photographs shall be “staged” and taken by a professional photographer to depict the most flattering images of a finished facility. Two vantage points, from which Finished Photographs will be taken, shall be agreed to in advance by the City. Photographer shall consider lighting, time of day, height of eye, landscaping and placement of vehicles, people and other props in each picture. Filters and post-photography processing may be utilized to achieve a finished product acceptable to the City.

3.04 LOCATION

- A. Vantage points, times and conditions for camera stations and photography for Progress and Finished Photographs shall be mutually agreed upon by the City, Contractor and Photographer. Progress Photograph vantage points may be changed by mutual agreement as the Work progresses, at no additional cost to the City.

END OF SECTION

SECTION 01325

CONSTRUCTION SCHEDULE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Provide Construction Schedules for the Work included in this Contract in accordance with requirements in this Section. Create Construction Schedule using Critical Path Method (CPM) computer software capable of mathematical analysis of Precedence Diagramming Method (PDM) plan. Provide printed activity listings and bar charts in formats described in this Section.
- B. Combine activity listings and bar charts with narrative report to form Construction Schedule submittal for Project Manager.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01312 - Coordination and Meetings
- C. Section 01330 - Submittal Procedures

1.03 SCHEDULING STAFF

- A. Employ or retain services of individual experienced in CPM scheduling for duration of the Contract. Individual shall cooperate with Project Manager and update schedule monthly as required to indicate current status of the Work.

1.04 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. During preconstruction meeting, as described in Section 01312 - Coordination and Meetings, provide sample bar charts and activity listings produced from scheduling software proposed. Scheduling software is subject to review by Project Manager and must meet requirements provided in this Section. Project Manager will provide review of samples within seven days of submittal.
- C. Within 21 days of receipt of approval of Contractor's format, or 30 days of Notice to Proceed, whichever is later, submit proposed Construction Schedule for review. Base Construction Schedule submittal on the following:
 - 1. Level of detail and number of activities required in schedule are dependent on project type.

- a. For wastewater projects, categorize work type and area code in schedule.
 - (1) For wastewater rehabilitation projects, there are six work-type categories. An area code will be assigned for each Meter Service Area or Basin. Include at least one activity for each unique combination of work type and area code. Normal schedules of wastewater rehabilitation projects contain between 35 and 100 activities, depending on number of basins and work types involved in each basin.
 - (2) For wastewater relief projects (line work), area codes will be assigned geographically.
 - (3) For wastewater plant or facility work, other criteria may apply to assignment of area codes, such as a combination of geographical and craft categories.
 - b. For projects with multiple types of tasks within scope, indicate types of work separately within schedule.
 - c. For projects with work at different physical locations or service areas, or different facilities within a site, indicate each location or facility separately within schedule. Show work on each floor of multi-story building as separate tasks.
 - d. For projects with multiple crafts or significant Subcontractor components, indicate elements separately within schedule. Unless permitted by Project Manager, tasks shall consist of work covered by only one division of Project Manual.
2. Unless permitted by Project Manager, each scheduled task shall be same as Schedule of Values line item, and vice versa.
 3. For projects with Major Unit Price Work, indicate Shop Drawing submittal and review, purchase, delivery, and Installation dates on Project schedule. Include activities for testing, adjustment, and delivering O&M manuals.
 4. No task except the acquisition of Major Unit Price Work shall represent more than one percent of Original Contract Price for facility projects and three percent of Original Contract Price for other projects. Duration of tasks may not exceed 40 calendar days.
 5. For projects where operating facilities are involved, identify each period of work that will impact any process or operation in the schedule and that must be agreed to by Project Manager and facility operator prior to starting work in the area.
- D. Construction Schedule submittals shall include:

1. Printed bar charts that meet criteria outlined in this Section and are produced by Contractor's approved scheduling software;
 2. Activity listings that meet criteria outlined in this Section and are produced by Contractor's approved scheduling software; and
 3. A predecessor/successor listing sorted by Activity ID that meets criteria outlined in this Section and is produced by Contractor's scheduling software.
 4. A logic network diagram is required with the first Construction Schedule submittal for facilities projects.
 5. Prepare and submit graphic or tabular display of estimated monthly billings (i.e. a cash flow curve for the Work) with the first schedule submittal. This information is not required in monthly updates, unless significant changes in work require re-submittal of schedule for review. Display shall allocate units indicated in bid schedule or Schedule of Values to Construction Schedule activities. Weighted allocations are acceptable, where appropriate. Dollar value associated with each allocated unit will be spread across the duration of that activity on a monthly basis. Total for each month and cumulative total will be indicated. These monthly forecasts are only for Project Manager's planning purposes. Monthly payments for actual work completed will be made in accordance with Document 00700 - General Conditions.
 6. Narrative Report that provides the information outlined in this Section.
- E. No payment will be made until Project Manager approves Construction Schedule and billing forecast.
- F. If Contractor desires to make changes in its method of operating and scheduling, after Project Manager has reviewed original schedule, notify Project Manager in writing, stating reasons for changes. When Project Manager considers these changes to be significant, Contractor may be required to revise and resubmit for review all or affected portion of Contractor's Construction Schedule to show effect on the Work.
- G. Upon written request from Project Manager, revise and submit for review all or any part of Construction Schedule submittal to reflect changed conditions in the Work or deviations made from original schedule.
- H. Updated Construction Schedule with actual start and actual finish dates, percent complete, and remaining duration of each activity shall be submitted monthly. Data date used in updating monthly Construction Schedule shall be the same date as used in monthly Payment Application. Monthly update of Construction Schedule is required for monthly Payment Application to be processed for payment.

1.05 SCHEDULING COMPUTER SOFTWARE REQUIREMENTS

- A. Contractor's scheduling software shall be capable of creating bar charts and activity listings, which can be sorted by various fields (i.e. Activity ID, Early Start, Total Float, Area Code, Specification Section number, and Subcontractor). Use software capable of producing logic network diagram.
- B. Use scheduling software capable of producing activity listings and bar charts with the following information for each activity in the schedule:
 - 1. Activity ID
 - 2. Activity Description
 - 3. Estimated (Original) Duration
 - 4. Remaining Duration
 - 5. Actual Duration
 - 6. Early Start Date
 - 7. Late Start Date
 - 8. Early Finish Date
 - 9. Late Finish Date
 - 10. Free Float
 - 11. Total Float
 - 12. Activity Codes (such as Area Code, Work Type, Specification Section, Subcontractor)
- C. Use scheduling software capable of printing calendars using mathematical analysis of schedule, indicating standard workdays of week and scheduled holidays.
- D. Use scheduling software capable of printing activity listing that indicates predecessors and successors, lag factors and lag relationships used in creating logic of the schedule.
- E. Use scheduling software to provide monthly time in Bar Chart format and scale with 12-month scale not to exceed one page width. Bar charts may be printed or plotted on 8-1/2 by 11-inch, 8-1/2 by 14-inch or 11 by 17-inch sheet sizes. Over-size plots are not acceptable.

1.06 NARRATIVE SCHEDULE REPORT

- A. Narrative schedule report shall list activities started this month, activities completed this month, activities continued this month, activities scheduled to start or complete next month, problems encountered this month, and actions taken to solve these problems.
- B. Narrative schedule report shall describe changes made to Construction Schedule logic (i.e. changes in predecessors and lags), activities added to schedule, activities deleted from schedule, any other changes made to the schedule other than addition of actual start dates and actual finish dates and changes of data date and remaining durations for re-calculation of mathematical analysis.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01326

CONSTRUCTION SCHEDULE (BAR CHART)

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Provide an initial Construction Schedule as required by this section for the Work. Do not start construction until Project Manager reviews the schedule.

1.02 FORM AND CONTENT OF INITIAL CONSTRUCTION SCHEDULE

A. Bar Chart:

1. Show major construction activities such as pipe laying, by traffic control phases or other approved key areas; tunnel construction, pavement removal, pavement replacement, pressure testing, chlorination, clean up and punch list as separate activities on the schedule.
2. Show week duration for each activity.
3. Show separate activities for each Shop Drawing and Product Data submittal critical to timely completion. Show submittal dates and dates Project Manager needs to provide approved submittals.
4. Provide separate horizontal bar for each activity. List start and finish date for each activity at left side of diagram.
5. Horizontal Time Scale: Identify first work day of each week.
6. Scale and Spacing: Notes must be legible. Allow space for notations and future revisions.
7. Order of Listings: Order bar chart listings by phases or other approved groups of activities that are contiguous. List activities in chronological order within each phase or group.

B. Narrative Description:

1. Submit narrative descriptions of anticipated work sequences as indicated by the sequence of activities presented in the schedule.
2. Discuss any activity that affects the public (such as phases of traffic control), interaction with specific forces of the City (such as valve operation, chlorination and testing) or other associated contractors.

1.03 PROGRESS REVISIONS

- A. Submit progress revisions or necessary information to complete and process Payment Applications. When required, re-submittals for rejected revisions must be submitted and reviewed prior to the following month's processing of a Payment Application. The following month's Payment Application will not be processed until the re-submittal is reviewed and required progress revisions are received.
- B. Provide a narrative report to describe:
 - 1. Major changes in scope.
 - 2. Revised projections in progress, completion, or changes in activity duration.
 - 3. Other identifiable changes.
 - 4. Problem areas, anticipated delays, and the impact on schedule.
 - 5. Corrective action recommended and its effect.
 - 6. Effect of changes on schedules or other contractors.
 - 7. Product delivery lead times.
- C. Include additional data with Bar Chart described in Paragraph 1.03A of this Section:
 - 1. Show original dates for each activity in the approved initial progress schedule by narrow bar next to a wider bar for the current schedule.
 - 2. Show date each activity actually started or finished when an event has occurred. Clearly identify actual dates in two right-most columns in left portion of an 11 by 17-inch chart.
 - 3. Indicate the percentage progress to the date of submittal for each activity.

1.04 SUBMITTALS

- A. Submit the initial progress schedule within 15 days after award of contract. Project Manager will review the schedule and return a reviewed copy within 21 days after receipt.
- B. Cut-off dates for progress revisions may be as early as the 20th of the month to avoid delaying processing of Payment Applications. Use the cut-off date for the first approved revision for further revisions.
- C. When required, re-submit within seven days after return of review copy.
- D. Include connecting lines between bars in the schedule to indicate the sequence that activities will be accomplished. Connecting lines when the activity's start or finish is modified will identify impact of preceding or succeeding activities. Submit a minimum of six copies of the bar chart on 11 by 17-inch opaque reproductions. Project Manager will retain five copies and return the remaining copy.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01330

SUBMITTAL PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Submittal procedures for:

1. Schedule of Values
2. Construction Schedules and Cash Flow Curve (billing forecast).
3. Shop Drawings, Product Data and Samples
4. Operations and Maintenance (O&M) Data
5. Manufacturer's Certificates
6. Construction Photographs
7. Project Record Documents and monthly certification.
8. Video Tapes
9. Design Mixes

1.02 SUBMITTAL PROCEDURES

A. Scheduling and Handling:

1. Submit Shop Drawings, data and Samples for related components as required by Specifications and Project Manager.
2. Schedule submittals well in advance of need for construction Products. Allow time for delivery of Products after submittal approval.
3. Develop submittal schedule that allows sufficient time for initial review, correction, resubmission and final review of all submittals. Allow a minimum of 30 days for initial review. Project Manager will review and return submittals to Contractor as expeditiously as possible but time required for review will vary depending on complexity and quantity of data submitted.

4. Project Manager's review of submittals covers only general conformity to Drawings, Specifications and dimensions that affect layout. Contractor is responsible for quantity determination. No quantities will be verified by Project Manager. Contractor is responsible for errors, omissions or deviations from Contract requirements; review of submittals does not relieve Contractor from the obligation to furnish required items in accordance with Drawings and Specifications.
 5. Submit five copies of documents unless otherwise specified.
 6. Revise and resubmit submittals as required. Identify all changes made since previous submittal.
 7. Assume risk for fabricated Products delivered prior to approval. Do not incorporate Products into the Work, or include payment for Products in periodic progress payments, until approved by Project Manager.
- B. Transmittal Form and Numbering:
1. Transmit each submittal to Project Manager with Transmittal letter which includes:
 - a. Date and submittal number
 - b. Project title and number
 - c. Names of Contractor, Subcontractor, Supplier and manufacturer
 - d. Identification of Product being supplied
 - e. Location of where Product is to be Installed
 - f. Applicable Specification section number
 2. Identify deviations from Contract documents clouding submittal drawings. Itemize and detail on separate 8-1/2 by 11-inch sheets entitled "DEVIATIONS FOR _____." When no deviations exist, submit a sheet stating no deviations exist.
 3. Have design deviations signed and sealed by an appropriate design professional, registered in the State of Texas.
 4. Sequentially number transmittal letters beginning with number one. Use original number for resubmittals with an alphabetic suffix (i.e., 2A for the first resubmittal of submittal 2, or 15C for third resubmittal of submittal 15, etc.). Show only one type of work or Product on each submittal. Mixed submittals will not be accepted.
- C. Contractor's Stamp:

1. Apply Contractor's Stamp certifying that the items have been reviewed in detail by Contractor and that they comply with Contract requirements, except as noted by requested variances.
 2. As a minimum, Contractor's Stamp shall include:
 - a. Contractor's name
 - b. Job number
 - c. Submittal number
 - d. Certification statement Contractor has reviewed submittal and it is in compliance with the Contract
 - e. Signature line for Contractor
- D. Submittals will be returned with one of the following Responses:
1. "ACKNOWLEDGE RECEIPT" when no response and resubmittal is required.
 2. "NO EXCEPTION" when sufficient information has supplied to determine that item described is accepted and that no resubmittal is required.
 3. "EXCEPTIONS AS NOTED" when sufficient information has been supplied to determine that item will be acceptable subject to changes, or exceptions, which will be clearly stated. When exceptions require additional changes, the changes must be submitted for approval. Resubmittal is not required when exceptions require no further changes.
 4. "REJECTED-RESUBMIT" when submittal does not contain sufficient information, or when information provided does not meet Contract requirements. Additional data or details requested by Project Manager must be submitted to obtain approval.

1.03 MANUFACTURER'S CERTIFICATES

- A. When required by Specification sections, submit manufacturers' certificate of compliance for review by Project Manager.
- B. Place Contractor's Stamp on front of certification.
- C. Submit supporting reference data, affidavits, and certifications as appropriate.
- D. Product certificates may be recent or from previous test results, but must be acceptable to Project Manager.

1.04 DESIGN MIXES

- A. When required by Specification sections, submit design mixes for review.
- B. Place Contractor's Stamp, as specified in this section, on the front of each design mix.
- C. Mark each mix to identify proportions, gradations, and additives for each class and type of mix submitted. Include applicable test results from samples for each mix. Perform tests and certifications within 12 months of the date of the submittal.
- D. Maintain copies of approved mixes at mixing plant.

1.05 CHANGES TO CONTRACT

- A. Changes to Contract may be initiated by completing a Request for Information form. Project Manager will provide a response to Contractor by completing the form and returning it to Contractor.
 - 1. If Contractor agrees that the response will result in no increase in cost or time, a Minor Change in the Work will be issued by City Engineer.
 - 2. If Contractor and Project Manager agree that an increase in time or cost is warranted, Project Manager will forward the Request for Proposal for negotiation of a Change Order.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01340

SHOP DRAWINGS, PRODUCT DATA, AND SAMPLES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Methods, schedules, and processes to be followed for Shop Drawings, Product Data and Sample submittals.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01330 – Submittal Procedures
- C. Section 01630 – Product Substitution Procedures

1.03 REQUIREMENT

- A. Submit Shop Drawings, Product Data and Samples as required by Document 00700 - General Conditions and Specification sections, using procedures specified in Section 01330 - Submittal Procedures and the requirements of this Section.
- B. Shop Drawings, Product Data and Samples are not considered Contract documents.

1.04 SHOP DRAWING/SUBMITTAL SCHEDULE

- A. Submit a separate Shop Drawing submittal schedule at same time the Construction Schedule is submitted. List Products for which Shop Drawings and other submittals are required in the order that they appear in Specifications. Include Product Data and Sample submittals in the schedule. Payment Applications or Certificates for Payment will not be processed until Project Manager has approved the Shop Drawing submittal schedule.

1.05 SHOP DRAWINGS

- A. Submit Shop Drawings and Product Data through the City's electronic project management system. If the City's project management system cannot accommodate the file, submit the Shop Drawings and Product Data using an alternate method approved by the Project Manager.
- B. Place Contractor's Stamp on each drawing as described in Section 01330 - Submittal Procedures.
- C. Show the following accurately and distinctly:

1. Field and erection dimensions;
 2. Arrangement and section views;
 3. Relation to adjacent materials or structure, including complete information for making connections between the Work and work under other contracts;
 4. Types of Products and finishes;
 5. Parts list and descriptions;
 6. Assembly drawings of equipment components and accessories showing respective positions and relationships to the complete equipment package;
 7. Identify details by referencing drawing sheet and detail numbers, schedule or room numbers as shown on the Contract drawings, where necessary for clarity.
- D. Scale drawings to provide a true representation of the specific equipment or item Furnished.
- E. Coordinate and submit components, necessary for Project Manager to adequately review submittal, as a complete package. Reproduction of the Drawings for use in Shop Drawings is not allowed.
- F. For major changes to original documents, submit Computer-Aided Design (CAD) drawings on a media acceptable to Project Manager.

1.06 PRODUCT DATA

- A. Submit Product Data for review as required in Specifications.
- B. Place Contractor's stamp, on each data item submitted, as described in Section 01330 - Submittal Procedures.
- C. Mark each copy to identify applicable Products, models, and options to be used in the Work. Where required by Specifications, supplement manufacturers' standard data to provide information unique to the Work.
- D. Give manufacturers, trade name, model or catalog designation and applicable reference standard for Products specified only by reference standards.
- E. Pre-approved and Approved Products:
 1. For "pre-approved" Products named in the City's pre-approved products list, provide an appropriate list designation, as described in Section 01630 - Product Substitution Procedures, within 30 days after Notice to Proceed.

2. For Products proposed as alternates to "approved" products, provide information required to demonstrate that the proposed Products meet the level of quality and performance criteria of the "approved" product.

1.07 SAMPLES

- A. Submit Samples for review as required by Specifications. Have Samples reviewed and signed by a Registered Professional.
- B. Place Contractor's stamp on each Sample or firmly attach a sheet of paper with Contractor's stamp, as described in Section 01330 - Submittal Procedures.
- C. Submit the number of Samples specified in Specifications; Project Manager will retain one.
- D. Reviewed Samples that may be used in the Work are identified in Specifications.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01351

ENVIRONMENTAL SAFETY AND WORKER PROTECTION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Environmental Safety and Worker Protection including monitoring emissions and exposure to workers and providing an appropriate response. The role of the Certified Industrial Hygienist (CIH) is also defined.

1.02 RELATED SECTIONS

- A. Section 01330 – Submittal Procedures
- B. Section 02136 – Waste Material Handling, Testing and Disposal
- C. Section 09971 – Painting and Protective Coatings for Potable Water Storage Tanks

1.03 MEASUREMENT AND PAYMENT

- A. No separate measurement and payment for work performed under this Section. The Contractor shall include the cost for this work in the contract bid price for work of which this is a component part.

1.04 REFERENCES

- A. The following is a list of applicable requirements to this project. It is not intended to be a complete listing of all laws and regulations to which the Contractor must comply.

- 1. Code of Federal Regulations
 - a. 29 CFR 1910, "Occupational Safety and Health Standards".
 - (1) 29 CFR 1910.146 "Permit-required confined spaces".
 - b. 29 CFR 1926, "Safety and Health Regulations for Construction" (Construction Industry Standards).
 - (1) 29 CFR 1926.33 "Access to Employee Exposure and Medical Records".
 - (2) 29 CFR 1926.51, "Sanitation Standard".
 - (3) 29 CFR 1926.59, "Hazard Communication".
 - (4) 29 CFR 1926.62, "Lead".

- (5) 29 CFR 1926.103 "Respiratory Protection".
- c. 40 CFR 50, "National Primary and Secondary Ambient Air Quality Standards"
 - (1) 40 CFR 50 Appendix B, "Reference Method for the Determination of Suspended Particulate Matter in the Atmosphere (High Volume Method)".
 - (2) 40 CFR 50 Appendix G, "Reference Method for the Determination of Lead in Suspended Particulate Matter Collected from Ambient Air".
- d. 40 CFR 58, "Ambient Air Quality Surveillance".
- e. 40 CFR 60 Appendix A, "Visual Determination of Fugitive Emissions from Material Sources and Smoke Emissions from Fires".
- f. 40 CFR 117, "Determination of Reportable Quantities for Hazardous Substances".
- g. 40 CFR 122, "Administered Permit Program: The National Pollutant Discharge Elimination System".
- 2. National Institute for Occupational Health and Safety NIOSH Method 7082, "Lead" (or equivalent).
- 3. American Society for Testing and Materials
 - a. ASTM D3335, "Test Method for Low Concentrations for Lead, Cadmium, and Cobalt in Paint by Atomic Absorption Spectroscopy."
- 4. EPA (Environmental Protection Agency) Publications
 - a. SW-846, "Test Methods for Evaluating Solid Waste - Physical/Chemical Methods".
 - b. EPA Method 3050, "Acid Digestion of Sediments, Sludges, and Soils".
- 5. SSPC Guide 6, "Guide for Containing Debris Generated During Paint Removal Operations".
- 6. SSPC Guide 7, "Guide for the Disposal of Lead Contaminated Surface Preparation Debris".
- 7. SSPC Publication 91-18, "Industrial Lead Paint Removal Handbook".
- 8. Texas Commission on Environmental Quality

9. Texas Administrative Code (TAC) 30, Chapter 101, "General Rules".
 - a. Texas Administrative Code (TAC) 30, Chapter 111, "Control of Air Pollution from Visible Emissions and Particulate Matter".
 - b. Texas Administrative Code (TAC) 30, Chapter 290, "Water Hygiene".
 - c. Texas Administrative Code (TAC) 30, Chapter 307, "Surface Water Quality Standards".
 - d. Texas Administrative Code (TAC) 30, Chapter 309, "Effluent Limitations".
 - e. Texas Administrative Code (TAC) 30, Chapter 335, "Industrial Solid Waste and Municipal Hazardous Waste".

1.05 SUBMITTALS

- A. Submittals shall conform to requirements of Section 01330 – Submittal Procedures.
- B. Submittals shall conform to appropriate codes for regulatory requirements.

1.06 DEFINITION

- A. Acceptance Criteria: Minimum standards for the content of programs, plans, procedures, and designs required by this specification for the performance of this project. Acceptance criteria will be the basis for judging the responsiveness of Contractors' programs and will also be used as a basis for suspending work, if necessary.
- B. Action Level: Employee exposure, without regard to the use of respirators, to an airborne concentration of lead of 30 micrograms per cubic meter of air ($\mu\text{g}/\text{m}^3$) calculated as an eight hour time-weighted average (TWA).
- C. CERCLA: Comprehensive Environmental Response, Compensation, and Liability Act; commonly called Superfund. Federal laws addressing the clean up of hazardous waste sites. Amended in 1986 by Superfund Amendments and Re- Authorization Act (SARA). EPA implementing regulations are contained in 40 CFR 300-373.
- D. Competent Person: One who is capable of identifying existing and predictable lead hazards in the surroundings or working conditions and who has authorization to take prompt corrective measures to eliminate them.
- E. Containment System: An enclosure built around lead paint removal areas designed to contain lead paint debris and prevent emissions to the environment.

- F. Dust Collection: Mechanical ventilation system designed specifically for the containment, capture, and removal of airborne particulate from the containment. Dust collection systems shall include ductwork, plenums and/or hoppers, and dust collector(s) for the removal of leaded paint dust from the air stream prior to discharging to the atmosphere.
- G. Emission: A release of material to the air, water, or ground.
- H. Entry/Exit Airlock: An isolated enclosure located at the entrance of the containment in which the workers remove contaminated dust and debris from their work clothes.
- I. EPA: The US. Environmental Protection Agency. Regulations are contained in Title 40 of the Code of Federal Regulations (40 CFR).
- J. Hazardous Waste (lead paint debris): Waste that is classified as hazardous due to its concentrations of regulated hazardous substances. Paint debris is classified as hazardous waste if, after testing by the Toxicity Characteristic Leaching Procedure (TCLP), the leachate contains any of the 8 metals or other substances in concentrations at or above limits established in 40 CFR 261.
- K. HEPA: A high efficiency particulate filter (HEPA) that is 99.97% efficient against particles of 0.3 microns in size or larger.
- L. Lead Containing Dust and Debris: Dust and debris generated during the project which contains lead in any amount, including but not limited to pulverized paint, spent abrasive, filters (wet and dry), and containment materials upon which lead is still present.
- M. NIOSH: National Institute of Occupational Safety and Health.
- N. OSHA: Occupational Safety and Health Administration. Standards are contained in Title 29 of the Code of Federal Regulations, Parts 1910 and 1926 (29 CFR 1910 and 29 CFR 1926).
- O. Owner: The City of Houston
- P. PEL: Permissible Exposure Limit. An employee exposure, without regard to the use of respirators, to an airborne concentration of lead of 50 µg/m³ over an 8 hour TWA.
- Q. POTW: Publicly Owned Treatment Works
- R. RCRA: Resource Conservation and Recovery Act. Federal law pertaining to hazardous waste management. EPA implementing regulations are contained in 40 CFR 240-280.
- S. Regulated Area: Area established by the Contractor to demarcate the zone(s) beyond which airborne concentrations of lead do not exceed the Action Level.

- T. SSPC: Society for Protective Coatings. An independent, non-profit organization of engineers, technical specialists, and Contractors whose goal is research and development of new coatings and methods for removal, application, and disposal of existing coatings on industrial structures.
- U. Tarpaulins: Flexible fabric, vinyl, plastic or canvas cover sheets, impenetrable to dust, wind, and water, used to enclose the cable and/or scaffold support system comprising the containment enclosure.
- V. TCLP: Toxicity Characteristic Leaching Procedure. Laboratory tests conducted on wastes that determine the amount of hazardous materials that leach out into a test solution. The test is intended to simulate the properties of water as it leaches through a solid waste landfill. TCLP testing is defined in 40 CFR 261, Appendix II.
- W. TSP: Total Suspended Particulate

PART 2 PRODUCTS

2.01 MATERIAL AND EQUIPMENT

- A. The Contractor is to supply materials and equipment to insure the safety and protection of workers and the environment in accordance with these specifications.

PART 3 EXECUTION

3.01 ENVIRONMENTAL PROTECTION AND MONITORING

NOTE: Section 09971 "Painting and Protective Coatings for Potable Water Storage Tanks", 2.04 "Containment System" specifically identifies containment system requirements.

- A. Protection of Ambient Air: Visible emissions are to be controlled to meet, as a minimum, TAC 30 Chapter 111, "Control of Air Pollution from Visible Emissions and Particulate Matter" requirements and SSPC-Guide 6I (CON), Level 1 Emissions. Air monitoring and analysis may be performed by the City during abrasive blast cleaning operations. Such monitoring will be in accordance with 40 CFR 50, Appendix B, "Reference Method for the Determination of Suspended Particulate Matter in the Atmosphere" and/or 40 CFR 50, Appendix G, "Reference Method for the Determination of Lead in Suspended Particulate Matter Collected from Ambient Air". The limits for down wind pollutant concentrations allowed during blasting operations are as follows:

1. PM-10: 450 micrograms/cubic meter/ 8 hr. (40 CFR 50.6)
2. Lead (Pb): 13.5 micrograms/cubic meter/8 hr. (40 CFR 50.12)

Visible emissions and/or monitored emissions for PM-10 and TSP lead in excess of

- the above levels shall be cause for shut down of the project until corrections to control/ containment system or paint removal/ surface preparation operations are made to comply with these requirements.
- B. Protection of Surface and Storm Water: The Contractor shall take all necessary precautions to ensure lead contaminants do not enter surface waters or storm water drainage systems.
1. The Contractor shall protect the area around ditches and drainage inlets. Daily verification of proper protection to minimize the potential contaminants reaching the drainage system shall be performed.
 2. The Contractor shall collect all potentially contaminated process waters for testing and, as appropriate, treatment. Process water from pressure washing, wet abrasive blast cleaning or hygiene facilities shall not be discharged to drainage systems or surface waters.
 3. The Contractor may remove lead or other heavy metals from such waters through filtration, ion exchange or other approved means. Following treatment, water samples must be tested prior to disposal. Discharge to sanitary sewer lines requires authorization, in writing, from a POTW.
- C. Protection of Soil and Grounds: The Contractor shall protect the soil around the structure to ensure that the soil does not become contaminated. Where lead is present in the coatings to be removed, as indicated in Section 02136 "Waste Material Handling, Testing and Disposal", the Contractor shall provide for the sampling and analysis of soil samples for total lead content.
1. Sampling and analysis shall be performed prior to commencement of paint removal operations to establish a background "base level". Soil samples shall be taken 3 feet from the base of the tank(s), at a distance of 6-10 feet beyond the proposed containment structure and at the property line.
 2. Samples from each area shall be taken in a minimum of four directions, at circular increments of 90, one of which shall include the direction of prevailing wind. Samples shall also be obtained, at the direction of the engineer, at the closest points of public access (i.e. housing, park, school).
 3. The soil sampling procedure shall be as outlined in SSPC Guide 6 Section 5.5.5. Each sampling point shall be sufficiently identified on a site map to allow return to the exact location upon project completion.
 4. Each sample shall be split in two portions, one for immediate analysis and the other sealed, preserved and furnished to the Engineer. The samples shall be analyzed in accordance with EPA Method 3050, "Acid Digestion of Sediments, Sludges and Soils", and shall be performed by a qualified laboratory approved by the Engineer.

5. Samples shall be obtained at the completion of work (post-construction samples) from all locations from which pre-construction samples were obtained. Samples shall be collected, handled and tested in the same manner as described above.
6. Upon completion of the work, soils found to be contaminated with lead in greater quantity than found in the background "base level", established at the start of the work, shall be removed by the Contractor to the depth necessary to achieve a lead content equivalent to, or below, the pre- construction back ground levels. Disposal shall be in accordance with applicable regulations.
7. The Contractor shall replace in-kind (i.e., topsoil, structural fill, etc.) with an equivalent amount of non-contaminated soil, compact in place and grade to pre-existing conditions. The Contractor shall also replace in-kind any surface improvements, such as grass, shrubs, etc. that were damaged or destroyed by the work. The soil removal, replacement and related work is to be performed by the Contractor at no additional cost to the Owner.

3.02 WORKER PROTECTION

- A. The Contractor shall develop a written Compliance Program to establish and implement practices and procedures for assuring that no employee is exposed to lead at concentrations greater than 50 micrograms per cubic meter of air ($\mu\text{g}/\text{m}^3$), the OSHA permissible exposure limit (PEL). This program is in addition to other OSHA hazard communication and safety and health requirements of the project, and shall be revised and updated at least every six months.
 1. The program shall establish methods for complying with this specification and the OSHA Construction Industry Lead Standard, 29 CFR 1926.62(e)(2)(ii). The Federal regulation is referred to as the "Lead Standard" for the purpose of this specification.
 2. The program shall apply to all Contractor employees associated with lead on the project, and to subcontractors working under the direct control of the Contractor who are associated with lead on the project.
 3. The program shall assign the specific responsibility for implementation and enforcement of the program to the Contractors' company management. The Contractor's Competent Person(s) shall be identified, by name, and qualifications submitted. The Competent Person shall be on-site during any operations which involve the removal, handling or disturbing of lead containing materials.
 4. The program shall contain a description of each activity in which lead is emitted (e.g. equipment used, material involved, controls in place, crew size, employee job responsibilities, operating procedures and maintenance practices).

5. The program shall contain a report of the technology considered in meeting the PEL and air monitoring data which documents the source of lead emissions.
 6. The program shall contain a work practice program which includes items required in the lead standard such as protective clothing and equipment, housekeeping, and hygiene facilities and practices.
- B. Exposure Monitoring: The Contractor shall be responsible for conducting and reporting worker exposure assessments in accordance with 29 CFR 1926.62.
1. Representative personal air samples shall be collected at the beginning of the lead removal work to determine employee lead exposures. Tasks involving potential lead exposure include, but are not limited to, paint removal operations, clean-up, and debris handling operations. Full shift (at least 7 hours) air samples shall be collected for each job classification in the exposure area. The range of exposures for lead removal and cleanup activities shall be determined.
 2. During the initial monitoring, workers performing the following activities (or equivalent) shall be protected to the anticipated exposure levels which are dictated by the lead standard:
 - a. 500 $\mu\text{g}/\text{m}^3$: Manual demolition of structures containing lead-containing coatings or paint (e.g., dry wall), manual scraping, manual sanding, heat gun applications, power tool cleaning with dust collection systems, and spray painting with lead paint.
 - b. 2,500 $\mu\text{g}/\text{m}^3$: Using lead-containing mortar, lead burning, or conducting the following activities where lead-containing coatings or paint are present: rivet busting, power tool cleaning without dust collection systems, clean-up activities where dry expendable abrasives are used, and the movement and removal of abrasive blasting enclosures.
 - c. More than 2,500 $\mu\text{g}/\text{m}^3$: Activities involving lead containing coatings or paint on structures disturbed by abrasive blasting, welding, cutting, and torch burning.
 3. Protection requires compliance with the necessary respiratory protection, personal protective clothing and equipment, change areas and washing facilities, blood lead and zinc protoporphyrin monitoring, and employee training. The protection measures shall be modified, as necessary, after the exposure results are received.
 4. Where initial monitoring indicates that lead exposures are below the Action Level, and where work activities and conditions remain the same as at the time of initial sampling, additional monitoring need not be repeated for that work activity.

5. Where the initial monitoring of a given work activity indicates that lead exposures are at or above the Action Level, additional exposure monitoring shall be conducted monthly. The monthly monitoring is more frequent than frequencies established in the lead standard which are at least every 6 months if above the Action Level, but below the PEL, or every 3 months if above the PEL.
 6. All air samples shall be collected and analyzed according to NIOSH Method 7082, or equivalent. All samples shall be analyzed by laboratories accredited by the American Industrial Hygiene Association for metals analysis.
 7. All exposed employees shall be notified in writing of the monitoring results within five (5) days after receiving the results.
 8. The Action Level for airborne lead exposure is 30 $\mu\text{g}/\text{m}^3$, as an 8-hour time weighted average (TWA) concentration, without regard to the use of respirators. Whenever workers' airborne lead exposures exceed the Action Level, the Contractor shall implement the following:
 - a. Periodic Exposure Monitoring
 - b. Employee Information and Training
 - c. Employee Medical Surveillance and Medical Removal Protection
 - d. Housekeeping
 - e. Record keeping
 - f. Signs and Regulated Areas
 9. The Permissible Exposure Limit (PEL) for airborne lead exposure is 50 $\mu\text{g}/\text{m}^3$, as an 8-hour TWA concentration. When the work area contains airborne lead levels above the PEL the Contractor shall implement the following in addition to those items listed in 3.02.B.8 of this section:
 - a. Compliance Program
 - b. Respiratory Protection
 - c. Protective Clothing and Equipment
 - d. Hygiene Facilities and Practices
- C. Respiratory Protection: After feasible engineering controls and work practices have been implemented, respiratory protection shall be used to maintain employees' lead exposures below the PEL.

1. Respirators shall be worn by all employees, other Contractors, inspectors, or observers who enter regulated areas.
 2. The Contractor shall develop a written Respiratory Protection Program in compliance with 29 CFR 1910.134, paragraphs (b), (d), (e), and (f), and the lead standard. The program shall address the selection, use, maintenance, and inspection of respirators, and qualifications for respirator users.
- D. Protective Clothing and Equipment: The Contractor shall provide protective clothing and equipment and ensure they are worn by all employees whose lead exposures exceed the PEL, or who enter regulated areas.
1. Protective clothing shall include washable and/or disposable full body coveralls, gloves, foot coverings, and hoods. Other protective equipment shall include face shields, hard hats, eye protection, and hearing protection as appropriate.
 2. Disposable protective clothing shall be used for no more than one work day. Such clothing may have to be disposed of as hazardous waste.
 3. Reusable protective equipment shall be cleaned or replaced weekly if exposure levels are less than 200 $\mu\text{g}/\text{m}^3$, or daily if the exposure levels are greater than or equal to 200 $\mu\text{g}/\text{m}^3$.
 4. Clothing shall not be removed or "cleaned" by any means which could reintroduce the lead dust into the ambient air. This includes brushing, shaking, and blowing. Vacuums equipped with HEPA filters shall be used for this purpose.
 5. Reusable coveralls shall be collected at the end of each work day in closed containers. The containers shall be labeled in accordance with the requirements of 29 CFR 1926.62(g)(2)(vii). Contaminated clothing shall be cleaned in accordance with all applicable Federal, State, or local regulations pertaining to lead-contaminated laundry and water discharge. Laundries shall be informed that the clothing contains lead. If the clothing is washed on site, the discharge water shall be filtered, containerized, and arrangements made with the local POTW or other approved means of proper disposal.
 6. Protective clothing and equipment shall be removed in the contaminated section of the change area and shall not be worn into any clean areas.
 7. The Contractor shall provide the necessary clothing and equipment for use by the Owner and its designated representatives.
- E. Housekeeping: Accumulations of lead-containing dust and debris generated by work activities shall be removed and cleaned daily.

1. All persons doing the cleanup shall be trained in performing lead activities, respirator qualified, and participate in the medical surveillance program. Respirators and protective clothing shall be worn by all persons doing the cleanup.
2. Compressed air may be used for housekeeping if used within containment and in conjunction with a ventilation system designed to capture the dust. Otherwise, HEPA-filtered vacuum cleaners shall be employed.
3. All lead-containing dust and debris shall be collected in sealed containers. The waste shall be tested to determine whether it will be disposed of as hazardous waste.

F. Personal Hygiene Facilities and Practices

1. Clean change areas shall be provided when employees' lead exposures exceed the PEL. The change areas shall be equipped with storage facilities for street clothing and a separate area for the removal and storage of lead-contaminated clothing and equipment. They shall be designed and used so that contamination of street clothing does not occur. Employees shall not leave the project site wearing any clothing worn while performing lead activities. Airborne lead exposures in the change area shall be maintained below the Action Level.
2. Shower facilities shall be provided whenever employees' lead exposures exceed the PEL. Shower facilities shall comply with OSHA Sanitation Standard, 29 CFR 1929.51. All employees whose lead exposures exceed the PEL shall shower at the end of each work shift or before leaving the project area. The shower facilities shall be made available for use by the Owner and its representatives, such as inspectors or observers.
3. Arrangements shall be made with the local POTW for the proper disposal of the shower and wash water after filtration (e.g., through a three stage 100, 50, and 5 micron filtering system), ion exchange, or other approved treatment technology.
4. Clean lunch areas shall be provided for all employees whose lead exposures exceed the PEL. Employees shall remove or clean (by vacuuming) their protective clothing and wash their hands and face before entering the lunch area. Lead exposures in the lunch area shall be maintained as free as practicable from lead contamination.
5. An adequate number of clean lavatory and hand washing facilities shall be provided. These shall comply with the OSHA Sanitation Standard, 29 CFR 1929.51.

6. Eating, drinking, smoking, chewing of food or tobacco products, or the application of cosmetics shall not be permitted in any areas where the lead exposures exceed the PEL. Thorough washing of hands and face is required prior to undertaking any of these activities.
- G. Medical Surveillance and Medical Removal Protection
1. All employees who are exposed to lead above the Action Level in a single day during this project shall be provided with initial and periodic medical examinations and blood lead tests as required by the lead standard. A final blood lead test shall be provided for each worker upon completion of the project, or at any time a worker's employment at the project ceases.
 2. When blood lead levels over 50 µg/dl are encountered, the Contractor shall provide for the temporary removal of employees from lead exposure above the Action Level. The required medical surveillance and periodic blood lead tests shall be provided in strict accordance with the lead standard throughout the removal.
 3. Employees who will be required to wear a respirator or who request one shall be provided with a respirator and the necessary medical examinations to determine their ability to wear a respirator.
 4. All examinations shall be provided by the Contractor and shall be performed by or under the direct supervision of a licensed physician.
- H. Employee Information and Training
1. The Contractor shall provide lead training for all employees who are exposed to lead above the Action Level for this project.
 2. The content of lead training shall include, as a minimum, those items listed in the lead standard.
 3. Training shall also include hazard communication in accordance with 29 CFR 1926.59.
 4. The Contractor shall notify other employers at the project site of the nature of the lead exposure work, the need to remain out of exposure areas, the warning sign and labeling system in effect, and the potential need for them to take measures to protect their employees.
- I. Signs and Regulated Areas
1. The Contractor shall establish a regulated area surrounding activities where lead exposures exceed the Action Level. This includes locations where lead-containing debris is handled or transferred to storage containers.

2. The regulated area shall be demarcated by ropes, tape, walls, or containment's with caution signs posted at all accessible sides. Signs shall contain the legend:

WARNING
LEAD WORK AREA
POISON
NO SMOKING OR EATING

3. The Contractor shall control access of persons into regulated areas. Access shall be limited to individuals with proper training and personal protective equipment, and medical surveillance testing.
4. All persons entering regulated areas shall wear protective clothing and respirators.
5. Eating, drinking, smoking, and chewing of food or tobacco products shall be prohibited in regulated areas and in any area where lead exposures exceed the Action Level.

- J. Record keeping: All records relating to training, medical examinations, blood lead monitoring, and exposure monitoring shall be maintained by the Contractor as required by the lead standard. All records shall be available for review by the Owner or its representative upon request.

3.03 CERTIFIED INDUSTRIAL HYGIENIST (CIH)

- A. The Contractor shall provide for the services of a Certified Industrial Hygienist (CIH) who must be certified by the American Board of Industrial Hygiene in comprehensive practice.
- B. Duties of the CIH shall be as follows:
 1. Conduct and/or verify training for contractor employees in accordance with 29 CFR 1926.62 (l).
 2. Review and approve Contractor's Written Compliance Plan for conformance to 29 CFR 1926.62(e)(2)(ii) and this Specification.
 3. Monitor and evaluate work weekly to assure conformance with the approved plan and that hazardous exposure is adequately controlled in accordance with worker safety and health requirements of these specifications
 4. Provide monthly reports of work compliance with control requirements in regards to working in a lead environment.
- C. Activities of the CIH shall include:

1. Meet with City to discuss details of Contractor's Written Compliance Plan for lead paint removal.
2. Ensure worker and area air monitoring, testing and reporting are conducted by or under the direction of the CIH.
3. Furnish a detailed worker and area air monitoring schedule coordinated with Contractor's proposed production schedule.
4. Directing, monitoring and inspecting lead paint removal work to ensure that the requirements of the Contract have been satisfied during the entire lead paint removal operation.
5. Report results of air monitoring samples to the Engineer, signed by the CIH within 48 hours after the air samples are taken.
6. The CIH shall review sampling data, collected on a day when lead paint removal operations occur, to determine if conditions require any change in work methods. Removal work shall not continue until approval is given by the CIH.
7. The CIH shall verify in writing and submit monitoring data to verify that:
 - a. Air borne lead levels at and beyond the lead control (regulated) area were and remained less than 30 mg/m³ of air
 - b. Contractor conformance to 29 CFR 1926.62 and Item 3.02, above
 - c. There were no visible accumulations of lead contaminated paint, dust or debris on the work site. Adjacent areas that may have become contaminated were properly cleaned and inspected.
 - d. The CIH shall verify that the work area and contractor's equipment have been adequately cleaned of lead contamination prior to demobilization from the work site.

3.04 DEMOBILIZATION

- A. The Contractor shall not remove the lead control area, boundaries, warning signs, etc. prior to proper removal of all hazardous wastes, debris and materials from the site and the City's receipt and acceptance of the CIH's verification.

END OF SECTION

SECTION 01410

TPDES REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Documentation to be prepared and signed by Contractor/Operator before conducting construction operations, in accordance with the Texas Pollutant Discharge Elimination System (TPDES) Construction General Permit Number TXR150000 issued on February 8, 2018(the Construction General Permit).
- B. Implementation, maintenance inspection, and termination of storm water pollution prevention control measures including, but not limited to, erosion and sediment controls, storm water management plans, waste collection and disposal, off-site vehicle tracking, and other appropriate practices shown on the Drawings or specified elsewhere in the Contract.
- C. Review of the Storm Water Pollution Prevention Plan (SWP3) implementation in a meeting with Project Manager prior to start of construction.

1.02 DEFINITIONS

- A. Commencement of Construction Activities: The exposure of soil resulting from activities such as clearing, grading, and excavation activities, as well as other construction related activities (e.g., stock piling of fill material, demolition).
- B. Large Construction Activity: Project that:
 - 1. disturbs five acres or more, or
 - 2. disturbs less than five acres but is part of a larger common plan of development that will disturb five acres or more of land.
- C. Small Construction Activity: Project that:
 - 1. disturbs one or more acres but less than five acres, or
 - 2. are part of a larger common plan of development that will disturb at least 1 but less than 5 Ac
- D. TPDES Operator:
 - 1. Operator - The person or persons associated with a large or small construction activity that is either a primary or secondary as defined below:

2. Primary Operator - the person or persons associated with a large or small construction activity that meets either of the following two criteria:
 - a. the persons have operational control over construction plans and specifications, including the ability to make modifications to those plans and specifications or
 - b. the person or persons have day-to-day operational control of those activities at a construction site that are necessary to ensure compliance with a storm water pollution prevention plan (SWP3) for the site or other permit conditions (e.g., they are authorized to direct workers at a site to carry out activities required by the SWP3 or comply with other permit conditions).
3. Secondary Operator -The person or entity, often the property owner, whose operational control is limited to:
 - a. the employment of other operators, such as a general contractor, to perform or supervise construction activities, or
 - b. the ability to approve or disapprove changes to construction plans and specifications, but who does not have day-to-day on-site operational control over construction activities at the site.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 SITE SPECIFIC STORM WATER POLLUTION PREVENTION PLAN (SWP3)

- A. Prepare a SWP3 following Part III of the Construction General Permit and the Storm Water Management Handbook for Construction Activities issued under City Ordinance Section 47-695(b). If conflicts exist between the Construction General Permit and the handbook, the more stringent requirements will apply.
- B. Update or revise the SWP3 as needed during the construction following Part III, Section E of the Construction General Permit.
- C. Submit the SWP3 and any updates or revisions to Project Manager for review and address comments prior to commencing, or continuing, construction activities.

3.02 NOTICE OF INTENT FOR LARGE CONSTRUCTION ACTIVITY

- A. Fill out, sign, and date TCEQ Form 20022 (03/06/2018) Notice of Intent (NOI) for an Authorization for Stormwater Discharges Associated with Construction Activity under TPDES General Permit TXR150000, ATTACHMENT 1 of this Section 01410.

- B. Transmit the signed Contractor's copy of TCEQ Form 20022 (03/06/2018), along with a \$325.00 check, made out to Texas Commission on Environmental Quality, and the completed Payment Submittal Form to Project Manager.
- C. Project Manager will complete a separate TCEQ Form 20022 (03/06/2018) for City's Notice of Intent, and will submit both Notices, along with checks for application fees, to the TCEQ.
- D. Submission of the Notice of Intent form by both the City and Contractor to TCEQ if mailing is required a minimum of seven days before Commencement of Construction Activities.

3.03 CONSTRUCTION SITE NOTICE FOR SMALL CONSTRUCTION ACTIVITY

- A. Fill out, sign, and date the Construction Site Notice, Attachment 2 to TPDES General Permit TXR150000, "Small Construction Site Notice", ATTACHMENT 2 of this Section 01410.
- B. Transmit the signed Construction Site Notice to Project Manager at least seven days prior to Commencement of Construction Activity.

3.04 CERTIFICATION REQUIREMENTS

- A. Fill out TPDES Operator's Information form, ATTACHMENT 3 of this Section 01410, including Contractor's name, address, and telephone number, and the names of persons or firms responsible for maintenance and inspection of erosion and sediment control measures. Use multiple copies as required to document full information.
- B. Contractor and Subcontractors shall sign and date the Contractor's / Subcontractor's Certification for TPDES Permitting, ATTACHMENT 4 of this Section 01410. Include this certification with other Project certification forms.
- C. Submit properly completed certification forms to Project Manager for review before beginning construction operations.
- D. Conduct inspections in accordance with TCEQ requirements. Ensure persons or firms responsible for maintenance and inspection of erosion and sediment control measures read, fill out, sign, and date the Erosion Control Contractor's certification for Inspection and Maintenance. Use the City of Houston Storm Water Pollution Prevention Plan, Construction Site Inspection Report, ATTACHMENT 5 of this Section 01410 to record maintenance inspections and repairs.

3.05 RETENTION OF RECORDS

- A. Keep a copy of this document and the SWP3 in a readily accessible location at the construction site from Commencement of Construction Activity until submission of the Notice of Termination (NOT) for Storm Water Discharges Associated with Construction Activity under TPDES Construction General Permit (TXR150000). Contractors with day-to-day operational control over SWP3 implementation shall have a copy of the SWP3 available at a central location, on-site, for the use of all operators and those identified as having responsibilities under the SWP3. Upon submission of the NOT, submit all required forms and a copy of the SWP3 with all revisions to Project Manager.

3.06 REQUIRED NOTICES

- A. Post the following notices from effective date of the SWP3 until date of final site stabilization as defined in the Construction General Permit:
 - 1. Post the TPDES permit number for Large Construction Activity, with a signed TCEQ Construction Site Notice for large or Small Construction Activity. Signed copies of the City's and Contractor's NOI must also be posted.
 - 2. Post notices near the main entrance of the construction site in a prominent place where it is safely and readily available for viewing by General Public, Local, State, and Federal Authorities. Post name and telephone number of Contractor's local contact person, brief project description and location of the SWP3.
 - a. If posting near a main entrance is not feasible due to safety concerns, coordinate posting of notice with Project Manager to conform to requirements of the Construction General Permit.
 - b. If Project is a linear construction project (e.g.: road, utilities, etc.), post notice in a publicly accessible location near active construction. Move notice as necessary.
 - 3. Post a notice to equipment and vehicles operators, instructing them to stop, check, and clean tires of debris and mud before driving onto traffic lanes. Post at each stabilized construction access area.
 - 4. Post a notice of waste disposal procedures in a readily visible location on site.

3.07 ON-SITE WASTE MATERIAL STORAGE

- A. On-site waste material storage shall be self-contained and shall satisfy appropriate local, state, and federal rules and regulations.
- B. Prepare list of waste material to be stored on-site. Update list as necessary to include up-to-date information. Keep a copy of updated list with the SWP3.

- C. Prepare description of controls to reduce pollutants generated from on-site storage. Include storage practices necessary to minimize exposure of materials to storm water, and spill prevention and response measures consistent with best management practices. Keep a copy of the description with the SWP3.

3.08 NOTICE OF TERMINATION

- A. Submit a NOT, ATTACHMENT 6 of this Section 01410, to Project Manager within 30 days after:
 - 1. Final stabilization has been achieved on all portions of the site that are the responsibility of the Contractor or
 - 2. Another operator has assumed control over all areas of the site that have not been stabilized and
 - 3. All silt fences and other temporary erosion controls have either been removed, scheduled to be removed as defined in the SWP3, or transferred to a new operator if the new operator has sought permit coverage.
- B. Project Manager will complete City's NOT and submit Contractor and City's notices to the TCEQ and MS4 entities.

END OF SECTION

ATTACHMENT 1

TCEQ Office Use Only
Permit No:
CN:
RN:



Notice of Intent (NOI) for an Authorization for Stormwater Discharges Associated with Construction Activity under TPDES General Permit TXR150000

IMPORTANT INFORMATION

Please read and use the General Information and Instructions prior to filling out each question in the NOI form.

Use the NOI Checklist to ensure all required information is completed correctly.
Incomplete applications delay approval or result in automatic denial.

Once processed your permit authorization can be viewed by entering the following link into your internet browser: http://www2.tceq.texas.gov/wq_dpa/index.cfm or you can contact TCEQ Stormwater Processing Center at 512-239-3700.

ePERMITS

Effective September 1, 2018, this paper form must be submitted to TCEQ with a completed electronic reporting waiver form (TCEQ-20754).

To submit an NOI electronically, enter the following web address into your internet browser and follow the instructions: <https://www3.tceq.texas.gov/steers/index.cfm>

APPLICATION FEE AND PAYMENT

The application fee for submitting a paper NOI is \$325. The application fee for electronic submittal of a NOI through the TCEQ ePermits system (STEERS) is \$225.

Payment of the application fee can be submitted by mail or through the TCEQ ePay system. The payment and the NOI must be mailed to separate addresses. To access the TCEQ ePay system enter the following web address into your internet browser: <http://www.tceq.texas.gov/epay>.

Provide your payment information for verification of payment:

- If payment was mailed to TCEQ, provide the following:
 - Check/Money Order Number: [REDACTED]
 - Name printed on Check: [REDACTED]
- If payment was made via ePay, provide the following:
 - Voucher Number: [REDACTED]
 - A copy of the payment voucher is attached to this paper NOI form.

RENEWAL (This portion of the NOI is not applicable after June 3, 2018)

Is this NOI for a renewal of an existing authorization? Yes No

If Yes, provide the authorization number here: TXR15

NOTE: If an authorization number is not provided, a new number will be assigned.

SECTION 1. OPERATOR (APPLICANT)

a) If the applicant is currently a customer with TCEQ, what is the Customer Number (CN) issued to this entity? CN

(Refer to Section 1.a) of the Instructions)

b) What is the Legal Name of the entity (applicant) applying for this permit? (The legal name must be spelled exactly as filed with the Texas Secretary of State, County, or in the legal document forming the entity.)

c) What is the contact information for the Operator (Responsible Authority)?

Prefix (Mr. Ms. Miss):

First and Last Name:

Suffix:

Title:

Credentials:

Phone Number:

Fax Number:

E-mail:

Mailing Address:

City, State, and Zip Code:

Mailing Information if outside USA:

Territory:

Country Code:

Postal Code:

d) Indicate the type of customer:

Individual

Federal Government

Limited Partnership

County Government

General Partnership

State Government

Trust

City Government

Sole Proprietorship (D.B.A.)

Other Government

Corporation

Other:

Estate

e) Is the applicant an independent operator? Yes No

(If a governmental entity, a subsidiary, or part of a larger corporation, check No.)

f) Number of Employees. Select the range applicable to your company.

0-20

251-500

21-100

501 or higher

101-250

g) Customer Business Tax and Filing Numbers: (**Required** for Corporations and Limited Partnerships. **Not Required** for Individuals, Government, or Sole Proprietors.)

State Franchise Tax ID Number:

Federal Tax ID:

Texas Secretary of State Charter (filing) Number:

DUNS Number (if known):

SECTION 2. APPLICATION CONTACT

Is the application contact the same as the applicant identified above?

Yes, go to Section 3

No, complete this section

Prefix (Mr. Ms. Miss):

First and Last Name: Suffix:

Title: Credential:

Organization Name:

Phone Number: Fax Number:

E-mail:

Mailing Address:

Internal Routing (Mail Code, Etc.):

City, State, and Zip Code:

Mailing information if outside USA:

Territory:

Country Code: Postal Code:

SECTION 3. REGULATED ENTITY (RE) INFORMATION ON PROJECT OR SITE

a) If this is an existing permitted site, what is the Regulated Entity Number (RN) issued to this site? RN

(Refer to Section 3.a) of the Instructions)

b) Name of project or site (the name known by the community where it's located):

[REDACTED]

c) In your own words, briefly describe the type of construction occurring at the regulated site (residential, industrial, commercial, or other):

[REDACTED]

d) County or Counties (if located in more than one):

[REDACTED]

e) Latitude: Longitude:

[REDACTED] [REDACTED]

f) Site Address/Location

If the site has a physical address such as 12100 Park 35 Circle, Austin, TX 78753, complete *Section A*.

If the site does not have a physical address, provide a location description in *Section B*. Example: located on the north side of FM 123, 2 miles west of the intersection of FM 123 and Highway 1.

Section A:

Street Number and Name:

[REDACTED]

City, State, and Zip Code:

[REDACTED]

Section B:

Location Description:

[REDACTED]

City (or city nearest to) where the site is located:

[REDACTED]

Zip Code where the site is located:

[REDACTED]

SECTION 4. GENERAL CHARACTERISTICS

a) Is the project or site located on Indian Country Lands?

Yes, do not submit this form. You must obtain authorization through EPA Region 6.

No

b) Is your construction activity associated with a facility that, when completed, would be associated with the exploration, development, or production of oil or gas or geothermal resources?

Yes. Note: The construction stormwater runoff may be under jurisdiction of the Railroad Commission of Texas and may need to obtain authorization through EPA Region 6.

No

c) What is the Primary Standard Industrial Classification (SIC) Code that best describes the construction activity being conducted at the site?

[REDACTED]

d) What is the Secondary SIC Code(s), if applicable?

[REDACTED]

e) What is the total number of acres to be disturbed?

[REDACTED]

f) Is the project part of a larger common plan of development or sale?

Yes

No. The total number of acres disturbed, provided in e) above, must be 5 or more. If the total number of acres disturbed is less than 5, do not submit this form. See the requirements in the general permit for small construction sites.

g) What is the estimated start date of the project? [REDACTED]

h) What is the estimated end date of the project? [REDACTED]

i) Will concrete truck washout be performed at the site? Yes No

j) What is the name of the first water body(ies) to receive the stormwater runoff or potential runoff from the site? [REDACTED]

k) What is the segment number(s) of the classified water body(ies) that the discharge will eventually reach? [REDACTED]

l) Is the discharge into a Municipal Separate Storm Sewer System (MS4)?

Yes No

If Yes, provide the name of the MS4 operator: [REDACTED]

Note: The general permit requires you to send a copy of this NOI form to the MS4 operator.

m) Is the discharge or potential discharge from the site within the Recharge Zone, Contributing Zone, or Contributing Zone within the Transition Zone of the Edwards Aquifer, as defined in 30 TAC Chapter 213?

Yes, complete the certification below.

No, go to Section 5

I certify that the copy of the TCEQ-approved Plan required by the Edwards Aquifer Rule (30 TAC Chapter 213) that is included or referenced in the Stormwater Pollution Prevention Plan will be implemented. Yes

SECTION 5. NOI CERTIFICATION

a) I certify that I have obtained a copy and understand the terms and conditions of the Construction General Permit (TXR150000). Yes

b) I certify that the full legal name of the entity applying for this permit has been provided and is legally authorized to do business in Texas. Yes

c) I understand that a Notice of Termination (NOT) must be submitted when this authorization is no longer needed. Yes

d) I certify that a Stormwater Pollution Prevention Plan has been developed, will be implemented prior to construction and to the best of my knowledge and belief is compliant with any applicable local sediment and erosion control plans, as required in the Construction General Permit (TXR150000). Yes

Note: For multiple operators who prepare a shared SWP3, the confirmation of an operator may be limited to its obligations under the SWP3, provided all obligations are confirmed by at least one operator.

SECTION 6. APPLICANT CERTIFICATION SIGNATURE

Operator Signatory Name: [REDACTED]

Operator Signatory Title: [REDACTED]

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code §305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signature (use blue ink): _____ Date: _____

NOTICE OF INTENT CHECKLIST (TXR150000)

Did you complete everything? Use this checklist to be sure!

Are you ready to mail your form to TCEQ? Go to the General Information Section of the Instructions for mailing addresses.

Confirm each item (or applicable item) in this form is complete. This checklist is for use by the applicant to ensure a complete application is being submitted. **Missing information may result in denial of coverage under the general permit.** (See NOI process description in the General Information and Instructions.)

APPLICATION FEE

If paying by check:

- Check was mailed **separately** to the TCEQs Cashier's Office. (See Instructions for Cashier's address and Application address.)
- Check number and name on check is provided in this application.

If using ePay:

- The voucher number is provided in this application and a copy of the voucher is attached.

RENEWAL

- If this application is for renewal of an existing authorization, the authorization number is provided.

OPERATOR INFORMATION

- Customer Number (CN) issued by TCEQ Central Registry
- Legal name as filed to do business in Texas. (Call TX SOS 512-463-5555 to verify.)
- Name and title of responsible authority signing the application.
- Phone number and e-mail address
- Mailing address is complete & verifiable with USPS. www.usps.com
- Type of operator (entity type). Is applicant an independent operator?
- Number of employees.
- For corporations or limited partnerships - Tax ID and SOS filing numbers.
- Application contact and address is complete & verifiable with USPS. <http://www.usps.com>

REGULATED ENTITY (RE) INFORMATION ON PROJECT OR SITE

- Regulated Entity Number (RN) (if site is already regulated by TCEQ)
- Site/project name and construction activity description
- County
- Latitude and longitude <http://www.tceq.texas.gov/gis/sqmaview.html>

Site Address/Location. Do not use a rural route or post office box.

GENERAL CHARACTERISTICS

Indian Country Lands –the facility is not on Indian Country Lands.

Construction activity related to facility associated to oil, gas, or geothermal resources

Primary SIC Code that best describes the construction activity being conducted at the site. www.osha.gov/oshstats/sicser.html

Estimated starting and ending dates of the project.

Confirmation of concrete truck washout.

Acres disturbed is provided and qualifies for coverage through a NOI.

Common plan of development or sale.

Receiving water body or waterbodies.

Segment number or numbers.

MS4 operator.

Edwards Aquifer rule.

CERTIFICATION

Certification statements have been checked indicating Yes.

Signature meets 30 Texas Administrative Code (TAC) §305.44 and is original.

Instructions for Notice of Intent (NOI) for Stormwater Discharges Associated with Construction Activity under TPDES General Permit(TXR150000)

GENERAL INFORMATION

Where to Send the Notice of Intent (NOI):

By Regular Mail:

TCEQ

Stormwater Processing Center (MC228)

P.O. Box 13087

Austin, Texas 78711-3087

By Overnight or Express Mail:

TCEQ

Stormwater Processing Center (MC228)

12100 Park 35 Circle

Austin, TX

Application Fee:

The application fee of \$325 is required to be paid at the time the NOI is submitted. Failure to submit payment at the time the application is filed will cause delays in acknowledgment or denial of coverage under the general permit. Payment of the fee may be made by check or money order, payable to TCEQ, or through EPAY (electronic payment through the web).

Mailed Payments:

Use the attached General Permit Payment Submittal Form. The application fee is submitted to a different address than the NOI. Read the General Permit Payment Submittal Form for further instructions, including the address to send the payment.

ePAY Electronic Payment: <http://www.tceq.texas.gov/epay>

When making the payment you must select Water Quality, and then select the fee category "General Permit Construction Storm Water Discharge NOI Application". You must include a copy of the payment voucher with your NOI. Your NOI will not be considered complete without the payment voucher.

TCEQ Contact List:

Application – status and form questions:

512-239-3700, swpermit@tceq.texas.gov

Technical questions:

512-239-4671, swgp@tceq.texas.gov

Environmental Law Division:

512-239-0600

Records Management - obtain copies of forms:

512-239-0900

Reports from databases(as available):

512-239-DATA (3282)

Cashier's office:

512-239-0357 or 512-239-0187

Notice of Intent Process:

When your NOI is received by the program, the form will be processed as follows:

- **Administrative Review:** Each item on the form will be reviewed for a complete response. In addition, the operator's legal name must be verified with Texas Secretary of State as valid and active (if applicable). The address(es) on the form must be verified with the US Postal service as receiving regular mail delivery. Do not give an overnight/express mailing address.

- **Notice of Deficiency:** If an item is incomplete or not verifiable as indicated above, a notice of deficiency (NOD) will be mailed to the operator. The operator will have 30 days to respond to the NOD. The response will be reviewed for completeness.
- **Acknowledgment of Coverage:** An Acknowledgment Certificate will be mailed to the operator. This certificate acknowledges coverage under the general permit.

or

Denial of Coverage: If the operator fails to respond to the NOD or the response is inadequate, coverage under the general permit may be denied. If coverage is denied, the operator will be notified.

General Permit (Your Permit)

For NOIs submitted **electronically** through ePermits, provisional coverage under the general permit begins immediately following confirmation of receipt of the NOI form by the TCEQ.

For **paper** NOIs, provisional coverage under the general permit begins **7 days after a completed NOI is postmarked for delivery** to the TCEQ.

You should have a copy of your general permit when submitting your application. You may view and print your permit for which you are seeking coverage, on the TCEQ web site <http://www.tceq.texas.gov>. Search using keyword TXR150000.

Change in Operator

An authorization under the general permit is not transferable. If the operator of the regulated project or site changes, the present permittee must submit a Notice of Termination and the new operator must submit a Notice of Intent. The NOT and NOI must be submitted no later than 10 days prior to the change in Operator status.

TCEQ Central Registry Core Data Form

The Core Data Form has been incorporated into this form. Do not send a Core Data Form to TCEQ. After final acknowledgment of coverage under the general permit, the program will assign a Customer Number and Regulated Entity Number, if one has not already been assigned to this customer or site.

For existing customers and sites, you can find the Customer Number and Regulated Entity Number by entering the following web address into your internet browser: <http://www15.tceq.texas.gov/crpub/> or you can contact the TCEQ Stormwater Processing Center at 512-239-3700 for assistance. On the website, you can search by your permit number, the Regulated Entity (RN) number, or the Customer Number (CN). If you do not know these numbers, you can select “Advanced Search” to search by permittee name, site address, etc.

The Customer (Permittee) is responsible for providing consistent information to the TCEQ, and for updating all CN and RN data for all authorizations as changes occur. For this permit, a Notice of Change form must be submitted to the program area.

INSTRUCTIONS FOR FILLING OUT THE NOI FORM

Renewal of General Permit. Dischargers holding active authorizations under the expired General Permit are required to submit a NOI to continue coverage. The existing permit number is required. If the permit number is not provided or has been terminated, expired, or denied, a new permit number will be issued.

Section 1. OPERATOR (APPLICANT)

a) Customer Number (CN)

TCEQ's Central Registry will assign each customer a number that begins with CN, followed by nine digits. **This is not a permit number, registration number, or license number.**

If the applicant is an existing TCEQ customer, the Customer Number is available at the following website: <http://www15.tceq.texas.gov/crpub/>. If the applicant is not an existing TCEQ customer, leave the space for CN blank.

b) Legal Name of Applicant

Provide the current legal name of the applicant. The name must be provided exactly as filed with the Texas Secretary of State (SOS), or on other legal documents forming the entity, as filed in the county. You may contact the SOS at 512-463-5555, for more information related to filing in Texas. If filed in the county, provide a copy of the legal documents showing the legal name.

c) Contact Information for the Applicant (Responsible Authority)

Provide information for the person signing the application in the Certification section. This person is also referred to as the Responsible Authority.

Provide a complete mailing address for receiving mail from the TCEQ. The mailing address must be recognized by the US Postal Service. You may verify the address on the following website: <https://tools.usps.com/go/ZipLookupAction!input.action>.

The phone number should provide contact to the applicant.

The fax number and e-mail address are optional and should correspond to the applicant.

d) Type of Customer (Entity Type)

Check only one box that identifies the type of entity. Use the descriptions below to identify the appropriate entity type. Note that the selected entity type also indicates the name that must be provided as an applicant for an authorization.

Individual

An individual is a customer who has not established a business, but conducts an activity that needs to be regulated by the TCEQ.

Partnership

A customer that is established as a partnership as defined by the Texas Secretary of State Office (TX SOS). If the customer is a 'General Partnership' or 'Joint Venture' filed in the county (not filed with TX SOS), the legal name of each partner forming the 'General Partnership' or 'Joint Venture' must be provided. Each 'legal entity' must apply as a co-applicant.

Trust or Estate

A trust and an estate are fiduciary relationships governing the trustee/executor with respect to the trust/estate property.

Sole Proprietorship (DBA)

A sole proprietorship is a customer that is owned by only one person and has not been incorporated. This business may:

1. be under the person's name
2. have its own name (doing business as or DBA)
3. have any number of employees.

If the customer is a Sole Proprietorship or DBA, the 'legal name' of the individual business 'owner' must be provided. The DBA name is not recognized as the 'legal name' of the entity. The DBA name may be used for the site name (regulated entity).

Corporation

A customer that meets all of these conditions:

1. is a legally incorporated entity under the laws of any state or country
2. is recognized as a corporation by the Texas Secretary of State
3. has proper operating authority to operate in Texas

The corporation's 'legal name' as filed with the Texas Secretary of State must be provided as applicant. An 'assumed' name of a corporation is not recognized as the 'legal name' of the entity.

Government

Federal, state, county, or city government (as appropriate)

The customer is either an agency of one of these levels of government or the governmental body itself. The government agency's 'legal name' must be provided as the applicant. A department name or other description of the organization is not recognized as the 'legal name'.

Other

This may include a utility district, water district, tribal government, college district, council of governments, or river authority. Provide the specific type of government.

e) Independent Entity

Check No if this customer is a subsidiary, part of a larger company, or is a governmental entity. Otherwise, check Yes.

f) Number of Employees

Check one box to show the number of employees for this customer's entire company, at all locations. This is not necessarily the number of employees at the site named in the application.

g) Customer Business Tax and Filing Numbers

These are required for Corporations and Limited Partnerships. These are not required for Individuals, Government, and Sole Proprietors.

State Franchise Tax ID Number

Corporations and limited liability companies that operate in Texas are issued a franchise tax identification number. If this customer is a corporation or limited liability company, enter the Tax ID number.

Federal Tax ID

All businesses, except for some small sole proprietors, individuals, or general partnerships should have a federal taxpayer identification number (TIN). Enter this number here. Use no prefixes, dashes, or hyphens. Sole proprietors, individuals, or general partnerships do not need to provide a federal taxID.

TX SOS Charter (filing) Number

Corporations and Limited Partnerships required to register with the Texas Secretary of State are issued a charter or filing number. You may obtain further information by calling SOS at 512-463-5555.

DUNS Number

Most businesses have a DUNS (Data Universal Numbering System) number issued by Dun and Bradstreet Corp. If this customer has one, enter it here.

Section 2. APPLICATION CONTACT

Provide the name and contact information for the person that TCEQ can contact for additional information regarding this application.

Section 3. REGULATED ENTITY (RE) INFORMATION ON PROJECT OR SITE

a) Regulated Entity Number (RN)

The RN is issued by TCEQ's Central Registry to sites where an activity is regulated by TCEQ. This is not a permit number, registration number, or license number. Search TCEQ's Central Registry to see if the site has an assigned RN at <http://www15.tceq.texas.gov/crpub/>. If this regulated entity has not been assigned an RN, leave this space blank.

If the site of your business is part of a larger business site, an RN may already be assigned for the larger site. Use the RN assigned for the larger site.

If the site is found, provide the assigned RN and provide the information for the site to be authorized through this application. The site information for this authorization may vary from the larger site information.

An example is a chemical plant where a unit is owned or operated by a separate corporation that is accessible by the same physical address of your unit or facility. Other examples include industrial parks identified by one common address but different corporations have control of defined areas within the site. In both cases, an RN would be assigned for the physical address location and the permitted sites would be identified

separately under the same RN.

b) Name of the Project or Site

Provide the name of the site or project as known by the public in the area where the site is located. The name you provide on this application will be used in the TCEQ Central Registry as the Regulated Entity name.

c) Description of Activity Regulated

In your own words, briefly describe the primary business that you are doing that requires this authorization. Do not repeat the SIC Code description.

d) County

Provide the name of the county where the site or project is located. If the site or project is located in more than one county, provide the county names as secondary.

e) Latitude and Longitude

Enter the latitude and longitude of the site in degrees, minutes, and seconds or decimal form. For help obtaining the latitude and longitude, go to:
<http://www.tceq.texas.gov/gis/sqmaview.html>.

f) Site Address/Location

If a site has an address that includes a street number and street name, enter the complete address for the site in *Section A*. If the physical address is not recognized as a USPS delivery address, you may need to validate the address with your local police (911 service) or through an online map site used to locate a site. Please confirm this to be a complete and valid address. Do not use a rural route or post office box for a site location.

If a site does not have an address that includes a street number and street name, provide a complete written location description in *Section B*. For example: "The site is located on the north side of FM 123, 2 miles west of the intersection of FM 123 and Highway 1."

Provide the city (or nearest city) and zip code of the site location.

Section 4. GENERAL CHARACTERISTICS

a) Indian Country Lands

If your site is located on Indian Country Lands, the TCEQ does not have authority to process your application. You must obtain authorization through EPA Region 6, Dallas. Do not submit this form to TCEQ.

b) Construction activity associated with facility associated with exploration, development, or production of oil, gas, or geothermal resources

If your activity is associated with oil and gas exploration, development, or production, you may be under jurisdiction of the Railroad Commission of Texas (RRC) and may need to obtain authorization from EPA Region 6.

Construction activities associated with a facility related to oil, gas or geothermal resources may include the construction of a well site; treatment or storage facility; underground hydrocarbon or natural gas storage facility; reclamation plant; gas processing facility;

compressor station; terminal facility where crude oil is stored prior to refining and at which refined products are stored solely for use at the facility; a carbon dioxide geologic storage facility; and a gathering, transmission, or distribution pipeline that will transport crude oil or natural gas, including natural gas liquids, prior to refining of such oil or the use of the natural gas in any manufacturing process or as a residential or industrial fuel.

Where required by federal law, discharges of stormwater associated with construction activities under the RRC's jurisdiction must be authorized by the EPA and the RRC, as applicable. Activities under RRC jurisdiction include construction of a facility that, when completed, would be associated with the exploration, development, or production of oil or gas or geothermal resources, such as a well site; treatment or storage facility; underground hydrocarbon or natural gas storage facility; reclamation plant; gas processing facility; compressor station; terminal facility where crude oil is stored prior to refining and at which refined products are stored solely for use at the facility; a carbon dioxide geologic storage facility under the jurisdiction of the RRC; and a gathering, transmission, or distribution pipeline that will transport crude oil or natural gas, including natural gas liquids, prior to refining of such oil or the use of the natural gas in any manufacturing process or as a residential or industrial fuel. The RRC also has jurisdiction over stormwater from land disturbance associated with a site survey that is conducted prior to construction of a facility that would be regulated by the RRC. Under 33 U.S.C. §1342(1)(2) and §1362(24), EPA cannot require a permit for discharges of stormwater from field activities or operations associated with {oil and gas} exploration, production, processing, or treatment operations, or transmission facilities, including activities necessary to prepare a site for drilling and for the movement and placement of drilling equipment, whether or not such field activities or operations may be considered to be construction activities unless the discharge is contaminated by contact with any overburden, raw material, intermediate product, finished product, byproduct, or waste product located on the site of the facility. Under §3.8 of this title (relating to Water Protection), the RRC prohibits operators from causing or allowing pollution of surface or subsurface water. Operators are encouraged to implement and maintain best management practices (BMPs) to minimize discharges of pollutants, including sediment, in stormwater during construction activities to help ensure protection of surface water quality during storm events.

For more information about the jurisdictions of the RRC and the TCEQ, read the Memorandum of Understanding (MOU) between the RRC and TCEQ at 16 Texas Administrative Code, Part 1, Chapter 3, Rule 3.30, by entering the following link into an internet browser:

[http://texreg.sos.state.tx.us/public/readtac\\$ext.TacPage?sl=R&app=9&p_dir=&p_rloc=&p_tloc=&p_ploc=&pg=1&p_tac=&ti=16&pt=1&ch=3&rl=30](http://texreg.sos.state.tx.us/public/readtac$ext.TacPage?sl=R&app=9&p_dir=&p_rloc=&p_tloc=&p_ploc=&pg=1&p_tac=&ti=16&pt=1&ch=3&rl=30) or contact the TCEQ Stormwater Team at 512-239-4671 for additional information.

c) Primary Standard Industrial Classification (SIC) Code

Provide the SIC Code that best describes the construction activity being conducted at this site.

Common SIC Codes related to construction activities include:

- 1521 - Construction of Single Family Homes

- 1522 - Construction of Residential Buildings Other than Single Family Homes
- 1541 - Construction of Industrial Buildings and Warehouses
- 1542 - Construction of Non-residential Buildings, other than Industrial Buildings and Warehouses
- 1611 - Highway and Street Construction, except Highway Construction
- 1622 - Bridge, Tunnel, and Elevated Highway Construction
- 1623 - Water, Sewer, Pipeline and Communications, and Power Line Construction

For help with SIC Codes, enter the following link into your internet browser:

<http://www.osha.gov/pls/imis/sicsearch.html> or you can contact the TCEQ Small Business and Local Government Assistance Section at 800-447-2827 for assistance.

d) Secondary SIC Code

Secondary SIC Code(s) may be provided. Leave this blank if not applicable. For help with SIC Codes, enter the following link into your internet browser:

<http://www.osha.gov/pls/imis/sicsearch.html> or you can contact the TCEQ Small Business and Environmental Assistance Section at 800-447-2827 for assistance.

e) Total Number of Acres Disturbed

Provide the approximate number of acres that the construction site will disturb.

Construction activities that disturb less than one acre, unless they are part of a larger common plan that disturbs more than one acre, do not require permit coverage.

Construction activities that disturb between one and five acres, unless they are part of a common plan that disturbs more than five acres, do not require submission of an NOI.

Therefore, the estimated area of land disturbed should not be less than five, unless the project is part of a larger common plan that disturbs five or more acres. Disturbed means any clearing, grading, excavating, or other similar activities.

If you have any questions about this item, please contact the stormwater technical staff by phone at 512-239-4671 or by email at swgp@tceq.texas.gov.

f) Common Plan of Development

Construction activities that disturb less than five acres do not require submission of an NOI unless they are part of a common plan of development or for sale where the area disturbed is five or more acres. Therefore, the estimated area of land disturbed should not be less than five, unless the project is part of a larger common plan that disturbs five or more acres. Disturbed means any clearing, grading, excavating, or other similar activities.

For more information on what a common plan of development is, refer to the definition of “Common Plan of Development” in the Definitions section of the general permit or enter the following link into your internet browser:

www.tceq.texas.gov/permitting/stormwater/common_plan_of_development_steps.html

For further information, go to the TCEQ stormwater construction webpage enter the following link into your internet browser: www.tceq.texas.gov/goto/construction and search for “Additional Guidance and Quick Links”. If you have any further questions about the Common Plan of Development you can contact the TCEQ Stormwater Team at

512-239-4671 or the TCEQ Small Business and Environmental Assistance at 800-447-2827.

g) Estimated Start Date of the Project

This is the date that any construction activity or construction support activity is initiated at the site. If renewing the permit provide the original start date of when construction activity for this project began.

h) Estimated End Date of the Project

This is the date that any construction activity or construction support activity will end and final stabilization will be achieved at the site.

i) Will concrete truck washout be performed at the site?

Indicate if you expect that operators of concrete trucks will washout concrete trucks at the construction site.

j) Identify the water body(s) receiving stormwater runoff

The stormwater may be discharged directly to a receiving stream or through a MS4 from your site. It eventually reaches a receiving water body such as a local stream or lake, possibly via a drainage ditch. You must provide the name of the water body that receives the discharge from the site (a local stream or lake).

If your site has more than one outfall you need to include the name of the first water body for each outfall, if they are different.

k) Identify the segment number(s) of the classified water body(s)

Identify the classified segment number(s) receiving a discharge directly or indirectly. Enter the following link into your internet browser to find the segment number of the classified water body where stormwater will flow from the site:

www.tceq.texas.gov/waterquality/monitoring/viewer.html or by contacting the TCEQ Water Quality Division at (512) 239-4671 for assistance.

You may also find the segment number in TCEQ publication GI-316 by entering the following link into your internet browser: www.tceq.texas.gov/publications/gi/gi-316 or by contacting the TCEQ Water Quality Division at (512) 239-4671 for assistance.

If the discharge is into an unclassified receiving water and then crosses state lines prior to entering a classified segment, select the appropriate watershed:

- 0100 (Canadian River Basin)
- 0200 (Red River Basin)
- 0300 (Sulfur River Basin)
- 0400 (Cypress Creek Basin)
- 0500 (Sabine River Basin)

Call the Water Quality Assessments section at 512-239-4671 for further assistance.

l) Discharge into MS4 – Identify the MS4 Operator

The discharge may initially be into a municipal separate storm sewer system (MS4). If the stormwater discharge is into an MS4, provide the name of the entity that operates the MS4 where the stormwater discharges. An MS4 operator is often a city, town, county, or utility district, but possibly can be another form of government. Please note that the Construction General Permit requires the Operator to supply the MS4 with a copy of the NOI submitted to TCEQ. For assistance, you may call the technical staff at 512-239-4671.

m) Discharges to the Edwards Aquifer Recharge Zone and Certification

The general permit requires the approved Contributing Zone Plan or Water Pollution Abatement Plan to be included or referenced as a part of the Stormwater Pollution Prevention Plan.

See maps on the TCEQ website to determine if the site is located within the Recharge Zone, Contributing Zone, or Contributing Zone within the Transition Zone of the Edwards Aquifer by entering the following link into an internet browser:

www.tceq.texas.gov/field/eapp/viewer.html or by contacting the TCEQ Water Quality Division at 512-239-4671 for assistance.

If the discharge or potential discharge is within the Recharge Zone, Contributing Zone, or Contributing Zone within the Transition Zone of the Edwards Aquifer, a site-specific authorization approved by the Executive Director under the Edwards Aquifer Protection Program (30 TAC Chapter 213) is required before construction can begin.

For questions regarding the Edwards Aquifer Protection Program, contact the appropriate TCEQ Regional Office. For projects in Hays, Travis and Williamson Counties: Austin Regional Office, 12100 Park 35 Circle, Austin, TX 78753, 512-339- 2929. For Projects in Bexar, Comal, Kinney, Medina and Uvalde Counties: TCEQ San Antonio Regional Office, 14250 Judson Rd., San Antonio, TX 78233-4480, 210-490- 3096.

Section 5. NOI CERTIFICATION

Note: Failure to indicate Yes to all of the certification items may result in denial of coverage under the general permit.

a) Certification of Understanding the Terms and Conditions of Construction General Permit (TXR150000)

Provisional coverage under the Construction General Permit (TXR150000) begins 7 days after the completed paper NOI is postmarked for delivery to the TCEQ. Electronic applications submitted through ePermits have immediate provisional coverage. You must obtain a copy and read the Construction General Permit before submitting your application. You may view and print the Construction General Permit for which you are seeking coverage at the TCEQ web site by entering the following link into an internet browser: www.tceq.texas.gov/goto/construction or you may contact the TCEQ Stormwater processing Center at 512-239-3700 for assistance.

b) Certification of Legal Name

The full legal name of the applicant as authorized to do business in Texas is required. The name must be provided exactly as filed with the Texas Secretary of State (SOS), or on

other legal documents forming the entity, that is filed in the county where doing business. You may contact the SOS at 512-463 5555, for more information related to filing in Texas.

c) Understanding of Notice of Termination

A permittee shall terminate coverage under the Construction General Permit through the submittal of a NOT when the operator of the facility changes, final stabilization has been reached, the discharge becomes authorized under an individual permit, or the construction activity never began at this site.

d) Certification of Stormwater Pollution Prevention Plan

The SWP3 identifies the areas and activities that could produce contaminated runoff at your site and then tells how you will ensure that this contamination is mitigated. For example, in describing your mitigation measures, your site's plan might identify the devices that collect and filter stormwater, tell how those devices are to be maintained, and tell how frequently that maintenance is to be carried out. You must develop this plan in accordance with the TCEQ general permit requirements. This plan must be developed and implemented before you complete this NOI. The SWP3 must be available for a TCEQ investigator to review on request.

Section 6. APPLICANT CERTIFICATION SIGNATURE

The certification must bear an original signature of a person meeting the signatory requirements specified under 30 Texas Administrative Code (TAC) §305.44.

If you are a corporation:

The regulation that controls who may sign an NOI or similar form is 30 Texas Administrative Code §305.44(a)(1) (see below). According to this code provision, any corporate representative may sign an NOI or similar form so long as the authority to sign such a document has been delegated to that person in accordance with corporate procedures. By signing the NOI or similar form, you are certifying that such authority has been delegated to you. The TCEQ may request documentation evidencing such authority.

If you are a municipality or other government entity:

The regulation that controls who may sign an NOI or similar form is 30 Texas Administrative Code §305.44(a)(3) (see below). According to this code provision, only a ranking elected official or principal executive officer may sign an NOI or similar form. Persons such as the City Mayor or County Commissioner will be considered ranking elected officials. In order to identify the principal executive officer of your government entity, it may be beneficial to consult your city charter, county or city ordinances, or the Texas statute(s) under which your government entity was formed. An NOI or similar document that is signed by a government official who is not a ranking elected official or principal executive officer does not conform to §305.44(a)(3). The signatory requirement may not be delegated to a government representative other than those identified in the regulation. By signing the NOI or similar form, you are certifying that you are either a ranking elected official or principal executive officer as required by the administrative code. Documentation demonstrating your position as a ranking elected official or principal executive officer may be requested by the TCEQ.

If you have any questions or need additional information concerning the signatory requirements discussed above, please contact the TCEQ's Environmental Law Division at 512-239-0600.

30 Texas Administrative Code

§305.44. Signatories to Applications

(a) All applications shall be signed as follows.

(1) For a corporation, the application shall be signed by a responsible corporate officer. For purposes of this paragraph, a responsible corporate officer means a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or the manager of one or more manufacturing, production, or operating facilities employing more than 250 persons or having gross annual sales or expenditures exceeding \$25 million (in second-quarter 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. Corporate procedures governing authority to sign permit or post-closure order applications may provide for assignment or delegation to applicable corporate positions rather than to specific individuals.

(2) For a partnership or sole proprietorship, the application shall be signed by a general partner or the proprietor, respectively.

(3) For a municipality, state, federal, or other public agency, the application shall be signed by either a principal executive officer or a ranking elected official. For purposes of this paragraph, a principal executive officer of a federal agency includes the chief executive officer of the agency, or a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., regional administrator of the EPA).

Texas Commission on Environmental Quality General Permit Payment Submittal Form

Use this form to submit your Application Fee only if you are mailing your payment.

Instructions:

- Complete items 1 through 5 below:
- Staple your check in the space provided at the bottom of this document.
- *Do not mail this form with your NOI form.*
- *Do not mail this form to the same address as your NOI.*

Mail this form and your check to either of the following:

By Regular U.S. Mail

Texas Commission on Environmental
Quality Financial Administration
Division
Cashier's Office, MC-214
P.O. Box 13088
Austin, TX 78711-3088

By Overnight or Express Mail

Texas Commission on Environmental
Quality Financial Administration
Division
Cashier's Office,
MC-214 12100
Park 35 Circle
Austin, TX 78753

Fee Code: GPA General Permit: TXR150000

1. Check or Money Order No:
2. Amount of Check/Money Order:
3. Date of Check or Money Order:
4. Name on Check or Money Order:
5. NOI Information:

If the check is for more than one NOI, list each Project or Site (RE) Name and Physical Address exactly as provided on the NOI. **Do not submit a copy of the NOI with this form, as it could cause duplicate permit application entries!**

If there is not enough space on the form to list all of the projects or sites the authorization will cover, then attach a list of the additional sites.

Project/Site (RE) Name:

Project/Site (RE) Physical Address:

Staple the check or money order to this form in this space.

ATTACHMENT 2



SMALL CONSTRUCTION SITE NOTICE

FOR THE
Texas Commission on Environmental Quality (TCEQ)
Stormwater Program
TPDES GENERAL PERMIT TXR150000

The following information is posted in compliance with **Part II.E.2.** of the TCEQ General Permit Number TXR150000 for discharges of stormwater runoff from small construction sites. Additional information regarding the TCEQ stormwater permit program may be found on the internet at:

http://www.tceq.state.tx.us/nav/permits/wq_construction.html

Operator Name:	
Contact Name and Phone Number:	
Project Description: <i>Physical address or description of the site's location, estimated start date and projected end date, or date that disturbed soils will be stabilized</i>	
Location of Stormwater Pollution Prevention Plan:	

For Small Construction Activities Authorized Under Part II.E.2. (Obtaining Authorization to Discharge) the following certification must be completed:

I _____ (Typed or Printed Name Person Completing This Certification) certify under penalty of law that I have read and understand the eligibility requirements for claiming an authorization under Part II.E.2. of TPDES General Permit TXR150000 and agree to comply with the terms of this permit. A stormwater pollution prevention plan has been developed and will be implemented prior to construction, according to permit requirements. A copy of this signed notice is supplied to the operator of the MS4 if discharges enter an MS4. I am aware there are significant penalties for providing false information or for conducting unauthorized discharges, including the possibility of fine and imprisonment for knowing violations.

Signature and Title _____ Date _____

_____ *Date Notice Removed*

_____ *MS4 operator notified per Part II.F.3.*

ATTACHMENT 3

TPDES OPERATOR'S INFORMATION

Owner's Name and Address: City of Houston

Mr.
(City Official)

(Department)
1002 Washington Ave, 2nd FL
Houston, TX 77002
(832) 394-9108

Contractors' Names and Addresses:

General Contractor: _____

Telephone: _____

Site Superintendent: _____

Telephone: _____

Erosion Control and
Maintenance Inspection: _____

Telephone: _____

Subcontractors' Names and Addresses:

Phone: _____

Phone: _____

Note: Insert name, address, and telephone number of person or firms

ATTACHMENT 4

CONTRACTOR'S / SUBCONTRACTOR'S

CERTIFICATION FOR TPDES PERMITTING

I certify under penalty of law that I understand the terms and conditions of TPDES General Permit No. TXR150000 and the Storm Water Pollution Prevention Plan for the construction site identified as part of this certification.

Signature: _____
Name: (printed or typed) _____
Title: _____
Company: _____
Address: _____
Date: _____

Signature: _____
Name: (printed or typed) _____
Title: _____
Company: _____
Address: _____
Date: _____

Signature: _____
Name: (printed or typed) _____
Title: _____
Company: _____
Address: _____
Date: _____

ATTACHMENT 5



City of Houston
Storm Water Quality
Construction Site Activities Inspection Report

TCEQ Stormwater Discharge Permit Number _____

COH Storm Water Quality Permit Number _____

COH Building Permit Login Number _____

NAME _____ DATE _____

ADDRESS _____

- No exceptions noted.
The following deficiencies have been noted:
NOI / Construction Site Notice Improperly Posted
Stormwater Pollution Prevention Plan Incomplete or requires updating
Copy of NOI / CSN not on site
Storm Water Pollution Prevention Plan not on site
Erosion and sediment controls improperly installed
Erosion and sediment control devices improperly maintained
Fueling/washout/chemical storage areas not properly protected
Portocan or other sanitary facilities not properly protected or leaking
Self-inspection and maintenance records incomplete
Sediment from site outside area of construction
Other (see description below)

The deficiencies must be corrected:
immediately; within 48 hours;
prior to re-inspection

Should the noted deficiencies not be corrected in the time frame indicated, further enforcement remedies will be sought.

For questions concerning the above:
Please contact the Storm Water Quality Group at
1002 Washington Avenue, 2nd Floor, Houston TX 77002
832-394-9108

Inspector's Name

Operator's Signature

Inspector's Cell Phone

Operator's Name
not present

Distribution: white - Stormwater Quality Engineer gold - operator

TCEQ Office Use Only
Permit No:
CN:
RN:
Region:



Notice of Termination (NOT) for Authorizations under TPDES General Permit TXR150000

IMPORTANT INFORMATION:

Please read and use the General Information and Instructions prior to filling out each question in the form.

Effective September 1, 2018, this paper form must be submitted to TCEQ with a completed electronic reporting waiver form (TCEQ-20754).

ePermits: This form is available on our online permitting system.
Sign up for online permitting at: <https://www3.tceq.texas.gov/steers/>

What is the permit number to be terminated?

TXR15 [redacted] TXRCW [redacted]

Section 1. OPERATOR (Permittee)

a) What is the Customer Number (CN) issued to this entity?

CN [redacted]

b) What is the Legal Name of the current permittee?

[redacted]

c) Provide the contact information for the Operator (Responsible Authority).

Prefix (Mr. Ms. or Miss): [redacted]

First and Last Name: [redacted] Suffix: [redacted]

Title: [redacted] Credentials: [redacted]

Phone Number: [redacted] Fax Number: [redacted]

Email: [redacted]

Mailing Address: [redacted]

City, State, and Zip Code: [redacted]

Country Mailing Information, if outside USA: [redacted]

Section 2. APPLICATION CONTACT

This is the person TCEQ will contact if additional information is needed regarding this application.

Is the application contact the same as the permittee identified above?

Yes, go to Section 3.

No, complete section below

Prefix (Mr. Ms. or Miss):

First and Last Name: Suffix:

Title: Credentials:

Phone Number: Fax Number:

Email:

Mailing Address:

City, State, and Zip Code:

Country Mailing Information, if outside USA:

Section 3. REGULATED ENTITY (RE) INFORMATION ON PROJECT OR SITE

a) TCEQ issued RE Reference Number(RN): RN

b) Name of project or site as known by the local community:

c) County, or counties if more than 1:

d) Latitude: Longitude:

e) Site Address/Location:

If the site has a physical address such as 12100 Park 35 Circle, Austin, TX 78753, complete Section 3A.

If the site does not have a physical address, provide a location description in Section 3B. Example: located on the north side of FM 123, 2 miles west of the intersection of FM 123 and Highway 1.

Section 3A: Physical Address of Project or Site:

Street Number and Name:

City, State, and Zip Code:

Section 3B: Site Location Description:

Location description:

City where the site is located or, if not in a city, what is the nearest city:

Zip Code where the site is located:

Section 4. REASON FOR TERMINATION

Check the reason for termination:

- Final stabilization has been achieved on all portions of the site that are the responsibility of the Operator and all silt fences and other temporary erosion controls have been removed, or scheduled for removal as defined in the SWP3.

- Another permitted Operator has assumed control over all areas of the site that have not been finally stabilized, and temporary erosion controls that have been identified in the SWP3 have been transferred to the new Operator.
- The discharge is now authorized under an alternate TPDES permit.
- The activity never began at this site that is regulated under the general permit.

Section 5. CERTIFICATION

Signatory Name: _____

Signatory Title: _____

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I further certify that I am authorized under 30 Texas Administrative Code §305.44 to sign and submit this document, and can provide documentation in proof of such authorization upon request.

Signature (use blue ink): _____ Date: _____

Instructions for Notice of Termination (NOT) for Authorizations under TPDES General Permit TXR150000

GENERAL INFORMATION

Where to Send the Notice of Termination (NOT):

BY REGULAR U.S. MAIL:

Texas Commission on Environmental Quality
Stormwater Processing Center (MC-228)
P.O. Box 13087
Austin, Texas 78711-3087

BY OVERNIGHT/EXPRESS MAIL:

Texas Commission on Environmental Quality
Stormwater Processing Center (MC-228)
12100 Park 35 Circle
Austin, TX 78753

TCEQ Contact List:

Application status and form questions:	512-239-3700, swpermit@tceq.texas.gov
Technical questions:	512-239-4671, swgp@tceq.texas.gov
Environmental Law Division:	512-239-0600
Records Management - obtain copies of forms:	512-239-0900
Reports from databases (as available):	512-239-DATA (3282)
Cashier's office:	512 239-0357 or 512-239-0187

Notice of Termination Process:

A Notice of Termination is **effective on the date postmarked for delivery to TCEQ.**

When your NOT is received by the program, the form will be processed as follows:

- 1) Administrative Review: The form will be reviewed to confirm the following:
 - the permit number is provided;
 - the permit is active and has been approved;
 - the entity terminating the permit is the current permittee;
 - the site information matches the original permit record; and
 - the form has the required original signature with title and date.
- 2) Notice of Deficiency: If an item is incomplete or not verifiable as indicated above, a phone call will be made to the applicant to clear the deficiency. A letter will not be sent to the permittee if unable to process the form.
- 3) Confirmation of Termination: A Notice of Termination Confirmation letter will be mailed to the operator.

Change in Operator:

An authorization under the general permit is not transferable. If the operator of the regulated entity changes, the present permittee must submit a Notice of Termination and the new operator must submit a Notice of Intent. The NOT and NOI must be submitted not later than 10 days prior to the change in Operator status.

INSTRUCTIONS FOR FILLING OUT THE FORM

The majority of permit information related to the current operator and regulated entity are available at the following website: http://www2.tceq.texas.gov/wq_dpa/index.cfm.

Section 1. Operator (Current Permittee):

- a) Customer Number (CN)
TCEQ's Central Registry assigns each customer a number that begins with CN, followed by nine digits. This is not a permit number, registration number, or license number. The Customer Number, for the current permittee, is available at the following website:
http://www2.tceq.texas.gov/wq_dpa/index.cfm.

- b) Legal Name of Operator
The operator must be the same entity as previously submitted on the original Notice of Intent for the permit number provided. The current operator name, as provided on the current authorization, is available at the following website:
http://www2.tceq.texas.gov/wq_dpa/index.cfm.

- c) Contact Information for the Operator (Responsible Authority)
Provide information for person signing the NOT application in the Certification section. This person is also referred to as the Responsible Authority.

Provide a complete mailing address for receiving mail from the TCEQ. Update the address if different than previously submitted for the Notice of Intent or Notice of Change. The mailing address must be recognized by the US Postal Service. You may verify the address on the following website: <https://tools.usps.com/go/ZipLookupAction!input.action>.

The phone number should provide contact to the operator.

The fax number and e-mail address are optional and should correspond to the operator.

Section 2. Application Contact:

Provide the name, title and contact information of the person that TCEQ can contact for additional information regarding this application.

Section 3. Regulated Entity (RE) Information on Project or Site:

- a) Regulated Entity Reference Number (RN)
A number issued by TCEQ's Central Registry to sites where an activity regulated by TCEQ. This is not a permit number, registration number, or license number. The Regulated Entity Reference Number is available at the following website:
http://www2.tceq.texas.gov/wq_dpa/index.cfm.
- b) Name of the Project or Site
Provide the name of the site as known by the public in the area where the site is located.
- c) County
Identify the county or counties in which the regulated entity is located.
- d) Latitude and Longitude
Enter the latitude and longitude of the site in degrees, minutes, and seconds or decimal form. The latitude and longitude as provided on the current authorization is available at the following website: http://www2.tceq.texas.gov/wq_dpa/index.cfm.
- e) Site/Project (RE) Physical Address/Location Information
The physical address/location information, as provided on the current authorization, is available at the following website: http://www2.tceq.texas.gov/wq_dpa/index.cfm.

Section 3A. If a site has an address that includes a street number and street name, enter the complete address for the site. If the physical address is not recognized as a USPS delivery address, you may need to validate the address with your local police (911 service) or through an online map site used to locate the site. Please confirm this to be a complete and valid address. Do not use a rural route or post office box for a site location.

Section 3B. If a site does not have an address that includes a street number and street name, provide a complete written location description. For example: "The site is located on the north side of FM 123, 2 miles west of the intersection of FM 123 and Highway 1."

Provide the city (or nearest city) and Zip Code of the facility location.

Section 4. Reason for Termination:

The Notice of Termination form is only for use to terminate the authorization (permit). The Permittee must indicate the specific reason for terminating by checking one of the options. If the reason is not listed then provide an attachment that explains the reason for termination.

Please read your general permit carefully to determine when to terminate your permit. Permits will not be reactivated after submitting a termination form. The termination is effective on the date postmarked for delivery to TCEQ.

Section 5. Certification:

The certification must bear an original signature of a person meeting the signatory requirements specified under 30 Texas Administrative Code §305.44.

IF YOU ARE A CORPORATION:

The regulation that controls who may sign an application form is 30 Texas Administrative Code §305.44(a), which is provided below. According to this code provision, any corporate representative may sign an NOI or similar form so long as the authority to sign such a document has been delegated to that person in accordance with corporate procedures. By signing the NOI or similar form, you are certifying that such authority has been delegated to you. The TCEQ may request documentation evidencing such authority.

IF YOU ARE A MUNICIPALITY OR OTHER GOVERNMENT ENTITY:

The regulation that controls who may sign an NOI or similar form is 30 Texas Administrative Code §305.44(a), which is provided below. According to this code provision, only a ranking elected official or principal executive officer may sign an NOI or similar form. Persons such as the City Mayor or County Commissioner will be considered ranking elected officials. In order to identify the principal executive officer of your government entity, it may be beneficial to consult your city charter, county or city ordinances, or the Texas statutes under which your government entity was formed. An NOI or similar document that is signed by a government official who is not a ranking elected official or principal executive officer does not conform to §305.44(a) (3). The signatory requirement may not be delegated to a government representative other than those identified in the regulation. By signing the NOI or similar form, you are certifying that you are either a ranking elected official or principal executive officer as required by the administrative code. Documentation demonstrating your position as a ranking elected official or principal executive officer may be requested by the TCEQ.

If you have any questions or need additional information concerning the signatory requirements discussed above, please contact the Texas Commission on Environmental Quality's Environmental Law Division at 512-239-0600.

30 Texas Administrative Code §305.44. Signatories to Applications

(a) All applications shall be signed as follows.

(1) For a corporation, the application shall be signed by a responsible corporate officer. For purposes of this paragraph, a responsible corporate officer means a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or the manager of one or more manufacturing, production, or operating facilities employing more than 250 persons or having gross annual sales or expenditures exceeding \$25 million (in second-quarter 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. Corporate procedures governing authority to sign permit or post-closure order applications may provide for assignment or delegation to applicable corporate positions rather than to specific individuals.

(2) For a partnership or sole proprietorship, the application shall be signed by a general partner or the proprietor, respectively.

(3) For a municipality, state, federal, or other public agency, the application shall be signed by either a principal executive officer or a ranking elected official. For purposes of this paragraph, a principal executive officer of a federal agency includes the chief executive officer of the agency, or a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., regional administrator of the EPA).

Section 3A. If a site has an address that includes a street number and street name, enter the complete address for the site. If the physical address is not recognized as a USPS delivery address, you may need to validate the address with your local police (911 service) or through an online map site used to locate the site. Please confirm this to be a complete and valid address. Do not use a rural route or post office box for a site location.

Section 3B. If a site does not have an address that includes a street number and street name, provide a complete written location description. For example: "The site is located on the north side of FM 123, 2 miles west of the intersection of FM 123 and Highway 1."

Provide the city (or nearest city) and Zip Code of the facility location.

Section 4. Reason for Termination:

The Notice of Termination form is only for use to terminate the authorization (permit). The Permittee must indicate the specific reason for terminating by checking one of the options. If the reason is not listed then provide an attachment that explains the reason for termination.

Please read your general permit carefully to determine when to terminate your permit. Permits will not be reactivated after submitting a termination form. The termination is effective on the date postmarked for delivery to TCEQ.

Section 5. Certification:

The certification must bear an original signature of a person meeting the signatory requirements specified under 30 Texas Administrative Code §305.44.

IF YOU ARE A CORPORATION:

The regulation that controls who may sign an application form is 30 Texas Administrative Code §305.44(a), which is provided below. According to this code provision, any corporate representative may sign an NOI or similar form so long as the authority to sign such a document has been delegated to that person in accordance with corporate procedures. By signing the NOI or similar form, you are certifying that such authority has been delegated to you. The TCEQ may request documentation evidencing such authority.

IF YOU ARE A MUNICIPALITY OR OTHER GOVERNMENT ENTITY:

The regulation that controls who may sign an NOI or similar form is 30 Texas Administrative Code §305.44(a), which is provided below. According to this code provision, only a ranking elected official or principal executive officer may sign an NOI or similar form. Persons such as the City Mayor or County

SECTION 01422

REFERENCE STANDARDS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Section includes general quality assurance as related to reference standards and a list of references.

1.02 QUALITY ASSURANCE

- A. For Products or workmanship specified by association, trade, or Federal standards, comply with requirements of the standard, except when more rigid requirements are specified or are required by applicable codes.
- B. Conform to reference standard by date of issue current on the date as stated in the General Conditions.
- C. Request clarification from Project Manager before proceeding should specified reference standards conflict with Contract documents.

1.03 SCHEDULE OF REFERENCES

- A. AASHTO American Association of State Highway and Transportation Officials
- B. ACI American Concrete Institute
- C. AGC Associated General Contractors of America
- D. AI Asphalt Institute Research
- E. AITC American Institute of Timber Construction
- F. AISC American Institute of Steel Construction
- G. AISI American Iron and Steel Institute
- H. ASME American Society of Mechanical Engineers
- I. AMPP The Association for Materials Protection and Performance
- J. ANSI American National Standards Institute
- K. APA Engineered Wood Association
- L. API American Petroleum Institute

M.	AREMA	American Railway Engineering and Maintenance-of-Way- Association
N.	ASTM	American Society for Testing and Materials International
O.	AWPA	American Wood Protection Association
P.	AWS	American Welding Society
Q.	AWWA	American Water Works Association
R.	COH	City of Houston
S.	CLFMI	Chain Link Fence Manufacturers Institute
T.	CRSI	Concrete Reinforcing Steel Institute
U.	EJMA	Expansion Joint Manufacturers Association
V.	FS	Federal Standardization Documents
W.	ICEA	Insulated Cable Engineers Association
X.	IEEE	Institute of Electrical and Electronics Engineers
Y.	ISA	International Society of Arboriculture
Z.	MIL	Military Specifications
AA.	NACE International	National Association of Corrosion Engineers
BB.	NEMA	National Electrical Manufacturers' Association
CC.	NFPA	National Fire Protection Association
DD.	OSHA	Occupational Safety and Health Administration
EE.	PCA	Portland Cement Association
FF.	PCI	Precast/Prestressed Concrete Institute
GG.	PPI	Plastic Pipes Institute
HH.	SDI	Steel Deck Institute
II.	SSPC	Society for Protective Coatings
JJ.	TAC	Texas Administrative Code
KK.	TxDOT	Texas Department of Transportation
LL.	UL	Underwriters' Laboratories, Inc.

MM. UNI-BELL PVC Pipe Association

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01450

CONTRACTOR'S QUALITY CONTROL

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Quality assurance and control of Installation and manufacturers' field services and reports.

1.02 QUALITY ASSURANCE AND CONTROL OF INSTALLATION

- A. Monitor quality control over Suppliers, manufacturers, Products, services, site conditions and workmanship, to produce work of specified quality at no additional cost to the City.
- B. Comply fully with manufacturers' Installation instructions, including each step in sequence.
- C. Request clarification from Project Manager before proceeding when manufacturers' instructions conflict with the Contract.
- D. Comply with specified standards as minimum requirements for the Work except when more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Perform the Work by persons qualified to produce a specified level of workmanship.

1.03 REFERENCES

- A. Obtain copies of standards and maintain at job site when required by individual Specification sections.

1.04 MANUFACTURERS' FIELD SERVICES AND REPORTS

- A. When specified in individual Specification sections, or as required by Project Manager, provide Product suppliers' or manufacturers' technical representative to observe the following:
 - 1. Site conditions;
 - 2. Conditions of surfaces and Installation;
 - 3. Quality of workmanship;
 - 4. Start-up of equipment;
 - 5. Operator training; and

6. Testing, adjusting and balancing of equipment as applicable to initiate required operation.
 - B. Conform to minimum time requirements for start-up operations and operator training when provided in Specification sections.
 - C. At Project Manager's request, submit qualifications of manufacturers' representative to Project Manager 15 days in advance of required representatives' services. Representative is subject to approval by Project Manager.
 - D. Manufacturer's representatives shall report observations and site decisions, or instructions given to applicators or installers that are supplemental or contrary to a manufacturer's written instructions. Submit report within 14 days of observation to Project Manager for review.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01452

INSPECTION SERVICES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Inspection services and references

1.02 RELATED SECTIONS

- A. Section 01454 – Testing Laboratory Services

1.03 INSPECTION

- A. City Engineer will appoint an Inspector to represent the City and perform inspections, tests, and other services specified in individual Specification sections.
- B. City Engineer may also appoint, employ, and pay an independent firm to provide additional inspection or construction management services as indicated in Section 01454 - Testing Laboratory Services.
- C. The independent firm will submit reports to Project Manager, indicating observations and results of tests and indicating compliance or noncompliance with Contract requirements.
- D. Contractor shall assist and cooperate with the Inspector; furnish samples of materials, design mix, equipment, tools, and storage.
- E. Contractor shall notify Project Manager 24 hours prior to expected time for operations requiring services.
- F. Contractor shall sign and acknowledge reports for Inspector.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01454

TESTING LABORATORY SERVICES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Testing laboratory services and Contractor responsibilities related to those services.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions

1.03 REFERENCES

- A. ASTM C 1077 - Standard Practice for Laboratories Testing Concrete and Concrete Aggregates for Use in Construction and Criteria for Laboratory Evaluation.
- B. ASTM D 3666 - Standard Specification for Minimum Requirements for Agencies Testing and Inspecting Bituminous Paving Materials.
- C. ASTM D 3740 - Standard Practice for Minimum Requirements for Agencies Engaged in the Testing and/or Inspection of Soil and Rock as Used in Engineering Design and Construction.
- D. ASTM E 329 - Standard Specification for Minimum Requirements for Agencies Engaged in the Testing and/or Inspection of Materials Used in Construction.
- E. ISO/TEC Guide 25 - General Requirements for the Competence of Calibration and Testing Laboratories.

1.04 SELECTION AND PAYMENT

- A. The City will select, employ, and pay for services of an independent testing laboratory to perform inspection and testing identified in Part 3 of individual Specification sections.
- B. Contractor shall employ and pay for services of an independent testing laboratory or laboratories to perform inspection and testing identified in Part 2 of individual Specification sections.
- C. Employment of a testing laboratory by the City shall not relieve Contractor of its obligation to perform work in accordance with requirements of Contract documents.
- D. The City will deduct a minimum two-hour charge for testing laboratory time from periodic progress payment when operations requiring testing or inspection are canceled without prior notification.

- E. The City will deduct cost of retesting from periodic progress payment whenever failed work is removed, replaced and retested.

1.05 QUALIFICATION OF LABORATORY

- A. Meet laboratory requirements of ASTM E 329 and applicable requirements of ASTM C 1077, ASTM D 3666, and ASTM D 3740.
- B. Meet ISO/TEC Guide 17025 conditions for accreditation by the American Association for Laboratory Accreditation (A2LA) in specific fields of testing required in individual Specification sections.
- C. If laboratory subcontracts are part of the testing services, such work will be placed with a laboratory complying with the requirements of this Section.

1.06 LABORATORY REPORTS

- A. Testing laboratory shall provide and distribute copies of laboratory reports to the distribution list Project Manager provides at the pre-construction conference.
- B. Keep one copy of each laboratory report distributed or faxed at the site field office for duration of the Work.
- C. Laboratory will fax material supplier, Contractor and Project Manager reports that indicate failing test results by no later than close of business on the working day following test completion and review.

1.07 LIMITS ON TESTING LABORATORY AUTHORITY

- A. Laboratory may not release, revoke, alter, or enlarge requirements of the Contract.
- B. Laboratory may not approve or accept any portion of the Work.
- C. Laboratory may not assume Contractor duties.
- D. Laboratory has no authority to stop the Work.

1.08 CONTRACTOR RESPONSIBILITIES

- A. Provide safe access to the Work and to manufacturer's facilities for Project Manager and for testing laboratory personnel.
- B. Provide testing laboratory with a copy of the Construction Schedule and a copy of each update to Construction Schedule.
- C. Notify Project Manager and testing laboratory during normal working hours of the day previous to expected time for operations requiring inspection and testing services. When Contractor fails to make timely prior notification, do not proceed with the operations requiring inspection and testing services.

- D. Notify Design Consultant 24 hours in advance when Specification requires presence of Design Consultant for sampling or testing.
- E. Request and monitor testing as required to provide timely results and to avoid delays to the Work. Provide samples to laboratory in sufficient time to allow required test to be performed in accordance with specified test methods before intended use of the Product.
- F. Cooperate with laboratory personnel in collecting samples on site. Provide incidental labor and facilities for safe access to the Work to be tested, to obtain and handle samples at site or at source of Products to be tested, and to facilitate tests and inspections including storage and curing of test samples.
- G. Make arrangements with laboratory through Project Manager. Payment for additional testing will be made in accordance with Document 00700 - General Conditions:
 - 1. Re-testing required for failed tests.
 - 2. Re-testing for nonconforming work.
 - 3. Additional sampling and tests requested beyond specified requirements.
 - 4. Insufficient notification of cancellation of tests for work scheduled but not performed.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 CONDUCTING TESTING

- A. Conform to laboratory sampling and testing methods specified in individual Specification sections to the latest issues of ASTM standards, TxDOT methods, or other recognized test standards as approved by Project Manager.
- B. Requirements of this Section shall also apply to those tests for approval of materials, for mix designs, and for quality control of materials as performed by employed testing laboratories.

END OF SECTION

SECTION 01502

MOBILIZATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Mobilization of construction equipment and facilities onto the site.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01145 – Use of Premises
- C. Section 01292 – Schedule of Values
- D. Section 01321 – Construction Photographs
- E. Section 01325 – Construction Schedule
- F. Section 01326 – Construction Schedule (Bar Chart)
- G. Section 01330 – Submittal Procedures
- H. Section 01410 – TPDES Requirements
- I. Section 01450 – Contractor's Quality Control
- J. Section 01520 – Temporary Field Office
- K. Section 01555 – Traffic Control and Regulation
- L. Section 01578 – Control of Ground and Surface Water
- M. Section 01580 – Project Identification Signs
- N. Section 01582 – Build Houston Forward Project Identification Signs
- O. Section 02260 – Trench Safety System

1.03 MEASUREMENT AND PAYMENT

- A. Unit Price Contracts. If Contract is Unit Price Contract, measurement for mobilization is on a lump sum basis.
- B. Stipulated Price (Lump Sum) Contract. If Contract is Stipulated Price Contract, payment for Work in this Section is included in total Stipulated Price.

- C. Mobilization payments will be included in monthly payment estimates upon written application by Contractor subject to the following provisions:
1. Authorization for payment of 50 percent of that portion of Contract Price designated for mobilization will be made upon receipt and approval by Project Manager of the following items, as applicable:
 - a. Safety Program (Document 00700, Paragraph 10.1.1).
 - b. Site Utilization Plan (Section 01145).
 - c. Schedule of Values (Section 01292), if any.
 - d. Initial Construction Photographs (Section 01321), if needed.
 - e. Preliminary Construction Schedule and Billing Forecast (Section 01325).
 - f. Construction Schedule (Section 01325 or Section 01326, as applicable).
 - g. Submittal Schedule (Section 01330).
 - h. Site specific Storm Water Pollution Prevention Plan (SWPPP) and Notice of Intent (NOI) along with storm water application fee (Section 01410), if required.
 - i. Contractor's Quality Control Plan (Section 01450), if required.
 - j. Establishment of a Field Office for Project Manager meeting requirements of Section 01520 – Temporary Field Office.
 - k. Traffic Control Plan (Section 01555), if required.
 - l. Plan for Control of Ground and Surface Water (Section 01578), if required.
 - m. Project Signs Submittal (Section 01580 or Section 01582).
 - n. Trench Safety Program (Section 02260), if required.
 - o. Dewatering plan, when required.
 2. Authorization for payment of the balance of that portion of Contract Price designated for mobilization will be made upon completion of the Work amounting to five percent of Original Contract Price. The amount of Contract Price designated for mobilization may not be applied in computing whether or not five percent of the Original Contract Price has been obtained.

3. Mobilization payments will be subject to retainage amounts stipulated in Document 00700 – General Conditions.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01504

TEMPORARY FACILITIES AND CONTROLS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary facilities and necessary controls for the Project, including utilities, telephone, sanitary facilities, storage sheds and building, safety requirements, first aid equipment, fire protection, security measures, protection of the Work and property, access roads and parking, environmental controls, pest and rodent control and disposal of trash, debris and excavated material.
- B. Facilities and controls specified in this section are considered minimum for the Project. Provide additional facilities and controls for proper execution of the Work and to meet Contractor's responsibilities for protection of persons and property.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01410 – TPDES Requirements
- C. Section 01555 – Traffic Control and Regulation
- D. Section 02260 – Trench Safety System

1.03 MEASUREMENT AND PAYMENT

A. UNIT PRICES

- 1. No separate payment will be made for any temporary facilities and controls required under this section. Include cost of such work in contract price listed for mobilization.

1.04 CONTRACTOR'S RESPONSIBILITY

- A. Comply with applicable requirements specified in other sections of Specifications.
 - 1. Maintain and operate temporary facilities and systems to assure continuous service.
 - 2. Modify and extend systems as the Work progress requires.
 - 3. Completely remove temporary materials and equipment when no longer required.

4. Restore existing facilities used for temporary services to specified or original condition.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 TEMPORARY UTILITIES

A. Obtaining Temporary Service:

1. Make arrangements with utility service companies for temporary services.
2. Abide by rules and regulations of the utility service companies or authorities having jurisdiction.
3. Be responsible for utility service costs until Date of Substantial Completion. Included are fuel, power, light, heat, and other utility services necessary for execution, completion, testing, and initial operation of work.

B. Water:

1. Provide water required for and in connection with work to be performed and for specified tests of piping, equipment, devices, or for other use as required for proper completion of the Work.
2. Water to be drawn from public fire hydrants. Obtain transit meter from City of Houston, Houston Public Works, Taps and Meters Section. Pay required deposit based on rates established by latest ordinance.
3. Provide and maintain an adequate supply of potable water for domestic consumption by Contractor personnel, Project Manager and representatives of the City.

C. Electricity and lighting:

1. Provide electric power service required for the Work including required testing, lighting, operation of equipment, and other Contractor use.
2. Electric power service includes temporary power or generators required to maintain plant operations during scheduled shutdowns.
3. Minimum lighting level shall be 10 foot-candles for open areas; 20-foot-candles for stairs and shops. Provide a minimum of one 300-watt lamp for each 200 square feet of work area.

D. Temporary Heat and Ventilation:

1. Provide temporary heat necessary for protection or completion of the Work.
 2. Provide temporary heat and ventilation to assure safe working conditions; maintain enclosed areas at a minimum of 50 degrees F.
- E. Telephone:
1. Provide emergency telephone service at Project site for use by Contractor personnel and others performing work or furnishing services at the site.
 2. Provide Houston-Metro lines, allowing unlimited calls, without charge in Greater Houston Metropolitan area with "call waiting" and "call forwarding" options. Provide one telephone answering machine with beepless remote message retrieval capability.
- F. Sanitary Facilities:
1. Provide and maintain sanitary facilities for persons on the site; comply with regulations of State and local departments of health.
 2. Enforce use of sanitary facilities by construction personnel at site. Enclose sanitary facilities. Pit-type toilets are not permitted. No discharge will be allowed from these facilities. Collect and store sewage and waste so as not to cause nuisance or health problems. Haul sewage and waste off-site and properly dispose in accordance with applicable regulations.
 3. Locate toilets near the Work site and secluded from view insofar as possible. Keep toilets clean and supplied throughout the course of the Work.

3.02 STORAGE SHEDS AND BUILDINGS

- A. Provide adequately ventilated, watertight storage facilities with floor above ground level for Products susceptible to weather damage.
- B. Storage of Products not susceptible to weather damage may be on blocks off the ground.
- C. Store Products in a neat and orderly manner. Place Products to permit easy access for identification, inspection and inventory.
- D. Fill and grade site for temporary structures to provide drainage away from temporary and existing buildings.

3.03 SAFETY REQUIREMENTS

- A. Submit a safety program at the pre-construction meeting and follow the program in accordance with Document 00700 – General Conditions. Include documented response to trench safety requirements of Section 02260 - Trench Safety System.

- B. Conduct operations in strict accordance with applicable Federal, State and local safety codes and statutes and with good construction practice. Establish and maintain procedures for safety of all work, personnel and equipment involved in the Work.
- C. Observe and comply with Texas Occupational Safety Act (Art. 5182a, V.C.S.) and with all safety and health standards promulgated by Secretary of Labor under Section 107 of Contract Work Hours and Standards Act, published in 29 CFR Part 1926 and adopted by Secretary of Labor as occupational safety and health standards under Williams-Steiger Occupational Safety and Health Act of 1970, and to other legislation enacted for safety and health of Contractor employees. Safety and health standards apply to Subcontractors and Suppliers as well as to the Contractor.
- D. Observance of and compliance with safety regulations is Contractor's responsibility without reliance or superintendence of or direction by Project Manager. Immediately advise Project Manager of investigation or inspection by Federal Safety and Health inspectors of Contractor's or Subcontractor's work or place of work on site under the Contract, and after investigation or inspection, advise Project Manager of results. Submit one copy of accident reports to Project Manager within 10 days of occurrence.
- E. Protect areas occupied by workmen using the best available devices for detection of lethal and combustible gases. Test devices frequently to assure functional capability. Constantly observe infiltration of liquids into the Work area for visual or odor evidence of contamination, and immediately take appropriate steps to seal off entry of contaminated liquids to the Work area.
- F. Implement safety measures, including but not limited to safety personnel, first-aid equipment, ventilating equipment and other safety equipment specified or detailed on Drawings.
- G. Maintain required coordination with City Police and Fire Departments during entire period covered by the Contract.
- H. Include Project safety analysis in safety plan. Itemize major tasks and potential safety hazards. Plan to eliminate hazards or protect workers and public from each hazard.

3.04 FIRST AID EQUIPMENT

- A. Provide a first aid kit throughout the construction period. List telephone numbers for physicians, hospitals, and ambulance services in each first aid kit.
- B. Have at least one person thoroughly trained in first aid and CPR procedures present on the site when work is in progress. Contractor to conform to protocols and requirements for training and protection against "blood borne pathogens".

3.05 FIRE PROTECTION

- A. Conform to specified fire protection and prevention requirements established by Federal, State, or local governmental agencies and as provided in Safety Program.

3.06 SECURITY MEASURES

- A. Protect the Work, materials, equipment, and property from loss, theft, damage, or vandalism. Protect City property used in performance of the Contract.
- B. If existing fencing or barriers are breached or removed for purposes of construction, provide and maintain temporary security fencing equal to existing.

3.07 PROTECTION OF UTILITIES AND PIPELINES

- A. Prevent damage to existing public utilities during construction. Approximate locations of known utilities are shown on Drawings, but all lines may not be shown. Excavate with caution and repair lines damaged by construction operations.
- B. Use the Utility Coordinating Committee One Call System, telephone number, (713) 223-4567, which must be called 48 hours in advance. The toll free telephone number is 1-800-669-8344, Texas One Call System.
- C. Before excavating, locate underground utilities by appropriate means including the use of metal detection equipment, and probes, or by excavation or surveys. Repair damage caused by investigative work and by failure to locate or to preserve underground utilities.
- D. Give utility owners a minimum five days notice before commencing excavation to allow time to locate utilities and make adjustments or relocations when they conflict with the Work. Include cost for temporary relocation of water, wastewater, and storm drainage lines, necessary to accommodate construction, in unit prices for utility construction unless otherwise noted. Bypassing of sanitary waste to storm drainage facilities is not allowed.
- E. Prior to excavation near pipelines, request a representative of the pipeline company to meet with Contractor and Project Manager at the site to discuss procedures to be used. Request pipeline company's representative to locate the pipelines in at least three locations: at each side and at centerline of proposed excavation of proposed utility. Also request representative and Project Manager to be present to observe Contractor operations when excavation is conducted within 15 feet of pipeline.
- F. Utility service lines are not shown on the construction document drawings. Contractor should anticipate that such service lines exist and should exercise extreme caution during construction. The utility service lines should be repaired and restored immediately as per the specification, if damaged due to any construction activities. No separate payment will be made for this repair and restoration work. Include payment in unit price for work in appropriate sections.
- G. Prior to abandonment of utility, make appropriate arrangements with City and owner of utility to terminate service, remove meters, transformers, and poles as may be required by site conditions.

3.08 PROTECTION OF THE WORK AND PROPERTY

A. Preventive Actions

1. Take necessary precautions and actions to prevent damage, injury, or loss to the Work or public and private property, including:
 - a. Storage of apparatus, supplies, and Products in an orderly, safe manner to limit interference with progress of the Work or work of other contractors, utility service companies, or the City's operations.
 - b. Suitable storage for Products subject to damage by exposure to weather, theft, breakage, etc.
 - c. Limitation of loading pressures imposed upon portions of the Work.
 - d. Frequent clean up of refuse, scrap materials, and debris from construction operations, necessary to maintain the site in a safe and orderly condition.
 - e. Provision of barricades and guard rails to protect pedestrian and traffic around openings, scaffolding, temporary stairs and ramps, excavations, elevated walkways, and other hazardous areas.
2. Protect public and private property adjacent to the site. Obtain written consent before entering or occupying privately-owned land except on easements provided for construction. Restore property damaged by construction operations to condition equal to or better than that existing before the damage.

B. Barricades and Warning Systems

1. Where work is performed on or adjacent to roadways, rights-of-ways, or public land, provide barricades, fences, lights, warning signs, danger signals, and other precautionary measures necessary for protection of persons or property and for protection of the Work.
 - a. Erect sufficient barricades to keep vehicles and pedestrians from entering the Work. Paint barricades to be visible at night. From sunset to sunrise, provide at least one light at each barricade.
 - b. Maintain barricades, signs, lights, and provide watchmen until Project Manager approves removal. Whenever work creates encroachment onto public roadways, station flagmen to manage traffic flow in accordance with approved traffic control plan.
 - c. Conform to requirements of Section 01555 – Traffic Control and Regulation.

C. Protection of Existing Structures

1. Underground Facilities

- a. Known Underground Facilities are shown on the Drawings but all Facilities may not be shown. Explore sufficiently ahead of trenching and excavation work to locate Underground Facilities in order to prevent damage to them and to prevent interruption of utility services. Restore damage to Underground Facilities to original condition at no additional cost to the City.
 - b. If necessary to avoid unanticipated Underground Facilities, Project Manager may make changes in location of the Work.
 - c. If permanent relocation of an Underground Facility is required and not provided for in the Contract documents, City Engineer will direct Contractor in writing to perform the Work under Modification provisions in Document 00700 - General Conditions.
2. Surface Structures include buildings, tanks, walls, bridges, roads, dams, channels, open drainage, piping, poles, wires, posts, signs, markers, curbs, walks, guard cables, fencing, and other facilities that are visible above the ground level.
3. Protection of Underground Facilities and Surface Structures:
- a. Support in place and protect Underground Facilities and Surface Structures located within or adjacent to the limits of the Work from damage. Install supports as required by the owner of the structure. Satisfy Project Manager that the owner of the facility or structure has approved methods and procedures before installing structure supports.
 - b. Avoid moving or changing public utility or private corporation property without prior written consent of a responsible official of the facility or structure. Allow representatives of utilities to enter the construction site for maintenance and repair purposes or to make necessary changes.
 - c. Notify utility and pipeline owners and operators of the nature of construction operations and dates when operations will be performed. When construction operations are required in immediate vicinity of existing structures, pipelines, or utilities, give a minimum of five working days advance notice. Probe and flag location of Underground Facilities prior to commencement of excavation. Keep flags in place until construction operations uncover the facility.
 - d. Assume risk for damages and expenses to Underground Facilities and Surface Structures within or adjacent to the Work.
- D. Employ a structural engineer to ensure protection measures are adequate for the safety and integrity of structures and facilities.
- E. Protection of Installed Products:

1. Provide protection of Installed Products to prevent damage from subsequent operations. Remove protection facilities when no longer needed, prior to completion of the Work.
2. Control traffic to prevent damage to Products and surfaces.
3. Provide coverings to protect Products from damage. Cover projections, wall corners, jambs, sills, and exposed sides of openings in areas used for traffic and passage of materials in subsequent work.

3.09 ROADS AND PARKING

- A. Prevent interference with traffic and operations of the City on existing roads.
- B. Designate temporary parking areas to accommodate construction and City personnel. When site space is not adequate, provide additional off-site parking. Locate as approved by Project Manager.
- C. Minimize use by construction traffic on existing streets and driveways.
- D. Do not allow heavy vehicles or construction equipment in existing parking areas.

3.10 ENVIRONMENTAL CONTROLS

- A. Use methods, equipment, and temporary construction necessary for control of environmental conditions at the site and adjacent areas.
- B. Comply with statutes, regulations, and ordinances relating to prevention of environmental pollution and preservation of natural resources including National Environmental Policy Act of 1969, PL 91-190, Executive Order 11514.
- C. Minimize impact to the surrounding environment. Do not use construction procedures that cause unnecessary excavation and filling of terrain, indiscriminate destruction of vegetation, air or stream pollution, or harassment or destruction of wildlife.
- D. Limit disturbed areas to boundaries established by the Contract. Do not pollute on-site streams, sewers, wells, or other water sources.
- E. Do not burn rubbish, debris or waste materials.

3.11 POLLUTION CONTROL

- A. Provide methods, means, and facilities necessary to prevent contamination of soil, water or the atmosphere by discharge of Pollutants from construction operations.
- B. Provide equipment and personnel to perform emergency measures to contain spillage, and to remove contaminated soils or liquids. Excavate and dispose of contaminated earth off-site in accordance with laws and regulations, and replace with suitable compacted fill and topsoil.

- C. Provide systems necessary for control of Pollutants.
 - 1. Prevent toxic concentrations of chemicals.
 - 2. Prevent harmful dispersal of Pollutants into the environment.
- D. Use equipment that conforms to current Federal, State, and local laws and regulations.

3.12 PEST AND RODENT CONTROL

- A. Provide rodent and pest control as necessary to prevent infestation of construction or storage areas.
- B. Employ methods and use materials that will not adversely affect conditions at site or on adjoining properties.

3.13 NOISE CONTROL

- A. Provide vehicles, equipment, and use construction activities that minimize noise to the greatest degree practicable. Conform to noise levels of Chapter 30 –Noise and Sound Level Regulation, City Code of Ordinances, and latest OSHA standards. Do not permit noise levels to interfere with the Work or create a nuisance to surrounding areas.
- B. Conduct construction operations during daylight hours except as approved by Project Manager.
- C. Select construction equipment that operates with minimum noise and vibration. When directed by Project Manager, correct objectionable noise or vibration produced by operation of equipment at no additional cost to the City. Sound Power Level (PWL) of equipment shall not exceed 85 dbA (re: 10-12 watts) measured five feet from the equipment, or at a lower level if prescribed by City Ordinances. Equipment noise requirements are contained in equipment specifications.

3.14 DUST CONTROL

- A. Use water or other methods approved by Project Manager to control amount of dust generated by vehicle and equipment operations.

3.15 WATER RUNOFF AND EROSION CONTROL

- A. Comply with requirements of section 01410 – TPDES Requirements.
- B. Conduct fill, grading and ditching operations and provide adequate methods necessary to control surface water, runoff, subsurface water, and water from excavations and structures in order to prevent damage to the Work, the site, or adjoining properties.

1. Plan and execute construction and earthwork by methods that control surface drainage from cuts and fills, and from borrow and waste disposal areas.
2. Minimize area of bare soil exposed at one time.
3. Provide temporary control measures, such as berms, dikes, and drains.
4. Provide, operate, and maintain equipment and facilities of adequate size to control surface water.
5. Construct fill and waste areas by selective placement of materials to eliminate erosion of surface silts or clays that may erode.
6. Direct water away from excavations, pits, tunnels, and other construction areas to prevent erosion, sedimentation or damage.
7. Maintain existing drainage patterns adjacent to the site by constructing temporary earth berms, sedimentation basins, retaining areas, and temporary ground cover.
8. Dispose of drainage water in a manner to prevent flooding, erosion, or other damage to the site or adjoining areas, in conformance with environmental requirements.
9. Inspect earthwork periodically to detect any evidence of erosion. Take corrective measures as required to control erosion.

END OF SECTION

SECTION 01506

DIVERSION PUMPING

PART 1 GENERAL

1.01 DEFINITIONS

- A. Diversion-pumping: Installation and operation of bulkheads, plugs, hoses, piping, and pumps required to maintain sewer flow and prevent backups and overflows.

1.02 RELATED SECTIONS

- A. Section 01330 – Submittal Procedures

1.03 SYSTEM DESCRIPTION

- A. Provides continuous sewer service to users of sewer systems while maintenance or construction operations are in progress, by diverting flow around construction locations. Maintain sewer flow to prevent backup or overflow onto streets, yards and unpaved areas or into buildings, adjacent ditches, storm sewers, and waterways. Do not divert sewage outside of sanitary sewer system.
- B. When pumps are operating, have an experienced operator on site to monitor operation, adjust pumps, make minor repairs to system, and report problems.

1.04 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittals Procedures.
- B. For systems that bypass sanitary sewer line segments of 42-inch diameter or larger, submit a Diversion Pumping Plan prior to installation. Show location, number and size of pumps, number, location, size and type of hoses or rigid piping, and location of downstream discharge; and special features where pipes or hoses cross roadways, temporary trenches, support bridges.

1.05 SCHEDULING

- A. When the City operates or maintains diversion pumping in construction areas, coordinate construction activities with Project Manager.
- B. Cease operation of diversion pumping when approved by Project Manager.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Design piping, joints and accessories to withstand at least twice maximum system pressure or 50 psi, whichever is greater.
- B. Use self-priming type or submersible electric pumps, with a working pressure gauge on the discharge. Pumps shall meet requirements of City of Houston Noise and Sound Level Regulations.

PART 3 EXECUTION

3.01 FIELD QUALITY CONTROL

- A. During diversion pumping, do not allow sewage to leak, dump, or spill into or onto areas outside of existing sanitary sewer systems.
- B. In the event of an accidental spill or overflow, immediately stop discharge and take action to clean up and disinfect spill. Promptly notify Project Manager so required reporting can be made to the Texas Commission on Environmental Quality (TCEQ) and the Environmental Protection Agency (EPA).

3.02 CLEANING

- A. When diversion-pumping operations are complete, drain sewage within piping into sanitary sewers prior to disassembly.

END OF SECTION

SECTION 01520

TEMPORARY FIELD OFFICE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary field office building and associated parking area.

1.02 RELATED SECTIONS

- A. Section 01770 – Closeout Procedures

1.03 FACILITY DESCRIPTION

- A. Temporary field office to be utilized by authorized representatives of the City to coordinate and monitor daily construction activities performed by Contractor.
- B. Field office shall be a non-smoking facility.

PART 2 PRODUCTS

2.01 FIELD OFFICE

A. General:

1. Locate office in vicinity of the Work at a location approved by Project Manager or where indicated on Drawings.
2. Furnish, Install and maintain field office for exclusive use of authorized representatives of the City. Provide sufficient room for Project meetings and Inspector's office.
3. Provide office within 10 days of Date of Commencement of the Work.
4. Construct two all-weather, hard surfaced parking spaces for exclusive use of authorized representatives of the City. Provide all-weather surfaced walk between parking spaces and field office.

B. Minimum Construction:

1. Structurally sound foundation and superstructure.
2. Weather tight with insulated roof, walls and 7-foot ceiling (minimum).
3. Stairs or walkway with handrail and covered entrance platform (minimum 4 feet by 4 feet) with mud scraper at door.

4. Resilient floor covering.
 5. Screened windows with area equal to approximately 10 percent of floor area sufficient for light, view of the site, and ventilation. Provide each window with operable sash and burglar bars.
 6. Secure exterior doors with dead-bolt cylinder locks and burglar bars.
- C. Minimum Services:
1. Exterior entrance light.
 2. Interior lighting of 75 foot-candles minimum at desktop height
 3. Automatic heating to maintain 65 degrees F in winter.
 4. Automatic cooling to maintain 75 degrees F in summer.
 5. Electric power service.
 6. Three telephone service lines one for voice, one for data, and one for fax, for exclusive use of authorized representatives of the City.
 7. Sanitary facilities in field office with one water closet, one lavatory, and one medicine cabinet for exclusive use of authorized representatives of the City.
- D. Minimum Furnishings:
1. One 5-drawer desk
 2. Two swivel desk chairs with casters.
 3. One plan table.
 4. One drawing plan rack.
 5. One 4-drawer legal file cabinet complete with fifty legal-size hanging folders and two full-sized carriers.
 6. One marker board with cleaner and markers.
 7. Two waste baskets.
 8. One 30-inch by 36-inch tack board.
 9. One all-purpose fire extinguisher.
 10. Six protective helmets (hard hats) with ratchet adjustment for exclusive use of authorized representatives of the City.

11. Conference table and chairs to accommodate 10 persons.
 12. All in one printer, copier, plain paper fax machine.
 13. Telephone instrument separate from fax machine.
- E. Provide adequate space for one set of Contract documents for ready reference.

PART 3 EXECUTION

3.01 MAINTENANCE

- A. Maintain all-weather surface driveway and parking areas, buildings, walkways, stairs and required furnishings and equipment for duration of the Contract.
- B. Provide janitorial services for duration of the Contract consisting of twice weekly sweeping and mopping floors, trash removal, weekly restroom cleaning, and weekly dusting of furniture and equipment.
- C. Provide soap, paper towels, toilet paper, cleansers and other necessary consumables.
- D. Immediately repair damage, leaks or defective service.

3.02 PROJECT CLOSEOUT

- A. Remove temporary field office and signs and restore site as specified in Section 01770 - Closeout Procedures.

END OF SECTION

SECTION 01554

TRAFFIC CONTROL AND STREET SIGNS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Materials, hardware and installation of Traffic Signs.

1.02 RELATED SECTIONS

- A. Section 01270 – Measurement and Payment
- B. Section 01330 – Submittal Procedures

1.03 MEASUREMENT AND PAYMENT

- A. Signs installed or replaced will be measured by each sign. Signs refurbished will be measured by each sign.
- B. Payment for installation of traffic signs will be on the basis of each sign installed.
- C. The price is full compensation for furnishing and installing new signs and hardware. Cost of associated posts, footings, and miscellaneous mounting hardware will not be paid for directly but is to be included in the unit price bid for installation of each traffic sign.
- D. Non-standard signs installed or replaced will be measured by the square foot of the sign face. Non-standard signs shall not be installed without prior approval from the City.
- E. Reinstallation of previously existing signs, where required per plans, is incidental to the work.
- F. Refer to Section 01270 – Measurements and Payments for unit price procedures.

1.04 REFERENCES

- A. The following ASTM Standards and documents, of the issue in effect on the date of Invitation for Bid, form a part of this specification to the extent herein.
 - 1. ASTM A 653 - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process

2. ASTM A 1011 - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength
3. ASTM B 209 - Specification for Aluminum and Aluminum Alloy Sheet and Plate
4. ASTM B449 - Standard Specification for Chromates on Aluminum
5. ASTM B921 - Standard Specification for Non-hexavalent Chromium Conversion Coatings on Aluminum and Aluminum Alloys
6. ASTM D 523 - Standard Method for Test for Specular Gloss
7. ASTM D 4956 - Standard Specification for Retroreflective Sheeting for Traffic Control
8. ASTM E 284 - Standard Terminology of Appearance
9. ASTM E 308 – Standard Practice for Computing the Colors of Objects by Using the CIE System
10. ASTM E 810 - Standard Test Method for Coefficient of Retroreflection of Retroreflective Sheeting Utilizing the Coplanar Geometry
11. ASTM E 1164 - Standard Practice for Obtaining Spectrophotometric Data for Object-Color Evaluation
12. Standard Highway Sign Designs (SHSD) for Texas
13. Texas Manual of Uniform Traffic Control Devices (TMUTCD)

1.05 SUBMITTALS

- A. Contractor shall submit a list of intended suppliers and products to be used for all signs, posts, and associated hardware. City reserves the right to request actual product samples prior to approval.
- B. Conform to requirements of Section 01330 – Submittal Procedures.

1.06 WARRANTY

- A. The Contractor shall warrant the materials and workmanship of each sign in accordance with the maximum limits of material warranties extended by manufacturers of raw materials, subject to the conditions they specify. The retro-reflective sheeting will be considered unsatisfactory if it has deteriorated due to natural causes to the extent that: (1) the sign is ineffective for its intended purpose when viewed from a moving vehicle under normal day and night driving conditions; or (2) the coefficient of retro-reflection is less than the minimum specified for that sheeting. When sign failure occurs prior to the minimum years indicated and an inspection demonstrates that the failure is caused by materials warranted to contractor to endure at least that long, the sign will be replaced or repaired free of materials charges. When failure occurs and inspection demonstrates that such failure is due to poor workmanship, the sign will be replaced or repaired at Contractor's expense, including shipping charges.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Substrate (Sign Blanks). All blanks to be installed shall be aluminum alloy 6061-T-6 or 5052-H38 in accordance with ASTM B-209. Treat sign blanks with a chemical process resulting in a coating meeting the requirements of ASTM B449, Class 2, or ASTM B921, Class 2. The coating shall be light-colored, tight, and free from powdery residues. The size, shape and thickness of the sign blanks are as indicated on the standard detail sheet in the plans or as specified by the Engineer.
1. Metal working. The aluminum shall be free of burrs and pits on both sides, including edges and holes, and shall be made ready for applications of the sheeting.
 2. Surface Preparation. The aluminum shall be thoroughly cleaned and degreased with solvent and alkaline emulsions cleaner by immersion, spray, or vapor degreasing and dried prior to application of the coating. The aluminum shall be new and corrosion-free with holes drilled or punched, corners rounded to the radii shown in the standard detail sheet, and all edges smoothed prior to application of sheeting. The heavy or medium chromate coating shall conform in color and corrosion resistance to that imparted by the Alodine 1200F treatment.
 3. Size. The dimensions of substrate applications for regulatory, warning, and guide signs shall be as specified by the Engineer and as shown on the plans.
- B. Sign Face (Background, Legends, Symbols, and Colors). These shall be in accordance with the Standard Highway Sign Designs (SHSD) for Texas and with the Texas Manual of Uniform Traffic Control Devices (TMUTCD).

1. The sign face, made of electronic film and retro-reflective sheeting shall comply with the appearance, specification, and good workmanship designated by the using agency for sign faces constructed of screen processed retro-reflective sheeting of the same type.
 2. All sign blanks shall be covered with appropriate retro-reflective sheeting.
 - a. All ground mounted stop signs, warning signs, and other regulatory signs, shall use at a minimum High Intensity Prismatic Reflective Sheeting.
 - b. All overhead signs shall use Diamond Grade Reflective Sheeting.
 - c. All other signs shall use Super Engineer Grade Sheeting
 3. Application Methods. The method of application of sheeting, letters, numbers, and symbols shall be precisely as prescribed in writing by the manufacturer.
 - a. Legend Spacing and Layout. Spacing and layout for all traffic control signs shall conform to the SHSD.
 - b. Tolerance for Horizontal Alignment. Letters, numerals, and symbols shall be horizontally aligned to a tolerance of 1/16 inch.
 - c. Tolerance for Vertical Alignment. Letters, numerals, and symbols shall be vertically aligned to a tolerance of 1/16 on each letter in each line.
- C. Sign Posts. Steel post shall conform to the standard specification for hot rolled carbon sheet steel, structural quality, ASTM designation A1011, Grade 50. Average minimum yield strength after cold forming is 60,000 psi. The cross section of the post shall be square tube formed steel, carefully rolled to size and shall be welded directly in the corner by high frequency resistance welding or equivalent process and externally scarified to agree with corner radii. Sign posts shall be hot dipped galvanized conforming to ASTM A653, G90.
1. Posts mounted over building basements, bridges, and cavities shall be round and 2 inches in diameter.
 2. Posts hard surface mounted or ground mounted shall be square and 1-3/4 inches x 1-3/4 inches in dimension.
 - a. The square end of the post shall not be modified or pointed.
 3. Installation.
 - a. Post Installation Methods:
 - (1) Mounting over Building Basements, Bridges and Cavities:

- (a) A galvanized cast iron pipe flange shall be used. The base shall be 8 inches in diameter with six 5/16 inch holes drilled equidistant around the circumference, 3/4 inch from the outer edge. The neck of the flange shall be 3 inches in diameter, drilled and threaded to receive a 2 inch diameter post.
 - (2) Hard Surface Mounting:
 - (a) Where the pole installation requires surface mounting, a 6.75 inch flange shall be used. Refer to City of Houston Standard Detail 01554-02 for additional requirements.
 - (3) Ground Mounting:
 - (a) Anchors shall be anchored in a minimum of one cubic foot of class "C" concrete, 34 inches deep, with a 6 inch long, 3/8 inch diameter pin inserted through the pre-drilled hole 3 inches from the bottom of the pole. Refer to City of Houston Standard Detail 01554-01 for additional requirements.
 - b. Sign Hardware.
 - (1) All ground mounted signs shall be attached to posts using 5/16" nut and bolt assembly according to City of Houston Standard Detail 01554-01.
 - (2) All signs installed on light standards or mast arms shall use stainless steel banding material, brackets and clips.
 - c. Sign placement and orientation shall be as specified in the construction plans.
- D. Each finished sign shall have the following sticker affixed to the back in a location where it will be visible when the sign is installed:



1. The sticker shall be Zebra Technologies Z-Ultimate 3000 White or approved equal. Finished product shall be weather and fade resistant for the expected life of the sign.
2. All new signs shall have the City bar code stickers

PART 3 EXECUTION

3.01 EQUIPMENT

- A. The contractor shall provide machinery, tools, and equipment necessary for proper execution of the work.

3.02 CONSTRUCTION

- A. Construction shall be high quality with no visible defects in the finished product. Fabrication shall be in accordance with these specifications. Street name signs shall always be supplied and installed at each project intersection whether signs previously existed at the location or not.
- B. The removal of existing signs shall be coordinated with the Traffic Operations Section of the Public Works Department (832-395-6771) and arrangements made for a convenient time to deliver City signs and poles. All salvaged traffic signs shall be delivered to the Traffic Operations Center located at 2200 Patterson Street. All deliveries to the Traffic Operations Center requires a minimum notice of two (2) working days prior to returning or delivering any sign and/or sign related material.

3.03 RESPONSIBILITIES

- A. The contractor is responsible for providing and supplying aluminum traffic signs covered with retro-reflective sheeting, applying standard legends (or special legends if shown in the plans) to the covered sign blanks, galvanized steel sign poles, pole anchors, all hardware for installing the signs and poles, and for installing traffic signs, poles and anchors as shown in the plans or call for in the contract documents, complete and ready for field installations.

END OF SECTION

SECTION 01555

TRAFFIC CONTROL AND REGULATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Requirements for signs, signals, control devices, traffic barriers, flares, lights and traffic signals; construction parking control, designated haul routes, and bridging of trenches and excavations.
- B. Qualifications and requirements for use of flagmen.

1.02 RELATED SECTIONS

- A. Section 01110 - Summary of Work
- B. Section 01270 – Measurement and Payment
- C. Section 01330 – Submittal Procedures

1.03 MEASUREMENT AND PAYMENT

- A. Unit Price Contracts.
 - 1. Traffic control and regulation. Payment for traffic control and regulation is on a lump sum basis. Include preparation and submittal of traffic control plan if different than shown on Drawings, and provision of traffic control devices, equipment, and personnel necessary to protect the Work and public. Payment will be based on Contractor's Schedule of Values for traffic control and regulation.
 - 2. Payment for traffic control for wastewater or water line projects will be authorized by Project Manager in three (3) parts. Partial payment will be made according to following schedule:
 - a. Payment of 25 percent of traffic control amount will be authorized when permanent control devices and necessary temporary markings, sufficiently deployed along job site as required to maintain progress of work, are installed at job site and approved. This limiting percentage will be prorated based upon extent of Contractor's setup.
 - b. A payment of 50 percent of traffic control amount will be authorized when pavement replacement commences. This limiting percentage will be prorated based upon linear footage, as measured along centerline axis of wastewater or water line, of pavement replaced.

- c. A payment of 25 percent of traffic control amount will be authorized when permanent pavement markings are restored and all unnecessary permanent and temporary control devices removed. This limiting percentage will be prorated based upon the extent of restoration.
 3. Flagmen: Measurement is on a lump sum basis for flagmen as required for the project. The amount invoiced shall be determined based on the schedule of value submitted for flagmen.
 4. New Portable Concrete Low Profile Traffic Barrier or Water Filled Barrier Provided. Payment is on a unit price basis for each linear foot of low profile traffic barrier or water filled barrier provided, installed with hardware assemblies and connected together in accordance with the approved traffic control plan.
 5. Portable Concrete Low Profile Traffic Barrier or Water Filled Barrier picked up from City of Houston Stockpile. Payment is on a unit price basis for each linear foot of low profile traffic barrier or water filled barrier picked up from designated stockpile, moved onto the project, set at location and connected together.
 6. Portable Concrete Low Profile Traffic Barrier or Water Filled Barrier Installed. Payment is on a unit price basis for each linear foot of low profile traffic barrier or water filled barrier delivered to the project location, installed with hardware assemblies and connected together in accordance with the approved traffic control plan.
 7. Portable Concrete Low Profile Traffic Barrier or Water Filled Barrier Moved and Reset. Payment is on a unit price basis for each linear foot of low profile traffic barrier or water filled barrier disassembled, moved on the project, reset at the new locations and connected together. Include cost to repair roadway in the unit price.
 8. Portable Concrete Low Profile Traffic Barrier or Water Filled Barrier Removed. Payment is on a unit price basis for each linear foot of low profile traffic barrier or water filled barrier removed from the project, including hardware assemblies, and stockpiling at location listed in Section 01110 - Summary of Work. Include cost to repair roadway in the unit price.
 9. Refer to Section 01270 - Measurement and Payment for unit price procedures.
 - B. Stipulated Price Contracts. Include payment for work under this section in the total Stipulated Price.
- 1.04 REFERENCES
- A. Texas Manual on Uniform Traffic Control Devices (TMUTCD)

- B. Article 4413 (29bb), commonly referred to as Private Investigators and Private Security Agencies Act, and Article 2.12, Texas Code of Criminal Procedure.
- C. Code of Ordinances, City of Houston, Texas.
 - 1. Chapter 10 Buildings And Neighborhood Protection, Article X Cleanup After Demolition Or Removal Of Structures
 - 2. Chapter 40 Streets and Sidewalks, Article XVII Sidewalk and Roadway Obstructions and Impairments
- D. Institute of Transportation Engineers (ITE) Purchase Specification for Flashing and Steady Burn Warning Lights, current edition

1.05 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. Traffic control plan:
 - 1. If using traffic control plan contained in the Contract without modification, submit a letter confirming use of the plan.
 - 2. If using a different traffic control plan, submit the plan for approval. The plan must conform to TMUTCD requirements and be sealed by a Registered Texas Professional Engineer.
- C. Submit copies of approved lane closure permits issued by City Traffic Engineering Branch.
- D. Submit Schedules of Values for traffic control plan and flagmen within 30 days following Notice to Proceed.
- E. Submit records verifying qualifications of Uniformed Peace Officers and Certified Flagmen proposed for use on the Work.
- F. When working in the central business district, submit copies of approved Pedestrian Way permits issued by the City's Traffic Engineering Branch.

1.06 FLAGMEN

- A. Use Uniformed Peace Officers and Certified Flagmen to control movement of vehicular and pedestrian traffic when construction operations encroach on public traffic lanes. Unless otherwise approved by Project Manager, use Uniformed Peace Officer for work along major thoroughfares, schools, churches, hospitals and Work at signalized intersections.

- B. Uniformed Peace Officer: Individual employed full-time as a peace officer who receives separate compensation as a privately employed flagman. Private employment may be an employee-employer relationship or on an individual basis. Flagman may not be in the employ of another peace officer nor be a reserve peace officer.
1. Uniformed Peace Officers may be:
 - a. sheriffs and their deputies;
 - b. constables and deputy constables;
 - c. marshals or police officers of an incorporated city, town or village; or
 - d. as otherwise provided by Article 2.12, Code of Criminal Procedure.
 2. The Uniformed Peace Officer must be a full-time peace officer, must work a minimum average of 32 paid hours per week, and must be paid a rate not less than the prevailing minimum hourly wage rate set by the federal Wage and Hour Act. The individual must be entitled to vacation, holidays, and insurance and retirement benefits.
- C. Certified Flagman: Individual who receives compensation as a flagman and meets the following qualifications:
1. Formally trained and certified in traffic control procedures by the City's E. B. Cape Center or flagman trainings listed on TXDOT traffic control training list.
 2. Speaks English. Ability to speak Spanish is desirable but not required.
 3. Paid for flagman duty at an hourly rate not less than the wage rate set for Rough Carpenter under the City's Wage Scale for Engineering Construction.
- D. Certified Flagmen must wear a distinctive uniform, bright-colored vest, and be equipped with appropriate flagging and communication devices while at the Work site. They must also have in their possession while on duty, a proof of training identification card issued by the appropriate training institute.

PART 2 PRODUCTS

2.01 SIGNS, SIGNALS, AND DEVICES

- A. Comply with TMUTCD requirements.
- B. Traffic cones and drums, flares and lights: Conform to local jurisdictions' requirements.

1. Warning lights shall meet the requirements of TMUTCD section 6F.83 and the current ITE "Purchase Specification for Flashing and Steady Burn Warning Lights".
 2. Warning lights shall be capable of being visible on a clear night from a distance of 3,000 feet.
- C. When working in the Central business district, provide pedestrian pathway signage approved by the City's Traffic Engineering Branch.

2.02 PORTABLE LOW PROFILE CONCRETE BARRIERS

- A. The low profile concrete barrier is a patented design. Information concerning this barrier may be obtained from Texas Transportation Institute, Texas A&M University System, College Station, Texas 77843-3135, (409) 845-1712.

2.03 WATER FILLED BARRIERS

- A. Provide barrier units that are capable of being lifted and moved when filled if draining is not possible.
- B. Provide water filled barrier that acts as its own free standing, non-redirective end treatment.
- C. When water filled barriers are used to channelize pedestrians, they must have a continuous detectable bottom for users of long canes and the top of the unit shall not be less than 32 inches in height.

PART 3 EXECUTION

3.01 PUBLIC ROADS

- A. Submit requests forms for lane closure and sidewalk closure to Office of City Engineer, Mobility Unit ten working days prior to need for blocking vehicular lanes or sidewalks. Do not block lanes or sidewalks without approved permits. Obtain application from the Office of City Engineer, Mobility Unit at 1002 Washington Ave, 2nd floor, Houston, TX 77002 or at the following internet address:
<https://www.houstonpermittingcenter.org/hpwmp1001#apply>
- B. Follow laws and regulations of governing jurisdictions when using public roads. Pay for and obtain permits from jurisdiction before impeding traffic or closing lanes. Coordinate activities with Project Manager.
- C. Give Project Manager one-week notice before implementing approved traffic control phases. Inform local businesses of impending traffic control activities.
- D. Notified police department, fire department, METRO, and local schools, churches, and businesses in writing a minimum of five business days prior to beginning work.

- E. Maintain 10-foot wide all-weather lanes adjacent to the Work for emergency vehicle use. Keep all-weather lanes free of construction equipment and debris.
- F. Do not obstruct normal flow of traffic from 7:00 a.m. to 9:00 a.m. and 4:00 p.m. to 6:00 p.m. on designated major arterials or as directed by Project Manager.
- G. Maintain local driveway access to residential and commercial properties adjacent to work areas at all times. Use all-weather materials approved by Project Manager to maintain temporary driveway access to commercial and residential driveways.
- H. Keep streets entering and leaving job site free of excavated material, debris, and foreign material resulting from construction operations in compliance with applicable ordinances.
- I. Remove existing signage and striping that conflict with construction activities or that may cause driver confusion.
- J. Provide safe access for pedestrians along major cross streets.
- K. Alternate closures of cross streets so that two adjacent cross streets are not closed simultaneously.
- L. Do not close more than two consecutive esplanade openings at a time without prior approval from Project Manager.

3.02 CONSTRUCTION PARKING CONTROL

- A. Control vehicular parking to prevent interference with public traffic and parking, access by emergency vehicles, and the City's operations.
- B. Monitor parking of construction personnel's vehicles in existing facilities. Maintain vehicular access to and through parking areas.
- C. Prevent parking on or adjacent to access roads or in non-designated areas.

3.03 FLARES AND LIGHTS

- A. Provide flares and lights during hours of low visibility to delineate traffic lanes and to guide traffic.
- B. When warning lights are used, they shall be mounted on signs or channelizing devices in a manner that if hit by an errant vehicle, they will not be likely to penetrate the windshield.

3.04 WATER FILLED BARRIERS

- A. Water filled barriers can be used as instructed by the Engineer and approved by City for projects where space is limited and heavy equipment to place concrete barriers is not feasible. Water filled barriers shall not be used on roadways with a posted speed limit more than 45 mph.
- B. Water filled barriers must be installed and maintained per the manufacturer's requirements and routinely inspected for defects.
- C. If water filled barrier is provided, use environmentally safe anti-freezing agent in the water when it is applicable per manufacturer specifications and recover agent when the barrier is drained.
- D. Dispose of water and agent properly. Do not drain water filled barrier into or across an existing travel lane.

3.05 HAUL ROUTES

- A. Utilize haul routes designated by authorities or shown on drawings for construction traffic.
- B. Confine construction traffic to designated haul routes.
- C. Provide traffic control at critical areas of haul routes to regulate traffic and minimize interference with public traffic.

3.06 TRAFFIC SIGNS AND SIGNALS

- A. Construct necessary traffic control devices for temporary signals required to complete the Work including loop detectors, traffic signal conduits, traffic signal wiring and crosswalk signals. Notify the City's Traffic Engineering Branch a minimum of 60 days in advance of need for control boxes and switchgear. The City will perform necessary service, programming or adjustments, to signal boxes and switchgear if required during construction.
- B. Install and operate traffic control signals to direct and maintain orderly traffic flow in areas under Contractor's control affected by Contractor's operations. Post notices, signs and traffic controls before moving into next phase of traffic control.
- C. Relocate traffic signs and signals as the Work progresses to maintain effective traffic control.
- D. Unless otherwise approved by Project Manager, provide driveway signs with name of business that can be accessed from each crossover. Use two signs for each crossover.
- E. Replace existing traffic control devices in Project area.
- F. Project Manager may direct Contractor to make minor adjustments to traffic control signage to eliminate driver confusion and maintain orderly traffic flow during construction at no additional cost to the City.

3.07 BRIDGING TRENCHES AND EXCAVATIONS

- A. When necessary, construct bridges over trenches and excavation to permit an unobstructed flow of traffic across construction areas and major drives. Use steel plates of sufficient thickness to support H-20 loading and install to operate with minimum noise.
- B. Shore trench or excavation to support bridge and traffic.
- C. Secure bridging against displacement with adjustable cleats, angles, bolts or other devices when:
 - 1. bridging is placed over existing bus routes,
 - 2. more than five percent of daily traffic is comprised of commercial or truck traffic,
 - 3. more than two separate plates are used for bridging, and
 - 4. when bridge is to be used for more than five consecutive days.
- D. Extend steel plates used for bridging a minimum of 1 foot beyond edges of trench or excavation. Use temporary paving materials such as premix to feather edges of plates to minimize wheel impact on secured bridging.

3.08 REMOVAL

- A. Remove equipment and devices when no longer required. All short-term duration closures within central business district (CBD) must have all their equipment picked up on a daily basis, this includes any and all construction equipment utilized, along with all traffic control, unless approved by the city mobility permits group.
- B. Repair damage caused by installation.
- C. Remove post settings to a depth of 2 feet.

3.09 TRAFFIC CONTROL, REGULATION AND DIRECTION

- A. Use Flagmen to control, regulate and direct an even flow and movement of vehicular and pedestrian traffic, for periods of time as may be required to provide for public safety and convenience, where:
 - 1. multi-lane vehicular traffic must be diverted into single lane vehicular traffic,
 - 2. vehicular traffic must change lanes abruptly,
 - 3. construction equipment must enter or cross vehicular traffic lanes and walks,
 - 4. construction equipment may intermittently encroach on vehicular traffic lanes and unprotected walks and crosswalk,

5. traffic regulation is needed due to rerouting of vehicular traffic around the Work site, and
 6. where construction activities might affect public safety and convenience.
- B. Use of Flagmen to assist in the regulation of traffic flow and movement does not relieve Contractor of responsibility to take other means necessary to protect the Work and public.
- 3.10 INSTALLATION STANDARDS
- A. Place temporary pavement for single lane closures, in accordance with TMUTCD.
 - B. Reinstall temporary and permanent pavement markings as approved by Project Manager. When weather conditions do not allow application according to manufacturer's requirements, alternate markings may be considered. Submit proposed alternate to Project Manager for approval prior to installation. No additional payment will be made for use of alternate markings.
- 3.11 MAINTENANCE OF EQUIPMENT AND MATERIAL
- A. Submit name, address and telephone number of individual designated to be responsible for maintenance of traffic handling at construction site to Project Manager. Individual must be accessible at all times to immediately correct deficiencies in equipment and materials used to handle traffic including missing, damaged, or obscured signs, drums, barricades, or pavement markings.
 - B. Inspect signs, barricades, drums, lamps and temporary pavement markings daily to verify that they are visible, in good working order, and conform with traffic handling plans as approved by Project Manager. Immediately repair, clean, relocate, realign, or replace equipment or materials that are not in compliance.
 - C. Keep equipment and materials, signs and pavement markings, clean and free of dust, dirt, grime, oil, mud, or debris.
 - D. Obtain approval of Project Manager to reuse damaged or vandalized signs, drums, and barricades.

END OF SECTION

SECTION 01562

TREE AND PLANT PROTECTION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Tree and plant protection.
- B. Minimum qualifications of Arborist and Urban Forester.

1.02 RELATED SECTIONS

- A. Section 01270 – Measurement and Payment
- B. Section 01330 – Submittal Procedures
- C. Section 02915 – Tree Planting

1.03 MEASUREMENT AND PAYMENT

- A. Payment for Tree Protection, including tree pruning or tree removal, shall be paid as a Lump Sum basis that shall include all items specified in this section unless payment is specified otherwise in this section
- B. Payment for Zero Curb Cutback will be on a per linear foot basis.
- C. Payment for Checker Plate will be on a square foot basis.
- D. Refer to Section 01270 - Measurement and Payment for unit price procedures.

1.04 REFERENCES

- A. American National Standard for tree pruning, ANSI A300 (Part 1) – 2001 Pruning Revision of ANSI A300-1995 Tree, Shrub and Other Woody Plant Maintenance – Standard Practices

1.05 SUBMITTALS

- A. Conform to requirements of Section 01330 – Submittal Procedures.
- B. Submit name and experience of qualified Arborist, proposed for use on the Work, to Project Manager.

1.06 PROJECT CONDITIONS

- A. Preserve and protect existing trees and plants to remain from foliage, branch, trunk, or root damage that could result from construction operations.

- B. Prevent following types of damage:
1. Compaction of root zone by foot or vehicular traffic, or material storage.
 2. Trunk damage from equipment operations, material storage, or from nailing or bolting.
 3. Trunk and branch damage caused by ropes or guy wires.
 4. Root or soil contamination from spilled solvents, gasoline, paint, lime slurry, and other noxious materials.
 5. Branch damage due to improper pruning or trimming.
 6. Damage from lack of water due to:
 - a. Cutting or altering natural water migration patterns near root zones.
 - b. Failure to provide adequate watering
 7. Damage from alteration of soil pH factor caused by depositing lime, concrete, plaster, or other base materials near roots zones.
 8. Cutting of roots larger than one inch in diameter.

1.07 DAMAGE ASSESSMENT

- A. When trees other than those designated for removal are destroyed or damaged as result of construction operations, remove and replace with same size, species, and variety up to and including 8 inches in trunk diameter. Trees larger than 8 inches in diameter shall be replaced with an 8 inch diameter tree of the same species and variety and total contract amount will be reduced by an amount determined from the following formula and paid to Tree Fund $0.7854 \times D^2 \times \13.25 where D is diameter in inches of tree or shrub trunk measured 12 inches above grade for that portion of the tree which is greater than 8 inches in diameter. A permit must be applied for and approved by the City of Houston, Urban Forestry Division prior to removal of any tree not scheduled for removal in the tree treatment schedule. Contractor shall contact City of Houston, Urban Forestry, by email to ForestryPlanReview@houstontx.gov or by phone call to 832-395-8450 to request a tree removal permit.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Pruning Paint: Black latex, water based paint, free of all petroleum products.

- B. Fertilizer: Fertilizer shall be a root stimulant that contains at a minimum the following ingredients: Ectomycorrhizal Fungi, VA Mycorrhizal (VAM) Fungi, Rhizosphere Bacillus spp., Kelp Meal Humic Acid, and Soluble Yucca.
- C. Tree Protection Fencing: Orange, plastic mesh fencing, 4 feet in height with 6 feet high “t” bar posts installed 10 feet on centers as per drawings.
- D. Plastic Root/Soil Protection: Clear polyethylene sheeting, minimum 6 mil, thickness.

PART 3 EXECUTION

3.01 PROTECTION OF EXISTING TREES AND SHRUBS

- A. Site preparation work and/or construction work shall not begin in any area where tree preservation measures have not been completed and approved.
- B. Protect exposed roots and root zone areas from contamination from stabilization materials and concrete using polyethylene.
- C. Cover exposed roots within 4 hours to reduce damage caused by desiccation. Roots may be covered with soil, mulch, polyethylene, or wet burlap to help protect them from drying.
- D. Designate limited areas as concrete washout areas. Locate concrete washout areas away from root zones.
- E. Install root pruning trenching where designated in tree treatment schedule and shown on the tree protection drawings. Trees scheduled for root pruning are called out specifically in the treatment schedule. Trench shall be located 2 ft. from the edge of proposed waterline or sanitary sewer for trees called out for root pruning for water or fittings, or sanitary sewer in the treatment schedule, 2 ft. from edge of proposed storm sewer pipe for trees called out for root pruning for storm in the treatment schedule, 30” back of proposed curb for trees called out for root pruning for street, and at edge of sidewalk for trees called out for root pruning for sidewalk. Root pruning shall not be performed where there is not adequate space to be located sufficiently away from tree to prevent damage. All pruning must be evaluated by Contractor’s Certified Arborist and reviewed and approved by City Forester before being performed. Trench locations shown on tree preservation plan are drawn to scale and should be located in field as drawn on plan. Exact locations shall be approved in the field by engineer and/or project urban forester prior to installation. Trenching depth shall be a minimum of 2 ft. deep and a maximum of 6 inches wide for water, fittings, sanitary sewer, storm, and street. Trenching depth shall be to the anticipated bottom of sidewalk and base material for sidewalk root pruning, roots lower than sidewalk shall not be pruned. All roots shall be cut by trencher, chainsaw, or handsaw to the specified depth. Roots shall be cut cleanly, and or not ripped, torn, or chopped. Trench shall be backfilled and compacted immediately after trenching. Trench shall be installed prior to any clearing and grubbing, excavation for underground, or any other site work.

- F. Install tree protection fencing around each tree to be preserved as indicated in the tree treatment schedule and on the tree protection plan.
1. Each tree to be preserved shall be protected with a tree protection fence. The fencing shall be continuous between posts, shall be pulled taut prior to securing to posts, and shall be firmly attached to the posts with a minimum of 4 wire ties.
 2. All tree protection fencing shall be installed prior to site work or construction activity. The fence shall be placed in a continuous alignment as shown on the tree protection plan. Fences shown on tree protection plan are drawn to scale and shall be installed as drawn, in the field. In general fences shall be placed 30" back of existing curb or edge of pavement where root pruning or zero curb cutback is not specified, and 6" back of root pruning trench where root pruning is specified and immediately back of curb where zero curb cutback is specified. Exact locations shall be approved by the project urban forester and/or engineer in the field. The Fences shall be placed to protect roots, trunks, and foliage. The contractor shall not remove or relocate tree protection fencing and shall not operate within the limits shown without direct approval of the project urban forester. In areas where the proposed waterline is located in the existing road side ditch and where tree protection fencing cannot be installed across the ditch, the fencing shall be installed at the top of outside ditch bank and no bore pits, peep holes, service taps, or any excavation should occur in the area immediately in front of the tree protection fencing for trees called out with "bore" in the Tree Treatment Schedule. The "bore" limits shall be the same as the limits of the tree protection fencing.
 3. Storage of equipment or materials will not be allowed inside a fence. Entryways and access into a protected area shall not be provided unless approved by the project urban forester.
 4. Damage to tree fences occurring during the progress of the work shall be repaired immediately at no additional cost to owner. Workmen shall be clearly instructed to exercise caution in performance of work near trees being preserved.
 5. Tree protection fencing shall be removed by contractor, at no additional costs, upon completion of all construction activity in each work zone area. Tree protection fencing materials used in the first two work zone areas shall be removed and utilized in subsequent work zone areas. Materials and labor shall be paid for each linear foot of fencing installed in first two work areas. All fencing installed in subsequent work zone areas shall be paid for labor only.
- G. Boring/Auguring of water lines or sanitary sewer lines

1. Water line or sanitary sewer line shall be bored/augured/ horizontally drilled under critical root zones areas of trees designated with auger or bore in the tree treatment schedule. The entire area protected with tree protection fencing shall be bored. No bore pits, come through holes, peep holes, push pits, or long or short side service taps shall be allowed in the areas protected by tree protection fencing. The tree protection plan takes into consideration the limits of augering equipment, there should be room for adequately spaced bore pits, peep holes, come through holes, and push pits. Any changes to the location of the tree protection fencing shall be authorized by the project Urban Forester and City Engineer.
- H. Hand digging of Service taps and leads
1. Trees called out for Hand dig short side service tap are located in very close proximity to existing short side water meters. Excavating the service tap with machinery would significantly impact the tree and be in violation of the City of Houston's Street Tree Ordinance. These short side service taps shall be excavated with manual labor to expose any roots 1" in diameter and larger. The first 24" of excavation shall be completed manually to expose the roots. Any root 1" in diameter and larger shall remain undamaged, the roots shall not be cut , nor shall the bark and cambium layer be scraped or damaged. Once the roots are exposed, if there is adequate room to utilize a mini-excavator without damaging the roots, the mini- excavator can be utilized to complete the excavation down to the water line. 1" plywood shall be placed on grade to provide root protection in the area of access of the mini-excavator. If roots 1" diameter or larger are cut or damaged, responsible party will be subject to a citation under the Street Tree Ordinance, and may also be required to incur the cost of tree removal and replacement of damaged tree on an inch for inch basis, if required by City of Houston Urban Forestry Division.
 2. Trees called out for Hand dig short side or long side service lead are located in very close proximity to existing water meters. Excavating the service lead with machinery would significantly impact the tree and be in violation of the City of Houston's Street Tree Ordinance. Short side leads shall be excavated with manual labor to expose any roots 1" in diameter and larger from the service tap of the meter. Come out hole and excavation required for long service leads shall be excavated with manual labor to expose roots 1" in diameter and larger, from the come out hole to the meter. In each case, all roots 1" in diameter and larger shall remain undamaged, the roots shall not be cut, nor shall the bark and cambium layer be scraped or damaged. If roots 1" diameter or larger are cut or damaged, responsible party will be subject to a citation under the cost of tree removal and replacement of damaged tree on an inch by inch basis, if required by City of Houston Urban Forestry Division.

3. Trees called out for Hand dig sanitary stub up are located in very close proximity to proposed service lead. Excavating the service lead with machinery would significantly impact the tree and be in violation of the City of Houston's Street Tree Ordinance. Excavation for sanitary stub up shall be completed with manual labor to expose any roots 1" in diameter and larger. The lead shall be bored from face of curb to stub up hole when called out in the tree treatment schedule. Come out and stub up holes shall be excavated with manual labor to expose roots 1" in diameter and larger. In case, all roots 1" in diameter and larger shall remain undamaged, the roots shall not be cut, nor shall the bark and cambium layer be scraped or damaged. If roots 1" diameter or larger are cut or damaged, responsible party will be subject to a citation under the Street Tree Ordinance, and may be required to incur the cost of tree removal and replacement of damaged tree on an inch by inch basis, if required by City of Houston Urban Forestry Division.
 4. Long side service taps shall not be located in an area specified to be bored in the tree treatment schedule. Should it be absolutely necessary to locate a long side service tap in an area specified to be bored, the excavation shall be completed as specified in paragraph 1 of this section-Hand digging short side service taps.
 5. All water meters and sanitary service leads called out on P&P drawings and visible in the field have been addressed in the Tree Protection Plan. Should any additional meters or lead be found during construction, or in any new meters or leads installed beneath the canopy of any tree, fenced for tree protection, the excavation shall be completed as specified in paragraph 1 and/or 2 of this section and paid for at the unit cost for each included in contract.
- I. Pruning of Trees
1. Trees shall be pruned in accordance with the American National Standard for tree pruning, ANSI A300 (Part 1) – 2001 Pruning Revision of ANSI A300-1995 Tree, Shrub and Other Woody Plant Maintenance – Standard Practices. Pruning shall be completed by professional arborists who has received training in proper pruning techniques.

2. Clearance prune designated trees for public streets, sidewalks, and construction areas. Provide minimum 14 feet and maximum of 18 feet of vertical clearance over proposed water trunk lines. Provide minimum of 14 feet and maximum of 16 feet of vertical clearance over proposed street construction, from 24” back of curb on one side to 24” back of curb on the other side. Provide 20’ of vertical clearance over proposed storm sewer up to 38” in size, and 30’ of vertical clearance for storm sewer larger than 38” in size. Pruning to be installed prior to any construction activity. Contractor shall notify property owner prior to trimming or pruning any trees with trunks located on private property. Exceptions will be made for trees determined to be arboriculturally significant by City of Houston Urban Forestry. Pruning of trees identified will be completed with approval and supervision of City of Houston Urban Forestry.
 3. All cuts should be made sufficiently close to the parent limb or trunk without cutting into the branch collar or leaving a protruding stub, so that closure can readily start under normal conditions. All lateral cuts shall be made to a lateral that is least 1/3 the diameter of the parent limb. Clean cuts shall be made at all times.
 4. Trees shall be pruned in a manner that will not destroy or alter the natural shape and character of the tree. Apply black latex paint to all fresh wounds on Oak (*Quercus*) species immediately after each cut is made.
 5. Crown cleaning prune designated trees shall include selective removal of dead, diseased, and/or broken limbs.
- J. Tree Removal
1. Trees scheduled for removal shall be sawed down and debris hauled from the site the same day. The stump shall be ground to 6” below grade and excess grindings shall be hauled from the site the same day, so that a pile of grindings is not left where the stump was ground. Enough grindings should be left so that an open hole does not remain.
 2. Only those trees called out for removal in the Tree Treatment Schedule shall be removed, or otherwise damaged. Should it be determined that any additional trees must be removed, a permit must be applied for and approved from the City of Houston Urban Forestry Division prior to removal. Contractor shall contact City of Houston Urban Forestry by e-mail to ForestryPlanReview@houston.tx.gov or by phone call to 832-395-8450 to request a tree removal permit.
- K. Root Stimulation
1. Deep root stimulate designated trees. Mix fertilizer with wetting agent per label instructions.

2. Stimulate entire root zone area within the dripline of the tree and continue 10 feet beyond the dripline, leaving out areas of anticipated root loss (construction areas).
 3. Mixture shall be injected into the top 10 inches of soil under pressure of 150 to 200 psi as soil conditions warrant.
 4. Mix in a tank with agitation capability per label instructions. Inject the mixture on a 2.5 ft. square grid at 4 lbs, actual nitrogen per 1,000 sq. ft.
- L. Regularly water trees which have received root damage, to eliminate additional stress caused by lack of moisture. Water during periods without adequate rainfall. For example, should 1.0” of rain not be received within a week period, the trees should be thoroughly watered. March through September, water once every two weeks. October through February, water every three weeks. Water thoroughly to saturate the entire root zone area.
- M. Chemically treat tree trunks with evidence of borer activity with the appropriate approved insecticide mixed and applied per the manufacturer’s product application recommendations. Trees shall be sprayed within 24 hours after observance of borer activity.
- N. Grading and filling around trees.
1. Maintain existing grade within the dripline of trees, unless otherwise indicated.
 2. Where existing grade around trees is above new finish grade, under supervision of project urban forester, carefully hand excavate within the dripline to make transition to new finish grade.
 3. Where existing grade is below new finish grade, place clean bank sand in a single layer to make the transition to new grade. Do not compact; hand grade to required elevation. Specifically to areas where proposed curb is higher than existing and backfill will be required.
- O. Demolition, Forming and Pouring Sidewalks (Sidewalk on Grade)
1. Demolition of existing sidewalks, located in or adjacent to the limits of tree protection fencing, shall be completed without disturbing, cutting, or otherwise damaging tree roots and soil located beneath them.
 2. The new sidewalk shall be formed at or above the elevation of the existing sidewalk, without disturbing, cutting or otherwise damaging tree roots. Every effort has been made to address tree root and sidewalk elevation issues with information available in the field and on plan and profile sheets. The elevation of every tree root was not available, if tree roots are found to be in conflict with proposed sidewalk, project engineer and urban forester shall be consulted as to how to install sidewalks with minimal impacts to adjacent trees.

3. Checkerplate shall be installed in areas called out only if tree root elevations prohibit construction of ADA compliant sloped concrete sidewalks. Checkerplate shall be installed per detail.

P. Zero curb cutback

1. Disturbance of tree roots or soil behind the existing and/or proposed curb within root zones of trees designated for zero curb cutback shall be prohibited. If the curb cannot be removed without disturbing soil or damaging roots back of curb when using equipment for demolition, the curb shall be broken using a hand held jackhammer and removed by hand.
2. The exposed roots and soil shall be covered immediately after demolition with 6 mil polyethylene in order to avoid desiccation, and contamination by the lime used for road bed stabilization. The polyethylene shall be placed so that it covers the vertical face of soil back of curb and laid back onto the grade 12 inches back of curb. The polyethylene should remain in place, across the entire area specified for zero curb cutback, from the time the existing curb is demolished until the time when the new curb is formed and backfilled. The polyethylene can be pulled up from the vertical face while the road bed is being graded or mixed, to avoid catching the plastic with machinery, but shall be replaced immediately after equipment has completed. The vertical face shall not be exposed for more than 8 hours in any 24 hour period.
3. There shall be no stabilization back of curb in the zero curb cutback areas, or forming with steel forms. The existing grade and roots back of existing curb shall not be disturbed. This may require forming of the new street with wooden forms with stakes inside forms, which may require leaving the forms in place after the street is poured. Should wooden forms be utilized, the wood shall be at minimum a 2x6. The new curb may require hand finishing, as a slip curb machine may not have adequate clearance without disturbing the roots that are to be protected with the zero curb cutback.
4. Roots extending into the street, or on top of the existing curb, in areas to paved shall be cut and removed by hand prior to disturbance or removal with equipment. Roots shall be pruned flush with the proposed back of curb. Roots one inch in diameter and larger shall be cut in a manner to provide a smooth, clean cut surface. Cuts shall be made with the appropriate pruning shears or pruning saws. Roots shall not be chopped or broken.
5. In areas where proposed curb will be lower than existing top of curb and tree roots 2" diameter or larger are present, the soil and roots shall not be graded or laid back. The existing elevation shall be maintained and the curb formed to meet elevation or a short elevation difference roots and top of curb maintained.

Q. Demolition, Forming and Pouring of Driveway Approaches

1. Demolition of existing driveway approaches located beneath the dripline of any tree shall be completed without disturbing, cutting, or otherwise damaging tree roots and soil located beneath them.
 2. The new approach shall be formed at or above the elevation of the existing approach where tree roots 2” diameter or larger are present, without disturbing, cutting or otherwise damaging tree roots. Maximum drive slopes may be needed at bottom of apron to allow forming of drive over tree roots at top of drive. As with sidewalks, the elevation of every tree roots was not available in design. If tree roots are found to be in conflict with proposed approach, project engineer and urban forester shall be consulted as to how to install driveway with minimal impacts to adjacent trees.
- R. Replacement Trees for Tree Removals under Ordinance
1. Location, species, and size of replacement trees are indicated on the drawings. Contractor shall layout individual trees at locations shown on drawings. Contractor shall layout individual trees at locations shown on drawings and be responsible for utility locate requirements. In case of conflicts, notify City Engineer and City Urban Forestry before proceeding with work. Trees shall be laid out and locations approved by City Engineer prior to planting.
 2. Trees shall meet and be planted according to City of Houston Standard Specification 02915.
- S. Arborist and Urban Forester Qualifications
1. Arborist – Employ qualified arborist acceptable to City’s Parks and Recreation Department to complete all tree treatments. Arborist shall be normally engaged in the field and have a minimum of 5 years experience. Qualifications of the selected arborist shall be submitted for review and approval by the project engineer and City of Houston.
 2. Urban Forester – An Urban forester shall be hired to monitor and assist with field layout (exact locations of fencing, root pruning, and zero curb cutback) of the tree preservation program during demolition and construction to ensure tree protection procedures and techniques are practiced as specified to address concerns and conditions which occur in the field. At a minimum, the individual responsible for monitoring and field layout of the tree protection shall have a minimum of 5 years of experience as a consultant, and shall not be affiliated with a tree care contractor in the Houston area. Qualifications of the selected urban forester shall be submitted for review and approval by the project engineer and City of Houston Urban Forestry Department.

END OF SECTION

SECTION 01570

STORM WATER POLLUTION PREVENTION CONTROL

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Implementation of Storm Water Pollution Prevention Plans (SWP3) described in Section 01410 - TPDES Requirement.
- B. Installation, maintenance and removal, of storm water pollution prevention structures: diversion dikes, interceptor dikes, diversion swales, interceptor swales, down spout extenders, pipe slope drains, paved flumes and level spreaders. Structures are used during construction and prior to final development of the site.
- C. Filter Fabric Barriers:
 - 1. Type 1: Temporary filter fabric barrier for erosion and sediment control in non-channelized flow areas.
 - 2. Type 2: Temporary reinforced filter fabric barrier for erosion and sediment control in channelized flow areas.
- D. Hay Bale Fence.
- E. Drop Inlet Basket
- F. Inlet Sediment Traps
- G. Brush Berm
- H. Sand Bag Barrier
- I. Bagged Gravel Barrier
- J. Sediment Basin
- K. Inlet Protection Barrier

1.02 RELATED SECTIONS

- A. Document 00410 – Bid Form
- B. Section 01270 – Measurement and Payment
- C. Section 01330 – Submittal Procedures
- D. Section 01410 – TPDES Requirements

- E. Section 01504 - Temporary Facilities and Controls
- F. Section 01562 - Tree and Plant Protection
- G. Section 01575 - Stabilized Construction Access
- H. Section 01576 - Waste Material Disposal
- I. Section 02233 - Clearing and Grubbing
- J. Section 02315 - Roadway Excavation
- K. Section 02317 - Excavation and Backfill for Utilities
- L. Section 02320 - Utility Backfill Materials
- M. Section 02505 - High Density Polyethylene (HDPE) Solid and Profile Wall Pipe
- N. Section 02506 - Polyvinyl Chloride Pipe
- O. Section 02642 - Corrugated Metal Pipe
- P. Section 03315 - Concrete for Utility Construction

1.03 MEASUREMENT AND PAYMENT

A. UNIT PRICES

1. Payment for filter fabric barrier is on a linear foot basis measured between limits of beginning and ending of stakes.
2. Payment for reinforced filter fabric barrier is on a linear foot basis measured between limits of beginning and ending of stakes.
3. Payment for drop inlet baskets is on a unit price basis for each drop inlet basket.
4. Payment for storm inlet sediment traps is on a unit price basis for each storm inlet sediment trap.
5. Payment for storm water pollution prevention structures is on a lump sum basis for the project. Earthen structures with outlet and piping include diversion dikes, interceptor dikes, diversion swales, interceptor swales, and excavated earth-outlet sediment trap, embankment earth-outlet sediment trap, down spout extenders, pipe slope drains, paved flumes, stone outlet sediment trap, and level spreaders.
6. Payment for hay bale barrier, if included in Document 00410 - Bid Form, is on a linear foot of accepted bale barriers, if not include in cost of storm water pollution prevention structures.

7. Payment for brush berm, if included in Document 00410 - Bid Form, is on a linear foot of accepted brush berm, if not include in cost of storm water pollution prevention structures.
 8. Payment for sandbag barrier, if included in Document 00410 - Bid Form, is on a linear foot basis measured between limits of beginning and ending of sandbags, if not include in cost of storm water pollution prevention structures.
 9. Payment for bagged gravel barrier, if included in Document 00410 - Bid Form, is on a linear foot basis measured between limits of beginning and ending of bagged gravel barrier, if not include in cost of storm water pollution prevention controls.
 10. Payment for inlet protection barriers, if included in Document 00410 - Bid Form, is on a linear foot basis measured along outside face of inlet protection barrier, if not include in cost of storm water pollution prevention structures.
 11. Refer to Section 01270 - Measurement and Payment for unit price procedures.
- B. Stipulated Price (Lump Sum) Contract. If Contract is Stipulated Price Contract, payment for Work in this Section is included in total Stipulated

1.04 REFERENCE STANDARDS

- A. ASTM
1. A 36 - Standard Specification for Carbon Structural Steel.
 2. D698 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft³ (600kN-m/m³)).
 3. D3786 - Standard Test Method for Hydraulic Bursting Strength for knitted Goods and Nonwoven Fabrics.
 4. D 4355 - Standard Test Method for Deterioration of Geotextiles from Exposure to Ultraviolet Light and Water (Xenon-Arc Type Apparatus).
 5. D 4491 - Standard Test Methods for Water Permeability of Geotextiles by Permittivity.
 6. D 4632 - Standard Test Method for Grab Breaking Load and Elongation of Geotextiles.
 7. D 4833 - Standard Test Method for Index Puncture Resistance of Geotextiles, Geomembranes, and Related Products.
 8. D 6382 - Standard Practice for Dynamic Mechanical Analysis and Thermogravimetry of Roofing and Waterproofing Membrane Material.

- B. Storm Water Management Handbook for Construction Activities prepared by City of Houston, Harris County and Harris County Flood Control District.

1.05 SYSTEM DESCRIPTIONS

- A. Filter Fabric Barrier Type 1 and Type 2: Install to allow surface or channel runoff percolation through fabric in sheet-flow manner and to retain and accumulate sediment. Maintain Filter Fabric Barriers to remain in proper position and configuration at all times.
- B. Hay Bale Fence: Install to allow surface runoff percolation through hay in sheet-flow manner and to retain and accumulate sediment. Maintain Hay Bale Fence to remain in proper position and configuration at all times.
- C. Interceptor Dikes and Swales: Construct to direct surface or channel runoff around the project area or runoff from project area into sediment traps.
- D. Drop Inlet Baskets: Install to allow runoff percolation through the basket and to retain and accumulate sediment. Clean accumulation of sediment to prevent clogging and backups.
- E. Sediment Traps: Construct to pool surface runoff from construction area to allow sediment to settle onto the bottom of trap.
- F. Sand Bags: Are used during construction activities in unstabilized minor swales, ditches, or streambeds when the contributing drainage area is no greater than 2 acres. It is also sediment barrier for stage one Inlet.
- G. Bagged Gravel Barrier: Are used during construction activities in unstabilized minor swales, ditches, or streambeds when the contributing drainage area is no greater than 2 acres. It is also sediment barrier for stage two Inlet.
- H. Drop Inlet Insert Basket: Is a temporary barrier placed within a storm drain inlet (Lower Portion of Stage I and Upper Portion of Stage II Inlets) consisting of a filter fabric supported by a metal frame work to prevent sediment and other pollutants from entering convey system.
- I. Brush Berm: Brush Berm is constructed at the perimeter of a distribute site within the developing area.

1.06 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. Submit manufacturer's literature for product specifications and installation instructions.
- C. Submit manufacturer's catalog sheets and other product data on geotextile or filter fabrics, outlet pipe, perforated riser and connectors.

- D. Submit proposed methods, equipment, materials, and sequence of operations for storm-water pollution prevention structures.
- E. Submit shop drawings for Drop Inlet Baskets.

PART 2 PRODUCTS

2.01 CONCRETE

- A. Concrete: Class B in accordance with Section 03315 - Concrete for Utility Construction or as shown on the Drawings.

2.02 AGREGATE MATERIALS

- A. Use poorly graded cobbles with diameter greater than 3 inches and less than 5 inches.
- B. Provide gravel lining in accordance with Section 2320 - Utility Backfill Materials or as shown on the drawings.
- C. Provide clean cobbles and gravel consisting of crushed concrete or stone. Use clean, hard crushed concrete or stone free from adherent coatings, salt, alkali, dirt, clay, loam, shale, soft or flaky materials, or organic matter.
- D. Sediment Pump Pit Aggregate: Use nominal 2-inch diameter river gravel.

2.03 PIPE

- A. Polyethylene culvert pipe or PVC sewer pipe in accordance with Section 02505- High Density Polyethylene (HDPE) Solid and Profile Wall Pipe and Section 02506 Polyvinyl Chloride Pipe or as shown on the Drawings.
- B. Inlet Pipes: Galvanized steel pipe in accordance with Section 02642 Corrugated Metal Pipe or as shown on the Drawings.
- C. Standpipe for Sediment Pump Pits: Galvanized round culvert pipe or round PVC pipe, minimum of 12-inch and a maximum of 24-inch diameter, perforate at 6 to 12 inch centers around circumference.

2.04 GEOTEXTILE FILTER FABRIC

- A. Woven or nonwoven geotextile filter fabric made of either polypropylene, polyethylene, ethylene, or polyamide material, in continuous rolls of longest practical length.
- B. Grab Strength: 100 psi in any principal direction (ASTM D-4632), Mullen burst strength >200 psi (ASTM D-3786), and equivalent opening size between 50 and 140.
- C. Furnish ultraviolet inhibitors and stabilizers for minimum 6 months of expected usable construction life at temperature range of 0 degrees F to 120 degrees F.

- D. Mirafi, Inc., Synthetic Industries, or equivalent

2.05 BARRIER

- A. Wire Barrier: Woven galvanized steel wire, 14 gauge by 6-inch square mesh spacing, minimum 24 inch roll or sheet width of longest practical length.
- B. Barrier Stakes: Nominal 2 by 2 inch moisture-resistant treated wood or steel posts (min. of 1.25 lbs. per linear foot and Brinell Hardness greater than 140) with safety caps on top length as required for minimum 8 inch bury and full height of filter fabric.

2.06 SANDBAGS

- A. Provide woven material made of polypropylene, polyethylene, or polyamide material.
 - 1. Minimum unit weight of four ounces per square yard.
 - 2. Minimum grab strength of 100 lbs in any principal direction (ASTM D4632)
 - 3. Mullen burst strength exceeding 300 lbs (ASTM D4833).
 - 4. Ultraviolet stability exceeding 70 percent. After 500 hours of exposure (ASTM 4355).
 - 5. Size: Length: 18 to 24 inches. Width: 12 to 18 inches. Thickness: 6 to 8 inches. Weight: Approximately 40 to 50 pounds not to exceed 75 pounds.

2.07 BAGGED GRAVEL BARRIER

- A. Minimum unit weight of four ounces per square yard.
- B. Minimum grab strength of 100 lbs in any principal direction (ASTM D4632)
- C. Mullen burst strength exceeding 300 lbs (ASTM D4833).
- D. Ultraviolet stability exceeding 70 percent. After 500 hours of exposure (ASTM 4355).
- E. Size: Length: 18 to 24 inches. Width: 12 to 18 inches. Thickness: 6 to 8 inches. Weight: Approximately 40 to 50 pounds not to exceed 75 pounds.

2.08 DROP INLET BASKET

- A. Provide steel frame members in accordance with ASTM A36.

- B. Construct top frame of basket with two short sides of 2 inch by 2 inch and single long side of 1 inch by 1 inch, 1/8 inch angle iron. Construct basket hangers of 2 inch by 1/4 inch iron bars. Construct bottom frame of 1 inch by 1/4 inch iron bar or 1/4 inch plate with center 3 inches removed. Use minimum 1/4 inch diameter iron rods or equivalent for sides of inlet basket.
- C. Weld minimum of 14 rods in place between top frame/basket hanger and bottom frame. Exact dimensions for top frame and insert basket will be determined based on dimensions of type of inlet being protected.

2.09 HAY BALE

- A. Hay: Standard-baled agricultural hay bound by wire, nylon, or polypropylene rope. Do not use jute or cotton binding.
- B. Hay Bale Stakes (applicable where bales are on soil): No. 3 (3/8 diameter) reinforcing bars, deformed or smooth at Contractor's option, length as required for minimum 18 inch bury and full height bales.

PART 3 EXECUTION

3.01 PREPARATION, INSTALLATION AND MAINTENANCE

- A. Provide erosion and sediment control structures at locations shown on the Drawings.
- B. Do not clear, grub or rough cut until erosion and sediment control systems are in place unless approved by Project Manager to allow installation of erosion and sediment control systems, soil testing and surveying.
- C. Maintain existing erosion and sediment control systems located within project site until acceptance of Project or until directed by Project Manager to remove and discard existing system.
- D. Regularly inspect and repair or replace damaged components of erosion and sediment control structures. Unless otherwise directed, maintain erosion and sediment control structure until project area stabilization is accepted. Redress and replace granular fill at outlets as needed to replenish depleted granular fill. Remove erosion and sediment control structures promptly when directed by Project Manger. Dispose of materials in accordance with Section 01576 - Waste Material Disposal.
- E. Remove and dispose sediment deposits at the designated spoil site for the Project. If a project spoil site is not designated on Drawings, dispose of sediment off site at approved location in accordance with Section 01576 - Waste Material Disposal.
- F. Unless otherwise shown on the Drawings, compact embankments, excavations, and trenches in accordance with Section 02315 - Roadway Excavation or Section - 02317 Excavation and Backfill for Utilities.

- G. Prohibit equipment and vehicles from maneuvering on areas outside of dedicated right of way and easements for construction. Immediately repair damage caused by construction traffic to erosion and sediment control structures.
- H. Protect existing trees and plants in accordance with Section 01562 - Tree and Plant Protection.

3.02 SEDIMENT TRAPS

- A. Install sediment traps so that surface runoff shall percolate through system in sheet flow fashion and allow retention and accumulation of sediment.
- B. Inspect sediment traps after each rainfall, daily during periods of prolonged rainfall, and at a minimum once each week. Repair or replace damaged sections immediately.
- C. Use fill material for embankment in accordance with Section 02320 - Utility Backfill Materials.
- D. Excavation length and height shall be as specified on Drawings. Use side slopes of 2:1 or flatter.
- E. Stone outlet sediment traps:
 - 1. Maintain minimum of 6 inches between top of core material and top of stone outlet, minimum of 4 inches between bottom of core material and existing ground and minimum of 1 foot between top of stone outlet and top of embankment.
 - 2. Embed cobbles minimum of 4 inches into existing ground for stone outlet. Core shall be minimum of 1 foot in height and in width and wrapped in triple layer of geotextile filter fabric.
- F. Sediment Basin with Pipe Outlet Construction Methods: Install outlet pipe and riser as shown on the Drawings.
- G. Remove sediment deposits when design basin volume is reduced by one- third or sediment level is one foot below principal spillway crest, whichever is less.

3.03 FILTER FABRIC BARRIER CONSTRUCTION METHODS

- A. Fence Type 1: Filter Fabric: Barrier
 - 1. Install stakes 3 feet on center maximum and firmly embed minimum 8 inches in soil. If filter fabric is factory preassembled with support netting, then maximum support spacing is 8 feet. Install wood stakes at a slight angle toward the source of anticipated runoff.

2. Trench in the toe of the fence lines so the downward face of the trenches is flat and perpendicular to direction of flow. V-trench configuration as shown on Drawings may also be used.
 3. Lay fabric along edges of trenches in longest practical continuous runs to minimize joints. Make joints only at a support post. Splice with minimum 6-inch overlap and seal securely.
 4. Staple filter fabric to stakes at maximum 3 inches on center. Extend fabric minimum 18 inches and maximum 36 inches above natural ground.
 5. Backfill and compact trench.
- B. Barrier Type 2: Reinforced Filter Fabric Barrier
1. Layout barrier same as for Type 1.
 2. Install stakes at 6 feet on center maximum and at each joint in wire fence, firmly embedded 1-foot minimum, and inclined it as for Type 1.
 3. Tie wire fence to stakes with wire at 6 inches on center maximum. Overlap joints minimum one bay of mesh.
 4. Install trench same as for Type 1.
 5. Fasten filter fabric wire fence with tie wires at 3 inches on center maximum.
 6. Layout fabric same as for Type 1. Fasten to wire fence with wire ties at 3 inches on center maximum and, if applicable, to stakes above top of wire fence it as for Type 1.
 7. Backfill and compact trench.
 8. Attach filter fabric to wooden fence stakes spaced a maximum of 6 feet apart or steel fence stakes spaced a maximum of 8 feet apart and embedded a minimum of 12 inches. Install stakes at a slight angle toward source of anticipated runoff.
 9. Trench in toe of filter fabric barrier with spade or mechanical trencher so that downward face of trench is flat and perpendicular to direction of flow. A V-trench configuration may also be used. Lay filter fabric along edges of trench. Backfill and compact trench upon completion of Construction.
 10. Filter fabric fence shall have a minimum height of 18 inches and a maximum height of 36 inches above natural ground.
 11. Cut length of fence to minimize use of joints. When joints are necessary, splice fabric together only at support post with minimum 6 inch overlap and seal securely.

12. When used in swales, ditches or diversions, elevation of barrier at top of filter fabric at flow line location in channel shall be lower than bottom elevation of filter fabric at ends of barrier or top of bank, whichever is less, in order to keep storm water discharge in channel from overtopping bank.

C. Triangular Filter Fabric Barrier Construction Methods

1. Attach filter fabric to wire fencing, 18 inches on each side. Provide a fabric cover and skirt with continuous wrapping of fabric. Skirt should form continuous extension of fabric on upstream side of fence.
2. Secure triangular fabric filter barrier in place using one of the following methods:
 - a. Toe-in skirt 6 inches with mechanically compacted material
 - b. Weight down skirt with continuous layer of 3-inch to 5-inch graded rock or
 - c. Trench-in entire structure 4 inches.
3. Anchor triangular fabric filter barrier structure and skirt securely in place using 6-inch wire staples on 2-foot centers on both edges and on skirt, or staked using 18-inch by 3/8-inch diameter re-bar with tee ends.
4. Lap fabric filter material by 6 inches to cover segment joints. Fasten joints with galvanized shoat rings.

3.04 DIKE AND SWALE

- A. Unless otherwise indicated, maintain minimum dike height of 18 inches, measured from cleared ground at up slope toe to top of dike. Maintain side slopes of 2:1 or flatter.
- B. Dike and Swale Stabilization: When shown on the Drawings, place gravel lining 3 inches thick and compacted into the soil or 6 inches thick if truck crossing is expected. Extend gravel lining across bottom and up both sides of swale minimum height of 8 inches vertically, above bottom. Gravel lining on dike side shall extend up the up slope side of dike a minimum height of 8 inches, measured vertically from interface of existing or graded ground and up slope toe of dike, as shown on Drawings.
- C. Divert flow from dikes and swales to sediment basins, stabilized outlets, or sediment trapping devices of types and at locations shown on Drawings. Grade dikes and swales as shown on Drawings, or, if not specified, provide positive drainage with maximum grade of 1 percent to outlet or basin.
- D. Clear in accordance with Section 2233 - Clearing and Grubbing Compact embankments in accordance with Section 2315 - Roadway Excavation.

- E. Carry out excavation for swale construction so that erosion and water pollution is minimal. Minimum depth shall be 1 foot and bottom width shall be 4 feet, with level swale bottom. Excavation slopes shall be 2:1 or flatter. Clear, grub and strip excavation area of vegetation and root material.

3.05 DOWN SPOUT EXTENDER

- A. Down spout extender shall have slope of approximately 1 percent. Use pipe diameter of 4 inches or as shown on the Drawings. Place pipe in accordance with Section 02317 – Excavation and Backfill for Utilities.

3.06 PIPE SLOPE DRAIN

- A. Compact soil around and under drain entrance section to top of embankment in lifts appropriately sized for method of compaction utilized.
- B. Inlet pipe shall have slope of 1 percent or greater. Use pipe diameter as shown on the Drawings.
- C. Top of embankment over inlet pipe and embankments directing water to pipe shall be at least 1 foot higher at all points than top of inlet pipe.
- D. Pipe shall be secured with hold-down grommets spaced 10 feet on centers.
- E. Place riprap apron with a depth equal to pipe diameter with 2:1 side slopes.

3.07 PAVED FLUME

- A. Compact soil around and under the entrance section to top of the embankment in lifts appropriately sized for method of compaction utilized.
- B. Construct subgrade to required elevations. Remove and replace soft sections and unsuitable material. Compact subgrade thoroughly and shape to a smooth, uniform surface.
- C. Construct permanent paved flumes in accordance with Drawings.
- D. Remove sediment from riprap apron when sediment has accumulated to depth of one foot.

3.08 LEVEL SPREADER

- A. Construct level spreader on undisturbed soil and not on fill. Ensure that spreader lip is level for uniform spreading of storm runoff.
- B. Maintain at required depth, grade, and cross section as specified on Drawings. Remove sediment deposits as well as projections or other irregularities which will impede normal flow.

3.09 INLET PROTECTION BARRIER

- A. Place sandbags for Stage I, Bagged gravel for Stage II and filter fabric barriers at locations shown on the SWP3. Maintain to allow minimal inlet in flow restrictions / blockage during storm event.

3.10 DROP INLET BASKET CONSTRUCTION METHODS

- A. Fit inlet insert basket into inlet without gaps around insert at locations shown on the SWP3.
- B. Support for inlet insert basket shall consist of fabricated metal as shown on Drawings.
- C. Push down and form filter fabric to shape of basket. Use sheet of fabric large enough to be supported by basket frame when holding sediment and extend at least 6 inches past frame. Place inlet grates over basket/frame to serve as fabric anchor.
- D. Remove sediment deposit after each storm event and whenever accumulation exceeds 1-inch depth during weekly inspections.

3.11 HAY BALE FENCE CONSTRUCTION METHODS

- A. Place bales in row with ends tightly abutting adjacent bales. Place bales with bindings parallel to ground surface.
- B. Embed bale in soil a minimum of 4 inches.
- C. Securely anchor bales in place with Hay Bale Stakes driven through bales a minimum of 18-inches into ground. Angle first stake in each bale toward previously laid bale to force bales together.
- D. Fill gaps between bales with straw to prevent water from channeling between bales. Wedge carefully in order not to separate bales.
- E. Replace with new hay bale fence every two months or as required by Project Manager.

3.12 BRUSH BERM CONSTRUCTION METHODS

- A. Construct brush berm along contour lines by hand placing method. Do not use machine placement of brush berm.
- B. Use woody brush and branches having diameter less than 2-inches with 6- inches overlap. Avoid incorporation of annual weeds and soil into brush berm.
- C. Use minimum height of 18-inches measured from top of existing ground at upslope toe to top of berm. Top width shall be 24 inches minimum and side slopes shall be 2:1 or flatter.

- D. Embed brush berm into soil a minimum of 4-inches and anchor using wire, nylon or polypropylene rope across berm with a minimum tension of 50 pounds. Tie rope securely to 18-inch x 3/8-inch diameter rebar stakes driven into ground on 4-foot centers on both sides of berm.

3.13 STREET AND SIDEWALK CLEANING

- A. Keep areas clean of construction debris and mud carried by construction vehicles and equipment. If necessary, install stabilized construction exits at construction, staging, storage, and disposal areas, following Section 01575- Stabilized Construction Access.
- B. In lieu of or in addition to stabilized construction exits, shovel or sweep pavements as required to keep areas clean. Do not waterhose or sweep debris and mud off street into adjacent areas, except, hose sidewalks during off-peak hours, after sweeping.

3.14 WASTE COLLECTION AREAS

- A. Prevent water runoff from passing through waste collection areas, and prevent water runoff from waste collection areas migrating outside collection areas.

3.15 EQUIPMENT MAINTENANCE AND REPAIR

- A. Confine maintenance and repair of construction machinery and equipment to areas specifically designated for that purpose, so fuels, lubricants, solvents, and other potential pollutants are not washed directly into receiving streams or storm water conveyance systems. Provide these areas with adequate waste disposal receptacles for liquid and solid waste. Clean and inspect maintenance areas daily.
- B. Where designated equipment maintenance areas are not feasible, take precautions during each individual repair or maintenance operation to prevent potential pollutants from washing into streams or conveyance systems. Provide temporary waste disposal receptacles.

3.16 VEHICLE/ EQUIPMENT WASHING AREAS

- A. Install wash area (stabilized with coarse aggregate) adjacent to stabilized construction access, as required to prevent mud and dirt run-off. Release wash water into drainage swales or inlets protected by erosion and sediment controls. Build wash areas following Section 01575- Stabilized Construction Access. Install gravel or rock base beneath wash areas.
- B. Wash vehicles only at designated wash areas. Do not wash vehicles such as concrete delivery trucks or dump trucks and other construction equipment at locations where runoff flows directly into waterways or storm water conveyance systems.
- C. Locate wash areas to spread out and evaporate or infiltrate wash water directly into ground, or collect runoff in temporary holding or seepage basins.

3.17 WATER RUNOFF AND EROSION CONTROL

- A. Control surface water, runoff, subsurface water, and water from excavations and structures to prevent damage to the Work, the site, or adjoining properties. Follow environment requirements.
- B. Control fill, grading and ditching to direct water away from excavations, pits, tunnels, and other construction areas, and to direct drainage to proper runoff courses to prevent erosion, sedimentation or damage.
- C. Provide, operate, and maintain equipment and facilities of adequate size to control surface water.
- D. Retain existing drainage patterns external to the site by constructing temporary earth berms, sedimentation basins, retaining areas, and temporary ground cover as required to control conditions.
- E. Plan and execute construction and earth work to control surface drainage from cuts and fills, and from borrow and waste disposal areas, to prevent erosion and sedimentation.
 - 1. Hold area of bare soil exposed at one time to a minimum.
 - 2. Provide temporary controls such as berms, dikes, and drains.
- F. Construct fill and waste areas by selective placement to eliminate surface silts or clays which will erode.
- G. Inspect earthwork periodically to detect start of erosion. Immediately apply corrective measures as required to control erosion.
- H. Dispose of sediments offsite, not in or adjacent to waterways or floodplains, nor allow sediments to flush into streams or drainage ways. Assume responsibility for offsite disposal location.
- I. Unless otherwise indicated, compact embankments, excavations, and trenches by mechanically blading, tamping, and rolling soil in maximum of 8- inch layers. Provide compaction density at minimum 90 percent Standard Proctor ASTM D-698-78 density. Make at least one test per 500 cubic yards of embankment.
- J. Prohibit equipment and vehicles from maneuver on areas outside of dedicated rights-of-way and easements for construction. Immediately repair damage to erosion and sedimentation control systems caused by construction traffic.
- K. Do not damage existing trees intended to remain.

3.18 REMOVAL OF CONTROLS

- A. Remove erosion and sediment controls when the site is finally stabilized or as directed by Project Manager.

- B. Dispose of sediments and waste products following Section 01504 - Temporary Facilities and Controls.

END OF SECTION

SECTION 01575

STABILIZED CONSTRUCTION ACCESS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Installation and removal of erosion and sediment control for stabilized construction access used during construction and prior to final development of site, as shown in City of Houston Standard Construction details, DWG No. 01571-01.

1.02 RELATED SECTIONS

- A. Section 01270 – Measurement and Payment
- B. Section 01330 – Submittal Procedures
- C. Section 01570 – Storm Water Pollution Prevention Control

1.03 MEASUREMENT AND PAYMENT

- A. Unit Price Contracts. If Contract is Unit Price Contract, payment for work in this Section will be based on the following:
 - 1. Stabilized construction roads, parking areas, access and wash areas: per square yard of aggregate/recycled concrete without reinforcing placed in 8-inch layers. No separate payment will be made for street cleaning necessary to meet TPDES requirements. Include cost of work for street cleaning under related Specification section.
- B. Stipulated Price (Lump Sum) Contracts. If the Contract is a Stipulated Price Contract, include payment for work under this Section in the total Stipulated Price.
- C. Refer to Section 01270 - Measurement and Payment for unit price procedures.

1.04 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. Submit manufacturers catalog sheets and other Product Data on geotextile fabric.
- C. Submit sieve analysis of aggregates conforming to requirements of this Specification.

1.05 REFERENCES

- A. ASTM D 4632 - Standard Test Method for Grab Breaking Load and Elongation of Geotextiles.

- B. Storm Water Quality Management Handbook For Construction Activities prepared by the City of Houston, Harris County and Harris County Flood Control District.

PART 2 PRODUCTS

2.01 GEOTEXTILE FABRIC

- A. Provide woven or non-woven geotextile fabric made of polypropylene, polyethylene, ethylene, or polyamide material.
- B. Geotextile fabric: Minimum grab strength of 200 lbs in any principal direction (ASTM D-4632) and equivalent opening size between 50 and 140.
- C. Geotextile and threads: Resistant to chemical attack, mildew, and rot and contain ultraviolet ray inhibitors and stabilizers to provide minimum of six months of expected usable life at temperature range of 0 to 120 degrees F.
- D. Representative Manufacturers: Mirafi, Inc. or equal.

2.02 COARSE AGGREGATES

- A. Coarse aggregate: Crushed stone, gravel, crushed blast furnace slag, or combination of these materials. Aggregate shall be composed of clean, hard, durable materials free from adherent coatings of, salt, alkali, dirt, clay, loam, shale, soft or flaky materials, or organic and injurious matter.
- B. Coarse aggregates to consist of open graded rock 2” to 8” in size.

PART 3 EXECUTION

3.01 PREPARATION AND INSTALLATION

- A. Provide stabilized construction roads and access at construction, staging, parking, storage, and disposal areas to keep street clean of mud carried by construction vehicles and equipment. Construct erosion and sediment controls in accordance with Drawings and Specification requirements.
- B. Do not clear grub or rough cut until erosion and sediment control systems are in place, unless approved by Project Manager to allow soil testing and surveying.
- C. Maintain existing construction site erosion and sediment control systems until acceptance of the Work or until removal of existing systems is approved by Project Manager.

- D. Regularly inspect, repair or replace components of stabilized construction access. Unless otherwise directed, maintain stabilized construction roads and access until the City accepts the Work. Remove stabilized construction roads and access promptly when directed by Project Manager. Discard removed materials off-site.
- E. Remove and dispose of sediment deposits at designated spoil site for Project. If a spoil site is not designated on Drawings, dispose of sediment off-site at a location not in or adjacent to stream or flood plain. Assume responsibility for off-site disposal.
- F. Spread compacted and stabilized sediment evenly throughout site. Do not allow sediment to flush into streams or drainage ways. Dispose of contaminated sediment in accordance with existing federal, state, and local rules and regulations.
- G. Prohibit equipment and vehicles from maneuvering on areas outside of dedicated rights-of-way and easements for construction. Immediately repair damage to erosion and sediment control systems caused by construction traffic.
- H. Conduct construction operations in conformance with erosion control requirements of Specification 01570 – Storm Water Pollution Prevention Control.

3.02 CONSTRUCTION MAINTENANCE

- A. Provide stabilized access roads, subdivision roads, parking areas, and other on-site vehicle transportation routes where shown on Drawings.
- B. Provide stabilized construction access and vehicle washing areas, when approved by Project Manager, of sizes and at locations shown on Drawings or as specified in this Section.
- C. Clean tires to remove sediment on vehicles leaving construction areas prior to entering public right-of-ways. Construct wash areas needed to remove sediment. Release wash water into drainage swales or inlets protected by erosion and sediment control measures.
- D. Details for stabilized construction access are shown on Drawings. Construct other stabilized areas to same requirements. Maintain minimum roadway widths of 14 feet for one-way traffic and 20 feet for two-way traffic and of sufficient width to allow ingress and egress. Place geotextile fabric as a permeable separator to prevent mixing of coarse aggregate with underlying soil. Limit exposure of geotextile fabric to elements between laydown and cover to a maximum 14 days to minimize potential damage.
- E. Grade roads and parking areas to provide sufficient drainage away from stabilized areas. Use sandbags, gravel, boards, or similar materials to prevent sediment from entering public right-of-ways, waterways or storm water conveyance systems.

- F. Inspect and maintain stabilized areas daily. Provide periodic top dressing with additional coarse aggregates to maintain required depth. Repair and clean out damaged control systems used to trap sediment. Immediately remove spilled, dropped, washed, or tracked sediment from public right-of- ways.
- G. Maintain lengths of stabilized areas as shown on Drawings or a minimum of 50 feet. Maintain a minimum thickness of 8 inches. Maintain minimum widths at all points of ingress or egress.
- H. Stabilize other areas with the same thickness, and width of coarse aggregate required for stabilized construction access, except where shown otherwise on Drawings.
- I. Stabilized areas may be widened or lengthened to accommodate truck washing areas when authorized by Project Manager.
- J. Clean street daily before end of workday. When excess sediments have tracked onto streets, Project Manager may direct Contractor to clean street as often as necessary. Remove and legally dispose of sediments.
- K. Use other erosion and sediment control measures to prevent sediment runoff during rain periods and non-working hours and when storm discharges are expected.

END OF SECTION

SECTION 01576

WASTE MATERIAL DISPOSAL

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Disposal of waste material and salvageable material.

1.02 RELATED SECTIONS

- A. Section 01330 – Submittal Procedures
- B. Section 01410 – TPDES Requirements

1.03 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. Submit copy of approved "Development Permit", as defined in Chapter 19 of Floodplain Ordinance (City Ordinance Number 81-914 and Number 85- 1705), prior to disposal of excess material in areas designated as being in "100-year Standard Flood Hazard Area" within the City and areas designated as being in "500-year Standard Flood Hazard Area". Contact the City of Houston Floodplain Management Office at the Houston Permitting Center (1002 Washington Avenue, 3rd Floor), at (832) 394-8854 for floodplain information.
- C. Obtain and submit disposal permits for proposed disposal sites, if required by local ordinances.
- D. Submit copy of written permission from property owner, with description of property, prior to disposal of excess material adjacent to Project. Submit written and signed release from property owner upon completion of disposal work.
- E. Describe waste materials expected to be stored on-site and a description of controls to reduce Pollutants from these materials, including storage practices to minimize exposure of materials to storm water; and spill prevention and response measures in the Project's Storm Water Pollution Prevention Plan (SWPPP). Refer to Section 01410 - TPDES Requirements.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 SALVAGEABLE MATERIAL

- A. Excavated Material: When indicated on Drawings, load, haul, and deposit excavated material at location or locations shown on Drawings outside limits of Project.
- B. Base, Surface, and Bedding Material: Load shell, gravel, bituminous, or other base and surfacing material designated for salvage into City trucks.
- C. Pipe Culvert: Load culverts designated for salvage into City trucks.
- D. Other Salvageable Materials: Conform to requirements of individual Specification Sections.
- E. Coordinate loading of salvageable material on City trucks with Project Manager.

3.02 EXCESS MATERIAL

- A. Remove and legally dispose of vegetation, rubble, broken concrete, debris, asphaltic concrete pavement, excess soil, and other materials not designated for salvage from job site.
- B. Excess soil may be deposited on private property adjacent to Project when written permission is obtained from property owner. See Paragraph 1.03 D above.
- C. Verify floodplain status of any proposed disposal site. Do not dispose of excavated materials in area designated as within 100-year and 500-year Standard Flood Hazard Areas unless "Development Permit" has been obtained. Remove excess material placed in "100-year and 500-year Standard Flood Hazard Areas" within the City without "Development Permit", at no additional cost to the City.
- D. Remove waste materials from site daily, in order to maintain site in neat and orderly condition.

END OF SECTION

SECTION 01578

CONTROL OF GROUND AND SURFACE WATER

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Dewatering, depressurizing, draining, and maintaining trenches, shaft excavations, structural excavations and foundation beds in stable condition, and controlling ground water conditions for tunnel excavations.
- B. Protecting work against surface runoff and rising floodwaters.
- C. Trapping suspended sediment in the discharge from the surface and ground water control systems.

1.02 RELATED SECTIONS

- A. Document 00410 – Bid Form
- B. Section 01270 – Measurement and Payment
- C. Section 01330 – Submittal Procedures
- D. Section 02260 – Trench Safety System

1.03 MEASUREMENT AND PAYMENT

A. UNIT PRICES

- 1. Measurement for control of ground water, if included in Document 00410 – Bid Form, will be on either a lump sum basis or a linear foot basis for continuous installations of wellpoints, eductor wells, or deep wells.
- 2. If not included in Document 00410 – Bid Form, include the cost to control ground water in unit price for work requiring such controls.
- 3. No separate payment will be made for control of surface water. Include cost to control surface water in unit price for work requiring controls.
- 4. Follow Section 01270 – Payment Procedures for unit price procedures.

- B. Stipulated Price (Lump Sum) Contract. If the Contract is a Stipulated Price Contract, include payment for work under this section in the total Stipulated Price.

1.04 REFERENCES

- A. ASTM D 698 - Standard Test Methods for Laboratory Compaction of Soils Using Standard Effort (12,400 ft-lbf/ft³ (600kN-m/m³))
- B. Federal Regulations, 29 CFR Part 1926, Standards-Excavation, Occupational Safety and Health Administration (OSHA)
- C. Storm Water Management Handbook for Construction Activities prepared by City of Houston, Harris County and Harris County Flood Control District.

1.05 DEFINITIONS

- A. Ground water control system: system used to dewater and depressurize water-bearing soil layers.
 - 1. Dewatering: lowering the water table and intercepting seepage that would otherwise emerge from slopes or bottoms of excavations, or into tunnels and shafts; and disposing of removed water. Intent of dewatering is to increase stability of tunnel excavations and excavated slopes, prevent dislocation of material from slopes or bottoms of excavations, reduce lateral loads on sheeting and bracing, improve excavating and hauling characteristics of excavated material, prevent failure or heaving of bottom of excavations, and to provide suitable conditions for placement of backfill materials and construction of structures and other installations.
 - 2. Depressurization: includes reduction in piezometric pressure within strata not controlled by dewatering alone, necessary to prevent failure or heaving of excavation bottom or instability of tunnel excavations.
- B. Excavation drainage: includes keeping excavations free of surface and seepage water.
- C. Surface drainage: includes use of temporary drainage ditches and dikes and installation of temporary culverts and sump pumps with discharge lines necessary to protect Work from any source of surface water.
- D. Monitoring facilities for ground water control system: includes piezometers, monitoring wells and flow meters for observing and recording flow rates.

1.06 PERFORMANCE REQUIREMENTS

- A. Conduct subsurface investigations to identify groundwater conditions and to provide parameters for design, installation, and operation of groundwater control systems. Submit proposed method and spacing of readings for review prior to obtaining water level readings.
- B. Design ground water control system, compatible with requirements of Federal Regulations 29 CFR Part 1926 and Section 02260 - Trench Safety Systems to produce following results:
 - 1. Effectively reduce hydrostatic pressure affecting:

- a. Excavations
 - b. Tunnel excavation, face stability or seepage into tunnels
 2. Develop substantially dry and stable subgrade for subsequent construction operations
 3. Preclude damage to adjacent properties, buildings, structures, utilities, installed facilities and other work
 4. Prevent loss of fines, seepage, boils, quick condition, or softening of foundation strata
 5. Maintain stability of sides and bottom of excavations
 - C. Provide ground water control systems that include single-stage or multiple-stage well point systems, eductor and ejector-type systems, deep wells, or combinations of these equipment types.
 - D. Provide drainage of seepage water and surface water, as well as water from other sources entering excavation. Excavation drainage may include placement of drainage materials, crushed stone and filter fabric, together with sump pumping.
 - E. Provide ditches, berms, pumps and other methods necessary to divert and drain surface water from excavation and other work areas.
 - F. Locate ground water control and drainage systems so as not to interfere with utilities, construction operations, adjacent properties, or adjacent water wells.
 - G. Assume sole responsibility for ground water control systems and for any loss or damage resulting from partial or complete failure of protective measures and settlement or resultant damage caused by ground water control operations. Modify ground water control systems or operations if they cause or threaten to cause damage to new construction, existing site improvements, adjacent property, adjacent water wells, or potentially contaminated areas. Repair damage caused by ground water control systems or resulting from failure of system to protect property as required.
 - H. Install an adequate number of piezometers installed at proper locations and depths, necessary to provide meaningful observations of conditions affecting excavation, adjacent structures and water wells.
 - I. Install environmental monitoring wells at proper locations and depths necessary to provide adequate observations of hydrostatic conditions and possible contaminant transport from contamination sources into work area or ground water control system.
- 1.07 SUBMITTALS
- A. Conform to requirements of Section 01330 - Submittals Procedures.

- B. Submit Ground Water and Surface Water Control Plan for review by Project Manager prior to start of excavation work. Include the following:
1. Results of subsurface investigations and description of extent and characteristics of water bearing layers subject to ground water control
 2. Names of equipment Suppliers and installation Subcontractors
 3. Description of proposed ground water control systems indicating arrangement, location, depth and capacities of system components, installation details and criteria and operation and maintenance procedures
 4. Description of proposed monitoring facilities indicating depths and locations of piezometers and monitoring wells, monitoring installation details and criteria, type of equipment and instrumentation with pertinent data and characteristics
 5. Description of proposed filters including types, sizes, capacities and manufacturer's application recommendations
 6. Design calculations demonstrating adequacy of proposed systems for intended applications. Define potential area of influence of ground water control operation near contaminated areas.
 7. Operating requirements, including piezometric control elevations for dewatering and depressurization
 8. Excavation drainage methods including typical drainage layers, sump pump application and other means
 9. Surface water control and drainage installations
 10. Proposed methods and locations for disposing of removed water
- C. Submit following records upon completion of initial installation:
1. Installation and development reports for well points, eductors, and deep wells
 2. Installation reports and baseline readings for piezometers and monitoring wells
 3. Baseline analytical test data of water from monitoring wells
 4. Initial flow rates
- D. Submit the following records weekly during control of ground and surface water operations:

1. Records of flow rates and piezometric elevations obtained during monitoring of dewatering and depressurization. Refer to Section 3.02, Requirements for Eductor, Well Points, or Deep Wells.
2. Maintenance records for ground water control installations, piezometers and monitoring wells

1.08 ENVIRONMENTAL REQUIREMENTS

- A. Comply with requirements of agencies having jurisdiction.
- B. Comply with Texas Commission on Environmental Quality regulations and Texas Water Well Drillers Association for development, drilling, and abandonment of wells used in dewatering system.
- C. Obtain necessary permits from agencies with jurisdiction over use of groundwater and matters affecting well installation, water discharge, and use of existing storm drains and natural water sources. Since review and permitting process may be lengthy, take early action to obtain required approvals.
- D. Monitor ground water discharge for contamination while performing pumping in vicinity of potentially contaminated sites.

PART 2 PRODUCTS

2.01 EQUIPMENT AND MATERIALS

- A. Select equipment and materials necessary to achieve desired results for dewatering. Selected equipment and materials are subject to review by Project Manager through submittals required in Section 1.07, Submittals.
- B. Use experienced contractors, regularly engaged in ground water control system design, installation, and operation, to furnish and install and operate educators, well points, or deep wells, when needed
- C. Maintain equipment in good repair and operating condition.
- D. Keep sufficient standby equipment and materials available to ensure continuous operation, where required.
- E. Portable Sediment Tank System: Standard 55-gallon steel or plastic drums, free of hazardous material contamination.
 1. Shop or field fabricate tanks in series with main inlet pipe, inter-tank pipes and discharge pipes, using quantities sufficient to collect sediments from discharge water.

PART 3 EXECUTION

3.01 GROUND WATER CONTROL

- A. Perform necessary subsurface investigation to identify water bearing layers, piezometric pressures and soil parameters for design and installation of ground water control systems. Perform pump tests, if necessary to determine draw down characteristics. Present results in the Ground Water and Surface Water Control Plan. submittal
- B. Provide labor, material, equipment, techniques and methods to lower, control and handle ground water in manner compatible with construction methods and site conditions. Monitor effectiveness of installed system and its effect on adjacent property.
- C. Install, operate, and maintain ground water control systems in accordance with the Ground Water and Surface Water Control Plan. Notify Project Manager in writing of changes made to accommodate field conditions and changes to Work. Provide revised drawings and calculations with notification.
- D. Provide continuous system operation, including nights, weekends, and holidays. Arrange appropriate backup if electrical power is primary energy source for dewatering system.
- E. Monitor operations to verify systems lower ground water piezometric levels at rate required to maintain dry excavation resulting in stable subgrade for subsequent construction operations.
- F. Depressurize zones where hydrostatic pressures in confined water bearing layers exist below excavations to eliminate risk of uplift or other instability of excavation or installed works. Define allowable piezometric elevations in the Ground Water and Surface Water Control Plan.
- G. Removal of ground water control installations.
 - 1. Remove pumping system components and piping when ground water control is no longer required.
 - 2. Remove piezometers, including piezometers installed during design phase investigations and left for Contractor's use, upon completion of testing, as required in accordance with Part 3 of applicable specification.
 - 3. Remove monitoring wells when directed by Project Manager.
 - 4. Grout abandoned well and piezometer holes. Fill piping that is not removed with cement-bentonite grout or cement-sand grout.

- H. During backfilling, maintain water level a minimum of 5 feet below prevailing level of backfill. Do not allow the water level to cause uplift pressures in excess of 80 percent of downward pressure produced by weight of structure or backfill in place. Do not allow water levels to rise into cement-stabilized sand until at least 48 hour after placement.
- I. Provide uniform pipe diameter for each pipe drain run constructed for dewatering. Remove pipe drains when no longer required. If pipe removal is impractical, grout connections at 50-foot intervals and fill pipe with cement- bentonite grout or cement-sand grout after removal from service.
- J. The extent of ground water control for structures with permanent perforated underground drainage systems may be reduced, for units designed to withstand hydrostatic uplift pressure. Provide a means to drain affected portions of underground systems, including standby equipment. Maintain drainage systems during construction operations.
- K. Remove systems upon completion of construction or when dewatering and control of surface or ground water is no longer required.
- L. Compact backfill to not less than 95 percent of maximum dry density in accordance with ASTM D 698.
- M. Foundation Slab: Maintain saturation line at least 3 feet below lowest elevations where concrete is to be placed. Drain foundations in areas where concrete is to be placed before placing reinforcing steel. Keep free from water for 3 days after concrete is placed.

3.02 REQUIREMENTS FOR EDUCTOR, WELL POINTS, OR DEEP WELLS

- A. For aboveground piping in ground water control system, include a 12-inch minimum length of clear, transparent piping between each eductor well or well point and discharge header to allow visual monitoring of discharge from each installation.
- B. Install sufficient piezometers or monitoring wells to show that trench or shaft excavations in water bearing materials are pre-drained prior to excavation. Provide separate piezometers for monitoring of dewatering and for monitoring of depressurization. Install piezometers and monitoring wells for tunneling as appropriate for selected method of work.
- C. Install piezometers or monitoring wells at least one week in advance of the start of associated excavation.
- D. Dewatering may be omitted for portions of under drains or other excavations, where auger borings and piezometers or monitoring wells show that soil is pre-drained by existing systems and that ground water control plan criteria are satisfied.
- E. Replace installations that produce noticeable amounts of sediments after development.

- F. Provide additional ground water control installations, or change method of control if, ground water control plan does not provide satisfactory results based on performance criteria defined by plan and by specifications. Submit revised plan according to Paragraph 1.07.B.

3.03 SEDIMENT TRAPS

- A. Install sediment tank as shown on approved plan.
- B. Inspect daily and clean out tank when one-third of sediment tank is filled with sediment.

3.04 SEDIMENT SUMP PIT

- A. Install sediment sump pits as shown on approved plan.
- B. Construct standpipe by perforating 12 inch to 24-inch diameter corrugated metal or PVC pipe.
- C. Extend standpipe 12 inches to 18 inches above lip of pit.
- D. Convey discharge of water pumped from standpipe to sediment trapping device.
- E. Fill sites of sump pits, compact to density of surrounding soil and stabilize surface when construction is complete.

3.05 EXCAVATION DRAINAGE

- A. Use excavation drainage methods if well-drained conditions can be achieved. Excavation drainage may consist of layers of crushed stone and filter fabric, and sump pumping, in combination with sufficient ground water control wells to maintain stable excavation and backfill conditions.

3.06 MAINTENANCE AND OBSERVATION

- A. Conduct daily maintenance and observation of piezometers or monitoring wells while ground water control installations or excavation drainage is operating at the site, or water is seeping into tunnels, and maintain systems in good operating condition.
- B. Replace damaged and destroyed piezometers or monitoring wells with new piezometers or wells as necessary to meet observation schedules.
- C. Cut off piezometers or monitoring wells in excavation areas where piping is exposed, only as necessary to perform observation as excavation proceeds. Continue to maintain and make specified observations
- D. Remove and grout piezometers inside or outside of excavation area when ground water control operations are complete. Remove and grout monitoring wells when directed by Project Manager.

3.07 MONITORING AND RECORDING

- A. Monitor and record average flow rate of operation for each deep well, or for each wellpoint or eductor header used in dewatering system. Also, monitor and record water level and ground water recovery. Record observations daily until steady conditions are achieved and twice weekly thereafter.
- B. Observe and record elevation of water level daily as long as ground water control system is in operation, and weekly thereafter until Work is completed or piezometers or wells are removed, except when Project Manager determines more frequent monitoring and recording are required. Comply with Project Manager's direction for increased monitoring and recording and take measures necessary to ensure effective dewatering for intended purpose.

3.08 SURFACE WATER CONTROL

- A. Intercept surface water and divert it away from excavations through use of dikes, ditches, curb walls, pipes, sumps or other approved means. Requirement includes temporary works required to protect adjoining properties from surface drainage caused by construction operations.
- B. Divert surface water and seepage water into sumps and pump it into drainage channels or storm drains, when approved by agencies having jurisdiction. Provide settling basins when required by agencies.

END OF SECTION

SECTION 01580

PROJECT IDENTIFICATION SIGNS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project identification sign description.
- B. Project sign installation.
- C. Maintenance and removal of Project sign.

1.02 RELATED SECTIONS

- A. Section 01330 – Submittal Procedures
- B. Section 01580 – Project Identification Signs

1.03 SYSTEM DESCRIPTION

- A. Sign Construction: Construct signs of new materials in accordance with Standard Detail provided at the Pre-construction Conference.
- B. Appearance: Maintain signs to present a clean and neat look throughout contract duration.
- C. Sign Manufacturer: Experienced professional sign company.
- D. Sign Placement: At locations shown in Drawings unless otherwise specified by Project Manager at pre-construction meeting.
 - 1. Provide one sign at each end of a linear Project involving paving, overlay, sewer line, storm drainage, or water main construction located in rights-of-ways.
 - 2. Provide one sign for site or building construction Contracts.
 - 3. Provide one sign at each site for Contracts with multiple sites.
 - 4. Sign Relocation: As work progresses, relocate signs if directed by Project Manager in writing. Include cost for one relocation of post-mounted signs in Contract Price. Subsequent relocations, if directed by Project Manager in writing, will be subject to Change Order.

- E. Skid-mounted signs: Use for projects with noncontiguous locations where work progresses from one location to another. Design skid structure to withstand a 60 mile-per-hour wind load to the face or back of sign using stakes, straps, or ballast. Contractor shall be responsible for security of signs at each site.

1.04 SUBMITTALS

- A. Submit Shop Drawings under provisions of Section 01330 - Submittal procedures.
- B. Show content, layout, lettering style, lettering size, and colors. Make sign and lettering to scale, clearly indicating condensed lettering, if used.

PART 2 PRODUCTS

2.01 SIGN MATERIALS

- A. Structure and Framing: Use new sign materials.
 - 1. Sign Posts: 4-inch by 4-inch pressure treated wood posts, 9 feet long for skid mounting and 12 feet long minimum for in-ground mounting.
 - 2. Skid Bracing: 2-inch by 4-inch wood framing material.
 - 3. Skid Members: 2-inch by 6-inch wood framing material.
 - 4. Fasteners:
 - a. Galvanized steel.
 - b. Attach sign to posts with 1/2-inch by 5-1/2 inch button head carriage bolts and secure with nuts and flat head washers.
 - c. Cover button heads with white reflective film or paint to match sign background.
 - d. Use metal brackets and braces and 3/4-inch wood screws to attach sign header.
- B. Sign and Sign Header: 3/4-inch thick marine plywood. Use 4-foot by 8-foot sheet for the sign and a single piece for the header to minimize joints. Do not piece wood sheets to fabricate sign face.
- C. Paint and Primers: White industrial grade, fast-drying, oil-based paint with gloss finish for structural and framing members, sign, and sign header material surfaces. Paint all sign surfaces prior to adding adhesive applications.
- D. Colors:

1. Sign Background: Reflective white 3M Scotchlite Engineer Grade, Pressure Sensitive Sheeting (White), or approved equal.
2. Border: For red border around area, which designates project name and project amount, use reflective red 3M Scotchlite Engineer Grade, Pressure Sensitive Sheeting (Red), or approved equal.
3. Sign Film: 3M Scotchcal Pressure Sensitive Films, or approved equal for legends, symbols, lettering, and artwork. Match colors to 3M Scotchcal Pressure Sensitive Films.
 - a. Lettering Below Seal: Black
 - b. Lettering Above Project Name: Vivid Blue
 - c. Lettering on Blue Background: White
 - d. Background Behind Project Name: Vivid Blue
- E. City Seal: Project Manager will provide City seals to Contractor, as needed.

2.02 SIGN LAYOUT

- A. Lettering:
 1. Style, Size, and Spacing: Helvetica Regular lettering.
 2. Condensed Style: Text may be condensed if needed to maintain sign composition.
- B. Composition:
 1. Lines with Standard Text
 - a. Top line shall read “BUILDING TOGETHER FOR THE FUTURE”.
 - b. Use lower left below City Seal to list names and titles for Mayor, Controller and Council Members. Place as shown on Drawings with indicated size and spacing.
 - c. Center telephone number of the Customer Response Center, “311”, near the bottom of the area with the blue background.
 2. Lines with Variable Text. Use blue background space for Project name and dollar amount.
 - a. Project Manager will provide Project name and dollar amount of Project for preparation of sign. Center name on one or two lines, and dollar amount immediately below Project name, in area with blue background. Use condensed lettering if necessary.

2.03 LAYOUT AND COMPOSITION FOR HEADER

A. City of Houston Seal:

1. A space of approximately 24 inches in diameter is provided for the City seal, the top 6 inches of which extends above the sign on the sign header.
2. Construct sign header of same material as sign face. Cut material to match curve of the City seal.
3. Project Manager will provide the seal to be affixed to the sign by sign maker.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install Project identification signs within seven days after Date of Commencement of the Work.
- B. Erect signs at locations shown in Drawings unless otherwise designated by Project Manager at pre-construction meeting. Position sign so it is fully visible and readable to general public.
- C. Erect sign level and plumb.
- D. If mounted on posts, sink posts 3 to 4 feet below grade and stabilize posts to minimize lateral motion. Leave a minimum of 8 feet of post above existing grade for mounting of sign.
- E. Erect sign so that top edge of sign is at a nominal 8 feet above existing grade.

3.02 MAINTENANCE AND REMOVAL

- A. Keep signs and supports clean. Repair deterioration and damage.
- B. Remove signs, framing, supports, and foundations to a depth of at least 2 feet upon completion of Project. Restore area to a condition equal to or better than before construction.

PROJECT No.: (FILE NO:)	CONTRACT No.:	REVIEWED BY:
-----------------------------	---------------	--------------

*INSTRUCTIONS TO SIGN MAKER (LIST COMPANY NAME):	
QTY.	ACTION ITEMS:
	Make new sign(s)
	Follow City standards attached
	Provide submittal (drawing) to the City for project sign showing content, layout, lettering style, lettering size, and colors
VARIABLE TEXT	
Line 1	Project Name:
Line 2	Project Amount (rounded to nearest \$1000):
ATTACHMENTS INCLUDED	
QTY.	SEALS / LOGOS
	City of Houston - 24" diameter
	STANDARDS
	Standard Specification Section 01580 - Project Identification Signs
	Standard Detail 01580-01 Construction Sign

(Instructions on reverse.)

INSTRUCTIONS

Contractor produces this form. Contractor shall insert the information and provide the form to the sign maker with Contractor's purchase order.

List PROJECT No., (FILE No.), CONTRACT No., and name of City's Project Manager REVIEWED BY.

INSTRUCTIONS TO SIGN MAKER:

- Give COMPANY NAME of sign maker.
- Indicate QUANTITY of new signs to be made.
- Direction for sign maker to follow City Standards in making signs.
- Require submittals from sign maker, who provides Shop Drawing of Project sign showing content, layout, lettering style, lettering size, and colors.

VARIABLE TEXT:

- Give PROJECT NAME. Write it out in all caps and suggest line break. Lines are required.
- Give Project amount to be listed on sign. Round off to nearest \$1000.

ATTACHMENTS INCLUDED:

- Seals

City provides the quantity of City seals required one for each Project sign.

- Standards

Contractor provides set of Standards to sign maker, including (Specification Section 01580 - Project Identification Signs, and Standard Detail No. 01580-01 - Construction Sign.

END OF SECTION

SECTION 01581

EXCAVATION IN PUBLIC WAY PERMIT SIGNS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project sign installation.
- B. Maintenance and removal of Project sign.

1.02 RELATED SECTIONS

- A. Section 01330 – Submittal Procedures

1.03 SYSTEM DESCRIPTION

- A. Sign Construction: Construct signs of new materials.
- B. Appearance: Maintain signs to present a clean and neat look throughout the Contract duration.
- C. Sign Placement: Place signs at each street entrance to street cut excavation.

1.04 REFERENCES

- A. Texas Manual on Uniform Traffic Control Devices, current edition

1.05 SUBMITTALS

- A. Submit Shop Drawings under provisions of Section 01330 - Submittal Procedures.
- B. Show content, layout, lettering style, lettering size and colors. Make sign and lettering to scale, clearly indicating condensed lettering, if used.

PART 2 PRODUCTS

2.01 SIGN LAYOUT

- A. Conform to Texas Manual on Uniform Traffic Control Devices. Minimum size: 36 inches by 36 inches.
- B. Lettering: Uppercase Helvetica Regular lettering.

- C. Composition: Include on sign copy of street cut permit, title “City of Houston”, contracting department’s name, address, and emergency telephone number and Contractor’s name. Project Manager will provide department name, address, and emergency telephone number for preparation of sign.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install Project signs before commencement of pavement excavation in Public Way.
- B. Position sign so it is fully visible and readable to general public.
- C. Erect sign level and plumb.
- D. Erect sign so that top edge of sign is at a nominal 8 feet above existing grade.

3.02 MAINTENANCE AND REMOVAL

- A. Keep signs and supports clean. Repair deterioration and damage.
- B. Remove signs, framing, supports and foundations to depth of at least 2 feet upon completion of the Work. Restore area to condition equal to or better than before construction.

END OF SECTION

SECTION 01582

BUILD HOUSTON FORWARD PROJECT IDENTIFICATION SIGNS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project identification sign description.
- B. Project sign installation.
- C. Maintenance and removal of Project sign.

1.02 RELATED SECTIONS

- A. Section 01270 – Measurement and Payment
- B. Section 01330 – Submittal Procedures

1.03 REFERENCES

- A. ASTM A 536 – Standard Specification for Ductile Iron Castings
- B. ASTM A 653 – Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process
- C. ASTM A 1011 - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength

1.04 DELIVERY AND HANDLING

- A. Contractor to procure, furnish, and install signs at locations dictated in the Drawings unless otherwise specified by Project Manager at pre-construction meeting.

1.05 SUBMITTALS

- A. Submit Shop Drawings under provisions of Section 01330 - Submittal Procedures.
- B. The shop drawing should include size of the proposed aluminum sign plate and the signpost detail applicable for the project.

1.06 MEASUREMENT AND PAYMENT

- A. Payment for this item will be measured by each “Build Houston Forward Identification Sign” installed and maintained at the project site.

- B. Payment for the work performed and material furnished in accordance with this item will be paid for “Build Houston Forward Identification Sign” of the size specified. The price is full compensation for furnishing, installing and maintaining new signs and removal at the end of the project. Cost of associated aluminum plate, posts, footings, and miscellaneous mounting hardware will not be paid for directly but is to be included in the unit price bid for installation of each Build Houston Forward project identification sign. Contractor to replace lost, missing, stolen, or the equivalent “Build Houston Forward Project Identification Signs” with no further compensation.
- C. Refer to Section 01270 – Measurement and Payment for unit price procedures.

PART 2 PRODUCTS

2.01 SIGN MATERIALS

- A. Structure and Framing: Use new sign materials.
 - 1. Signposts / Tubing:
 - a. Steel post shall conform to the standard specification for hot rolled carbon sheet steel, structural quality, ASTM designation A1011, Grade 50. Average minimum yield strength after cold forming is 60,000 psi. The cross section of the post shall be square tube formed steel, carefully rolled to size and shall be welded directly in the corner by high frequency resistance welding or equivalent process and externally scarified to agree with corner radii. Signposts shall be hot dipped galvanized conforming to ASTM A653, G90.
 - b. 24-inch sign: 1 ¾-inch by 1 ¾-inch galvanized square perforated signposts minimum length:
 - (1) Concrete Footing – 140-inch-long post
 - (2) Skid Mounting – 104-inch-long post
 - (3) Pile Driven – 154-inch-long post
 - (4) Surface Mounting – 106-inch-long post
 - c. 48-inch sign: 1 ¾-inch by 1 ¾-inch galvanized square perforated signposts minimum length:
 - (1) Concrete Footing – 125-inch-long post
 - (2) Skid Mounting – 89-inch-long post
 - (3) Pile Driven – 139-inch-long post

(4) Surface Mounting – 91-inch-long post

2. Skid Mounted Signs:

- a. Use for projects with noncontiguous locations where work progresses from one location to another.
- b. Secure skid structure to withstand a 60 mile-per-hour wind load to the face or back of sign using stakes, straps, or ballast. Contractor shall be responsible for security of signs at each site.
- c. Where sign supports require the use of weights to keep from turning over, the use of sandbags with dry, cohesionless sand should be used.
- d. The sandbags shall be tied shut to keep the sand from spilling and to maintain a constant weight.
- e. Rock, concrete, iron, steel, or other solid objects shall not be permitted for use as sign support weights.
- f. Sandbags should weigh a minimum of 35 lbs. and a maximum of 50 lbs.
- g. Sandbags shall be made of a durable material that tears upon vehicular impact. Rubber (such as tire inner tubes) shall NOT be used.
- h. Sandbags shall only be placed along or laid over the base supports of the traffic control device and shall not be suspended above ground level or hung with rope, wire, chains or other fasteners. Sandbags shall be placed along the length of the skids to weigh down the sign support.
- i. Sandbags shall NOT be placed under the skid and shall not be used to level sign supports placed on slopes.

3. Fasteners:

- a. Galvanized steel.
- b. Attach sign to posts with 5/16-inch by 3-inch hex head bolts and secure with hex nylon locknut and split lock washers.
- c. Bolts to connect perforated metal tubes shall be 3/8-inch by 3-inch grade 8.
- d. Bolts to connect square perforated tubing cross brace on 48-inch sign shall be 3/8-inch by 4 ½-inch grade 8 bolt.
- e. Cover hex heads with white reflective film or paint to match sign background.

2.02 FABRICATION

- A. Sign Construction: Construct signs of new materials in accordance with Standard Detail provided at the Pre-construction Conference.
- B. City of Houston Project Manager will submit the Sign Intake Form to Build Houston Forward Sign Coordinator 21 days before project Commencement.
- C. Build Houston Forward Sign Coordinator will provide content, layout, lettering style, lettering size, and colors for fabrication. The Sign Coordinator provides abbreviated project name, convert Construction Start and Completion Dates, produce QR-Code for the sign, and send completed form to the Project Manager.
- D. The Contractor shall procure, furnish aluminum plate, prepare the sign with approved project sign information, and install the sign per approved sign submittal.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install Project identification signs within seven days after Date of Commencement of the Work.
- B. Sign Placement: Erect signs at locations shown in Drawings unless otherwise designated by Project Manager at pre-construction meeting. Position sign so it is fully visible and readable to the general public.
 - 1. Provide one sign at each end of a linear Project involving paving, overlay, sewer line, storm drainage, or water main construction located in rights-of-ways.
 - 2. Provide one sign for site or building construction Contracts.
 - 3. Provide one sign at each site for Contracts with multiple sites.
 - 4. Sign Relocation: As work progresses, relocate signs if directed by Project Manager in writing. Include cost for one relocation of post-mounted signs in Contract Price. Subsequent relocations, if directed by Project Manager in writing, will be subject to Change Order.
- C. Erect sign level and plumb.
- D. The square end of the post shall not be modified or pointed.

- E. When signpost installation is required over building basements, bridges and cavities, an ASTM A-536 Grade 65-45-12 Ductile Iron surface mounting sign base shall be used. The base shall be connected to the surface with four 0.56-inch diameter holes and 8-inch by ½-inch screws. The neck of the flange shall have inside dimensions of 2.06-inch by 2.06-inch with a thickness of 0.75-inch and be connected to the signpost with hex nylon insert locknuts (NE), Grade 8, yellow zinc plated.
- F. For concrete footing installations:
 - 1. Anchors shall be anchored in a minimum of one cubic foot of class “C” concrete, 34 inches deep, with a 6 inch long, ¾ inch diameter pin inserted through the pre-drilled hole 3 inches from the bottom of the square anchor stub.
 - 2. If mounted on posts in concrete footings stabilize posts to minimize lateral motion.
 - 3. Leave a minimum of 9 feet of post above existing grade for mounting of 24-inch sign, and 8 feet of post above existing grade for mounting 48-inch sign.
- G. Where the pole installation requires surface mounting, an ASTM A-536 Grade 65-45-12 Ductile Iron surface mounting sign base shall be used. The base shall be connected to the surface with four 0.56-inch diameter holes and 8-inch by ½-inch screws. The neck of the flange shall have inside dimensions of 2.06-inch by 2.06-inch with a thickness of 0.75-inch and be connected to the signpost with hex nylon insert locknuts (NE), Grade 8, yellow zinc plated.
- H. If mounted on posts and pile driven, set posts a minimum of 4-feet below grade and stabilize posts to minimize lateral motion.
- I. If mounted on skid mounts:
 - 1. 24-inch sign – install post into tee section and secure with nut and bolt assembly. Install tee section into base of tee section and secure with nut and bolt assembly.
 - 2. 48-inch sign – install both posts into tee sections and secure with nut and bolt assembly.

3.02 MAINTENANCE AND REMOVAL

- A. Keep signs and supports clean and neat looking throughout contract duration. Repair deterioration and damage.
- B. Completely remove signs, framing, supports, and foundations upon completion of Project. Restore area to a condition equal to or better than before construction.

END OF SECTION

SECTION 01610

BASIC PRODUCT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Requirements for transportation, delivery, handling, and storage of Products.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions

1.03 PRODUCTS

- A. Products: Defined in Document 00700 – General Conditions. Does not include machinery and equipment used for preparation, fabrication, conveying and erection of the Work. Products may also include existing materials or components designated for reuse.
- B. For material and equipment specifically indicated or specified to be reused in the work:
 - 1. Use special care in removal, handling, storage and reinstallation, to assure proper function in completed work.
 - 2. Arrange for transportation, storage and handling of products which require off-site storage, restoration or renovation. Include cost in unit price for related items.
- C. When contract documents require that installation of work comply with manufacturer's printed Instructions, obtain and distribute copies of such instructions to parties involved in installation, including two copies to Project Manager. Maintain one set of complete instructions at job site during installation until completion.
- D. Provide Products from the fewest number of manufacturers as practical, in order to simplify spare parts inventory and to allow for maximum interchangeability of components. For multiple components of the same size, type or application, use the same make and model of component throughout the Work.

1.04 TRANSPORTATION

- A. Make arrangements for transportation, delivery, and handling of Products required for timely completion of the Work.
- B. Transport and handle Products in accordance with manufacturer's instructions.

- C. Consign and address shipping documents to proper party giving name of the Project and its complete street address. Shipments shall be delivered to Contractor.

1.05 DELIVERY

- A. Arrange deliveries of Products to accommodate short-term site completion schedules and in ample time to facilitate inspection prior to Installation. Avoid deliveries that cause lengthy storage or overburden of limit storage space.
- B. Coordinate deliveries to avoid conflict with the Work and conditions at the site and to accommodate the following:
 - 1. Work of other contractors or the City.
 - 2. Limitations of storage space.
 - 3. Availability of equipment and personnel for handling Products.
 - 4. The City's use of premises.
- C. Have Products delivered to the site in manufacturer's original, unopened, labeled containers.
- D. Immediately upon delivery, inspect shipment to assure:
 - 1. Product complies with requirements of the Contract.
 - 2. Quantities are correct.
 - 3. Containers and packages are intact; labels are legible.
 - 4. Products are properly protected and undamaged.

1.06 PRODUCT HANDLING

- A. Coordinate off-loading of Products delivered to the site. If necessary during construction, move and relocate stored Products at no additional cost to the City.
- B. Provide equipment and personnel necessary to handle Products, including those provided by the City, by methods to prevent damage to Products or packaging.
- C. Provide additional protection during handling as necessary to prevent breaking, scraping, marring, or otherwise damaging Products or surrounding areas.
- D. Handle Products by methods to prevent over-bending or overstressing.
- E. Lift heavy components only at designated lifting points.
- F. Handle Products in accordance with manufacturer's recommendations.

- G. Do not drop, roll, or skid Products off delivery vehicles. Hand-carry or use Suitable materials handling equipment.

1.07 STORAGE OF PRODUCTS

- A. Store and protect Products in accordance with manufacturer's recommendations and requirements of these Specifications.
- B. Make necessary provisions for safe storage of Products. Place Products so as to prevent damage to any part of the Work or existing facilities and to maintain free access at all times to all parts of the Work and to utility service company installations in the vicinity of the Work. Keep Products neatly and compactly stored in locations that will cause minimum inconvenience to other contractors, public travel, adjoining owners, tenants, and occupants. Arrange storage in a manner so as to provide easy access for inspection.
- C. Restrict storage to areas available on the site for storage of Products as shown on Drawings or approved by Project Manager.
- D. Provide off-site storage and protection when on-site storage is not adequate. Provide addresses of, and access to, off-site storage locations for inspection by Project Manager.
- E. Do not use lawns, grass plots, or other private property for storage purposes without written permission of owner or other person in possession or control of premises.
- F. Protect stored Products against loss or damage.
- G. Store in manufacturers' unopened containers.
- H. Neatly, safely, and compactly stack Products delivered and stored along the line of the Work to avoid inconvenience and damage to property owners and general public, and maintain at least 3 feet clearance around fire hydrants. Keep public, private driveways and street crossings open.
- I. Repair or replace damaged lawns, sidewalks, streets or other improvements to satisfaction of Project Manager. Total length that Products may be distributed along route of construction at one time is 1000 linear feet, unless otherwise approved in writing by Project Manager.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01630

PRODUCT SUBSTITUTION PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Options for making Product or process selections.
- B. Procedures for proposing equivalent Products or processes, including pre-approved, pre-qualified, and approved Products or processes.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01330 – Submittal Procedures

1.03 DEFINITIONS

- A. Product: As defined in Document 00700 – General Conditions. Product does not include machinery and equipment used for production, fabrication, conveying, and erection of the Work. Products may also include existing materials or components designated for reuse.
- B. Process: Any proprietary system or method for installing system components resulting in an integral, functioning part of the Work. For this Section, the word Products includes Processes.

1.04 SELECTION OPTIONS

- A. Pre-approved Products: Construction products of certain manufacturers or Suppliers designated in Specifications as "pre-approved." The City maintains a list of pre-approved products. Pre-approved Products for this Project are designated as pre-approved in Specifications. Products of other manufacturers or suppliers are not acceptable for this Project and will not be considered under the submittal process for approving alternate products.
- B. Pre-qualified Products: Construction products of certain manufacturers or Suppliers designated in Specifications as "pre-qualified." Pre-qualified Products for this Project are designated as pre-qualified in Specifications. Products of other manufacturers or suppliers are not acceptable for this Project and will not be considered under the submittal process for approving alternate products.

- C. Approved Products: Construction products of certain manufacturers or Suppliers designated in Specifications followed by words "or approved equal." Approval of alternate products not listed in Specifications may be obtained through provisions for product options and substitutions in Document 00700 • General Conditions, and by following submittal procedures specified in Section 01330- Submittal Procedures. The procedure for approval of alternate products is not applicable to pre-approved or pre-qualified products.
- D. Product Compatibility: To the maximum extent possible, provide Products that are of the same type or function from a single manufacturer, make, or source. Where more than one choice is available, select Product that is compatible with other Products already selected, specified, or in use by the City.

1.05 CONTRACTOR'S RESPONSIBILITY

- A. Responsibility related to Product options and substitutions is defined in Document 00700 - General Conditions.
- B. Furnish information Project Manager deems necessary to judge equivalency of alternate Product.
- C. Pay for laboratory testing, as well as any other review or examination costs, needed to establish equivalency between products in order to obtain information upon which Project Manager can base a decision.
- D. If Project Manager determines alternate product is not equal to that named in Specifications, Furnish one of the specified Products.

1.06 CITY REVIEW

- A. Use alternate Products only when approved in writing by Project Manager. Project Manager's determination regarding acceptance of proposed alternate Product is final.
- B. Alternate Products shall be accepted if Products are judged by Project Manager to be equivalent to specified Product or to offer substantial benefit to the City.
- C. The City retains the right to accept any Product deemed advantageous to the City, and similarly, to reject any product deemed not beneficial to City.

1.07 SUBSTITUTION PROCEDURE

- A. Collect and assemble technical information applicable to the proposed Product to aid in determining equivalency as related to the approved Product specified.
- B. Submit a written request for a construction Product to be considered as an alternate Product.

- C. Submit Product information after the effective date of the Contract and within the time period allowed for substitution submittals given in Document 00700 - General Conditions. After the submittal period has expired, requests for alternate Products shall be considered only when specified Product becomes unavailable because of conditions beyond Contractor's control.
- D. Submit five copies of each request for alternate Product approval. Include the following information:
 - 1. Complete data substantiating compliance of proposed substitution with the Contract.
 - 2. For Products:
 - a. Product identification, including manufacturer's name and address.
 - b. Manufacturer's literature with Product description, performance and test data, and reference standards.
 - c. Samples, as applicable.
 - d. Name and address of similar projects on which Product was used and date of installation. Include names of Owner, design consultant, and installing contractor.
 - 3. For construction methods:
 - a. Detailed description of proposed method.
 - b. Drawings illustrating methods.
 - 4. Itemized comparison of proposed substitution with Product or method specified.
 - 5. Data relating to changes in Construction Schedule.
 - 6. Relation to separate contracts, if any.
 - 7. Accurate cost data on proposed substitution in comparison with Product or method specified.
 - 8. Other information requested by Project Manager.
- E. Approved alternate Products will be subject to the same review process as the specified Product would have been for Shop Drawings, Product Data, and Samples.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01725

FIELD SURVEYING

PART 1 GENERAL

1.01 QUALITY CONTROL

- A. Conform to State of Texas laws for surveys requiring Registered Professional Land Surveyors (RPLS). Employ a RPLS acceptable to Project Manager if required by the Contract.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01330 – Submittal Procedures
- C. Section 01785 – Project Record Documents

1.03 MEASUREMENT AND PAYMENT

- A. Unit Prices
 - 1. No separate payment will be made for field surveying. Include cost in unit price for related items.

1.04 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. Submit name, address, and telephone number of RPLS to Project Manager before starting survey work.
- C. Submit documentation verifying accuracy of survey work on request.
- D. Submit certificate signed by RPLS, that elevations and locations of the Work are in conformance with the Contract.

1.05 PROJECT RECORD DOCUMENTS

- A. Maintain a complete and accurate log of control and survey work as it progresses.
- B. Prepare a certified survey setting forth dimensions, locations, angles, and elevations of construction and site work upon completion of foundation walls and major site improvements.
- C. Submit record documents under provisions of Section 01785 - Project Record Documents.

1.06 EXAMINATION

- A. Verify locations of survey control points prior to starting the Work.
- B. Notify Project Manager immediately if any discrepancies are discovered.

1.07 SURVEY REFERENCE POINTS

- A. The City will establish survey control datum as provided in Document 00700 - General Conditions and as indicated on Drawings. Inform Project Manager 14 days in advance of recovery of horizontal and vertical control points.
- B. Locate and protect survey control points prior to starting site work; preserve permanent reference points during construction.
- C. Notify Project Manager a minimum of 48 hours before relocation of reference points is needed due to changes in grades or other reasons.
- D. Promptly report loss or destruction of reference points to Project Manager.
- E. Reimburse the City for cost of reestablishment of permanent reference points disturbed by construction operations.

1.08 SURVEY REQUIREMENTS

- A. Utilize recognized engineering survey practices.
- B. Establish a minimum of two permanent benchmarks on site, referenced to established control points. Record horizontal and vertical location data on Project record documents.
- C. Establish elevations, lines and levels to provide quantities required for measurement and payment and for appropriate controls for the Work. Locate and lay out the following with appropriate instruments:
 - 1. Site improvements including grading, fill and topsoil placement, utilities, and footings and slabs
 - 2. Grid or axis for structures
 - 3. Building foundation, column locations, and ground floor elevations
- D. Periodically verify layouts.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01731

CUTTING AND PATCHING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Cutting, patching and fitting of the Work or work under construction. Coordinating Installation or connection of the Work to existing facilities, or uncovering work for access, inspection or testing and related submittals.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Section 01330 – Submittal Procedures

1.03 MEASUREMENT AND PAYMENT

- A. Unit Prices
 - 1. No separate payment will be made for cutting and patching. Include cost in unit price for related items.

1.04 CUTTING AND PATCHING

- A. Perform activities to avoid interference with facility operations and work of others in accordance with Document 00700 - General Conditions of Contract.
- B. Execute cutting and patching, including excavation, backfill and fitting to:
 - 1. Remove and replace defective work or work not conforming to Drawings and Specifications;
 - 2. Take samples of installed work as required for testing;
 - 3. Remove construction required to provide for specified alterations or additions to existing work;
 - 4. Uncover work to allow inspection or reinspection by Project Manager or regulatory agencies having jurisdiction;
 - 5. Connect uninstalled work to completed work in proper sequence;
 - 6. Remove or relocate existing utilities and pipes that obstruct work;
 - 7. Make connections or alterations to existing or new facilities;

8. Provide openings, channels, chases and flues and cut, patch, and finish; if required; or
 9. Provide protection for other portions of the Work.
- C. Restore existing work to a condition equal to or better than that which existed prior to cutting and patching, and to standards required by Specifications.
 - D. Support, anchor, attach, match, trim and seal materials to work of others. Unless otherwise specified, Furnish and Install sleeves, inserts, and hangers required for execution of the Work.
 - E. Provide shoring, bracing and support necessary to maintain structural integrity and to protect adjacent work from damage during cutting and patching. Request written approval from Project Manager, before cutting structural members such as beams, anchors, lintels, or other supports. Follow approved submittals, as applicable.
 - F. Match new materials to existing materials by bonding, lapping, mechanically tying, anchoring or other effective means in order to prevent cracks and to minimize evidence of patching. Conceal effects of demolition and patching by blending new construction to existing surfaces. Avoid obvious breaks, joints or changes of surface appearance unless shown on Drawings or authorized by Project Manager.

1.05 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. Submit a written request to Project Manager for consent to proceed, before conducting cutting operations that might affect structural integrity, design function, City operations, or work of another contractor.
- C. Include the following in submittal:
 1. Identification of Project
 2. Description of affected work
 3. Necessity for cutting
 4. Effect on other work and on structural integrity
 5. Describe the proposed work including:
 - a. Scope of cutting and patching
 - b. Contractor, Subcontractor or Supplier who will execute the work
 - c. Proposed Products
 - d. Extent of refinishing

- e. Schedule of operations
- 6. Alternatives to cutting and patching
- D. When work conditions or schedules dictate the need for change of materials or methods, submit a written recommendation to Project Manager that includes:
 - 1. conditions necessitating the change;
 - 2. recommendations for alternative materials or methods; and
 - 3. submittals required for proposed substitutions
- E. Notify Project Manager in writing when work will be uncovered for observation. Do not begin cutting or patching operations until authorized by Project Manager.

1.06 CONNECTIONS TO EXISTING FACILITIES

- A. Perform construction operations necessary to complete connections and tie-ins to existing facilities. Keep existing facilities in continuous operation unless otherwise permitted in the Specifications or approved in writing by Project Manager.
- B. Coordinate interruption of service requiring connection to existing facilities with Project Manager. Do not bypass wastewater or sludge to waterways. Provide temporary pumping facilities to handle wastewater if necessary. Use temporary bulkheads to minimize disruption. Provide temporary power and piping to facilitate construction where necessary.
- C. Submit a detailed schedule of proposed connections, including shut-down and tie-ins. Include proposed time and date as well as anticipated duration of work. Coordinate the connection schedule with the construction schedule.
 - 1. Submit specific times and dates to Project Manager at least 48 hours in advance of proposed work.
- D. Procedures and Operations:
 - 1. Operate existing pumps, valves and gates in required sequence under supervision of Project Manager. Do not operate valves, gates or other items of equipment without Project Manager's knowledge.
 - 2. If possible, test equipment under operating conditions before making final tie-ins to connect equipment to existing facility.
 - 3. Coordinate work and schedules. Notify Project Manger at least 48 Hours before shutdowns or bypasses are required.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01732

PROCEDURE FOR WATER VALVE ASSISTANCE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Operation of valves. City of Houston employees will operate existing valves. Contractor's employees may operate new valves included in the Project prior to acceptance by the City.

1.02 PROCEDURE

- A. Perform activities listed in Exhibit A attached to this Section.

1.03 SUBMITTALS

- A. Submit request for work order planning meetings in accordance with Exhibit A. Include information listed in Step 1 of Exhibit A, attached to this Section.

1.04 CANCELLATION

- A. Contractor, Project Manager, or Public Utilities Division may cancel a scheduled valve assistance appointment at no extra cost or payment to Contractor. Contractor shall notify City's appointed Project Inspector ("Inspector") 24 hours in advance of cancellation. Inspector shall notify Central Operation Service (COS) immediately upon receipt of cancellation notice. Cancellation may be caused by bad weather, preparation work taking longer than anticipated, or unforeseen delays by one or more of the three parties.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

PAGE LEFT INTENTIONALLY BLANK

EXHIBIT A

PROCEDURE FOR VALVE ASSISTANCE

The following procedure will be used by Utility Maintenance Branch personnel when completing a service request from individual Contractors, through Inspector, for operation of existing water valves.

ROUTINE VALVE ASSISTANCE REQUEST (NON-EMERGENCY JOBS):

- Step 1. a. When notified by Contractor, Inspector will schedule a work order planning meeting by calling Central Operation Service (COS) at (713) 295•5521 and providing information shown below. The work order planning meeting shall be conducted a minimum of three days after the request; excluding weekends, holidays, inclement weather days, and the day of the call.

Location of Work (Street Intersection)	Project #
Project Description	Contractor (Company Name)
Job Superintendent's Name	Superintendent's Office #/Mobile #/Pager #
Contractor's Emergency Information	Name and Phone #/Mobile #/Pager #
Inspector/Senior Inspector	Name, Phone #/Mobile #/Pager #
Date & Time assistance is requested	

- b. COS will create a work order for each wet connection, cut and plug, etc. that will be designated as a "Code 40" (Private Contractor).
- c. COS will give Inspector the work order number. This work order number must be used as a reference in all communications regarding this request for Valve Assistance.
- d. Valve personnel must have the work order number on their route sheet. When valve personnel arrive at the job site for the Work Order Planning Meeting between Inspector, Contractor, and Utility Maintenance valve personnel, they will verify the street intersection and work order number with the Inspector before beginning Work Order Planning Meeting.
- e. During Work Order Planning Meeting, the work to be performed will be outlined and the actual date work will be performed will be mutually determined by Inspector, Contractor and City's Utility Maintenance Division valve personnel, based upon relevant factors such as preparatory work needed, customer requirements, etc.
- f. Valve personnel will perform work specifically outlined in the work order requested. Also, Utility Maintenance Branch valve personnel will only operate existing water valves. Inspector must contact COS and request a new work order for additional work.

- g. Valve personnel will contact the dispatcher and advise when the job is complete. Valve personnel will list all appropriate information on the Crew Activity Report.
- Step 2. Should valve personnel not be able to keep an appointment to provide valve assistance, Utility Maintenance Branch will provide notification to appropriate Inspector by phone at least 24 hours prior, with that fact and rescheduling information, if available.
- Step 3. Inspector will notify COS if valve personnel have not arrived at the site within 30 minutes of scheduled appointment. If Contractor is not ready when valve operator arrives to provide valve assistance, the City shall charge Contractor \$50.00 per hour, starting 15 minutes after the scheduled appointment time, minimum one hour charge.
- Step 4. Contractor will not be due delay claims or downtime if Utility Maintenance Branch has notified Inspector that they will not be able to provide valve assistance as scheduled.
- Step 5. Test installed new valves in the presence of Inspector before substantial completion inspection is scheduled. Place new valves in open position on or before the Date of Substantial Completion.
- Step 6. Project Manager will notify, in writing, Utility Maintenance Branch two months before the warranty expires to report any problems they have with new water lines. Project Manager will notify Contractor about these problems.

EMERGENCY REQUEST FOR VALVE ASSISTANCE PROCEDURE:

Step 1. When notified by Contractor, Inspector will request emergency Valve Assistance due to a broken line/service, etc. by calling COS at (713) 295•5521 and providing the following information:

Location of Work (Street Intersection)	Project #
Project Description	Superintendent's Office #/Mobile #/Pager #
Contractor (Company Name)	Name and Phone #/Mobile #/Pager #
Job Superintendent's Name	Name, Phone #/Mobile #/Pager #
Contractor's Emergency Information	
Inspector/Senior Inspector	
Date & Time assistance is requested	

Step 2. COS will create an emergency work order number and describe the work to be performed.

Step 3. COS will give Inspector the emergency work order number. Reference work order number in all communications regarding request for Valve Assistance.

Step 4. COS will contact designated valve personnel and assign emergency work order. Dispatcher will follow standard COS procedures if this situation occurs after normal working hours.

Step 5. Valve personnel must have the emergency work order number on the route sheet. When valve personnel arrive at the job site for emergency work, they will verify the street intersection and emergency work order number with Inspector prior to beginning work requested for operating existing water valves. Valve personnel will coordinate verification of street intersection and work order number with Inspector prior to performing work.

SECTION 01740

SITE RESTORATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Restoration of site affected by the Work in public or private property, including pavement, esplanades, sidewalks, driveways, fences, lawns and landscaping.

1.02 RELATED SECTIONS

- A. Section 01110 – Summary of Work
- B. Section 01270 – Measurement and Payment
- C. Section 01330 – Submittal Procedures
- D. Section 01562 – Tree and Plant Protection
- E. Section 01576 – Waste Material Disposal
- F. Section 02514 – Disinfection of Water Lines
- G. Section 02921 – Hydro Mulch Seeding
- H. Section 02922 – Sodding
- I. Section 02951 – Pavement Repair and Restoration

1.03 MEASUREMENT AND PAYMENT

- A. Unit Prices.
 - 1. Payment for restoration of Project site disturbed by utility construction operations is on a linear foot basis. Measurement will be as provided for corresponding utility in each Specification section. No separate payment made for branch pipe, valves and, other associated work for utilities. Measurement for restoration with multiple utilities within the same right-of-way will be on a linear foot basis for only one utility.
 - 2. No separate payment made for facility or roadway projects. Include cost in the surface improvements associated with the facility or roadway construction.
 - 3. Payment includes required site restoration within the right-of-way or easement regardless of size or type of pipe, method of construction, paved or unpaved areas or thickness and width of pavement.

4. No separate payment made for site restoration for service connections under this Section. Include cost in appropriate utility section.
 5. Refer to Section 01270 – Measurement and Payment for Unit Price procedures.
- B. Stipulated Price (Lump Sum) Contracts. If Contract is Stipulated Price Contract, include payment for work under this section in total Stipulated Price.

1.04 DEFINITIONS

- A. Phase: Locations identified on the plans and listed in Section 01110 – Summary of Work under Work Sequence.
- B. Site Restoration: Replacement or reconstruction of Site Improvements located in rights-of-way, easements, public property, and private property affected or altered by the Work.
- C. Site Improvement: Includes pavement, curbs and gutters, esplanades, sidewalks, driveways, fences, lawns, irrigation systems, landscaping, and other improvements in existence at the Project site before commencement of construction operations.

1.05 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures.
- B. Schedule of testing, service connections, abandonment, backfill, and site restoration.
- C. Sample of notices to residents outlining their responsibility for maintenance of site improvements adjacent to the Project that are not disturbed by construction operations

1.06 SCHEDULING

- A. Schedule testing, service connections, abandonment, backfill and site restoration immediately following completion of pipe laying work or paving within each block or line segment.
- B. Phased Construction:
 1. Commencement of subsequent Phase will follow scheduling of site restoration of prior Phase. Limit work to a maximum of two Phases of the project.
- C. Construction of Projects with no Phases listed in Section 01110 - Summary of Work:
 1. Complete site restoration prior to disturbing over 50% of total project linear feet or 2,000 linear feet, whichever is greater, of right-of-way or easement.
 2. Limit work to a maximum of 50% of total project linear feet or 2,000 linear feet, whichever is greater, of right-of-way and easement. Commence work in additional right-of-way or easement after completion of site restoration.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Pavement, Sidewalks and Driveways: Materials specified in Section 02951 - Pavement Repair and Resurfacing.
- B. Seeding and Sodding: Sod specified in Section 02922 - Sodding and Seed specified in Section 02921 - Hydromulch Seeding.
- C. Trees, Shrubs and Plantings: Conform to requirements of Section 01562 – Tree and Plant Protection.

PART 3 EXECUTION

3.01 PREPARATORY WORK

- A. Provide cleanup and restoration crews to work closely behind pipe laying and roadway construction crews, and where necessary, during testing, service restoration, abandonment, backfill and surface restoration.
- B. Water Lines: Unless otherwise approved by Project Manager, comply with the following:
 - 1. Once Project Manager approves work within a Phase, immediately begin preparatory work for disinfection effort.
 - 2. No later than three days after completing disinfection preparatory work, submit to City appropriate request for disinfection.
 - 3. If City fails to perform initial disinfection of lines in accordance with Section 2514 - Disinfection of Water Lines, within seven days from submission of appropriate request, and if approved by Project Manager, pipe laying operations may continue beyond approved limits until the City responds.
 - 4. Immediately after transfer of services, begin abandonment of old water lines and site restoration.
- C. Wastewater Lines:
 - 1. Once Project Manager approves work within a Line Segment, immediately begin preparatory work for testing effort.
 - 2. No later than three days after completing preparatory work for testing, initiate testing work.

3. Immediately after transfer of service connections, begin abandonment of old wastewater lines, and site restoration.
- D. Street Construction and Paving Projects
1. Once Project Manager approves work within a Line Segment or block, immediately begin preparatory work for testing effort.
 2. No later than three days after completing preparatory work for testing, initiate testing work.
 3. Immediately after testing begin site restoration.
- E. Street Construction and Paving Projects
1. Once Project Manager approves work within a block, immediately begin preparatory work for sidewalk construction, sodding and hydromulching and tree planting.
 2. No later than seven days after completing preparatory work, initiate construction.
- 3.02 CLEANING
- A. Remove debris and trash to maintain a clean and orderly site in accordance with requirements of General Conditions and Section 01576 - Waste Material Disposal.
- 3.03 LANDSCAPING AND FENCES
- A. Seeding and Sodding.
1. Remove construction debris and level area with bank sand so that new grass surface matches level of existing grass and maintains pre• construction drainage patterns. Level and fill minor ruts or depressions caused by construction operations with bank sand, where grass is still viable.
 2. Restore previously existing turfed areas with sod and fertilize in accordance with Section 02922 - Sodding. Sod to match existing turf.
 3. Restore unpaved areas not requiring sodding with hydromulch seeding conforming to Section 02921 - Hydromulch Seeding.
- B. Trees, Shrubbery and Plants.
1. Remove and replant trees, shrubs, and plants in accordance with requirements of Section 01562 – Tree and Plant Protection.
- C. Fence Replacement.

1. Replace removed or damaged fencing to equal or better condition than existed prior to construction, including concrete footings and mow strips. Provide new wood posts, top and bottom railing and panels. Metal fencing material, not damaged by the Work, may be reused.
2. Remove and dispose of damaged or substandard material.

3.04 MAINTENANCE

- A. Maintain shrubs, plantings, sodded areas and seeded areas.
- B. Replace shrubs, plantings and seeded or sodded areas that fail to become established.
- C. Refer to Section 01562 - Tree and Plant Protection, Section 02921 - Hydromulch Seeding and Section 02922 - Sodding for maintenance requirements.

END OF SECTION

SECTION 01755

STARTING SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Starting systems.
- B. Demonstration and instructions.
- C. Testing, adjusting and balancing.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PREPARATION

- A. Coordinate schedule for start-up of various equipment and systems.
- B. Notify Project Manager seven days prior to startup of each item.
- C. Verify each piece of equipment or system has been checked for proper lubrication, drive rotation, belt tension, control sequence, or other damage-causing conditions.
- D. Verify tests, meter readings, and specified electrical characteristics agree with those required by equipment or system manufacturer.
- E. Verify wiring and support components for equipment are complete and tested.
- F. Execute start-up under supervision in accordance with manufacturer's instructions.
- G. When specified in individual Specification sections, require manufacturer to provide an authorized representative to be present at the site to inspect, check and approve equipment or system installation prior to start-up, and to supervise placing equipment or system in operation.
- H. Submit written report indicating that equipment or system has been properly installed and is functioning correctly.

3.02 DEMONSTRATION AND INSTRUCTIONS

- A. Demonstrate operation and maintenance of Products to Project Manager two weeks prior to Date of Substantial Completion.

- B. Utilize O&M Manuals as the basis for instruction. Review contents of manual with Project Manager in detail to explain aspects of operation and maintenance.
- C. Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, maintenance, and shutdown of each item of equipment at agreed- upon times, at the equipment location.
- D. Prepare and insert additional data in O&M Manuals when the need for additional data becomes apparent during instruction.
- E. At a minimum, Contractor will demonstrate the following:
 - 1. Products and procedures to be used in maintaining various surfaces, e.g., counter tops, toilet partitions, tile floors and carpeting;
 - 2. procedures to set and maintain landscape irrigation system;
 - 3. procedures to set and maintain security and fire alarm systems; and
 - 4. procedures to set and maintain HVAC systems.

3.03 TESTING, ADJUSTING AND BALANCING

- A. Contractor shall appoint, employ and pay for the services of an independent firm to perform testing, adjusting and balancing.
- B. Submit reports by the independent firm to Project Manager describing observations and results of tests and signifying compliance or non- compliance with specified requirements and requirements of the Contract.

END OF SECTION

SECTION 01770

CLOSEOUT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures to establish Date of Substantial Completion.
- B. Closeout procedures for final submittals, O&M data, warranties, spare parts and maintenance materials.
- C. Texas Department of Licensing and Regulation (TDLR) inspection for Texas Accessibility Standards (TAS) compliance.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions
- B. Document 01110 – Summary of Work
- C. Section 01292 – Schedule of Values
- D. Section 01330 – Submittal Procedures
- E. Section 01785 – Project Record Documents

1.03 SUBSTANTIAL COMPLETION

- A. Comply with Document 00700 - General Conditions regarding Date of Substantial Completion when Contractor considers the Work, or portion thereof designated by Project Manager, to be substantially complete.
- B. Insure the following items have been completed when included in the Work, prior to presenting a list of items to be inspected by Project Manager for issuance of a Certificate of Substantial Completion:
 - 1. cutting, plugging, and abandoning of water, wastewater, and storm sewer lines, as required by Contract documents for each item;
 - 2. construction of, and repairs to, pavement, driveways, sidewalks, and curbs and gutters;
 - 3. sodding and hydromulch seeding, unless waived by Project Manager in writing;

4. general clean up including pavement markings, transfer of services, successful testing and landscape;
 5. additional requirements contained in Section 01110 - Summary of Work.
- C. Assist Project Manager with inspection of Contractor's list of items and complete or correct the items, including items added by Project Manager, within specified time period.
- D. Should Project Manager's inspection show failure of Contractor to comply with requirements to obtain Date of Substantial Completion, including those items in Paragraph 1.03.B. of this section, Contractor shall complete or correct the items, before requesting another inspection by Project Manager.

1.04 CLOSEOUT PROCEDURES

- A. Comply with Document 00700 - General Conditions regarding final completion and final payment when the Work is complete and ready for Project Manager's final inspection.
- B. Provide Project Record Documents in accordance with Section 01785 - Project Record Documents.
- C. Complete or correct items on punch list, with no new items added. Address new items during warranty period.
- D. The City will occupy portions of the Work as specified in other sections.

1.05 FINAL CLEANING

- A. Execute final cleaning prior to final inspection.
- B. For facilities, clean interior and exterior glass and surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- C. Clean equipment and fixtures to sanitary condition.
- D. Clean or replace filters of operating equipment.
- E. Clean debris from roofs, gutters, down spouts, and drainage systems.
- F. Clean site; sweep paved areas, and rake clean landscaped surfaces.
- G. Remove waste and surplus materials, rubbish, and temporary construction facilities from site following final test of utilities and completion of the Work.

1.06 ADJUSTING

- A. Adjust operating equipment to ensure smooth and unhindered operation. Refer to Section 01292 - Schedule of Values, for payment.

1.07 OPERATION AND MAINTENANCE DATA

- A. Submit O&M data as noted in Section 01330 - Submittal Procedures.
- B. Refer to Section 01292 - Schedule of Values, for payment.

1.08 WARRANTIES

- A. Provide original of each warranty from Subcontractors, Suppliers, and manufacturers.
- B. Provide Table of Contents and assemble warranties in a 3-ring/D binder with durable plastic cover.
- C. Submit warranties prior to final progress payment.
- D. Warranties shall commence in accordance with the requirements in Document 00700 - General Conditions.

1.09 SPARE PARTS AND MAINTENANCE MATERIALS

- A. Provide Products, spare parts, maintenance and extra materials in quantities specified in individual Specification sections.
- B. Deliver to a location within the City limits as directed by Project Manager. Applicable items must be delivered prior to issuance of a final Certificate for Payment.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01782

OPERATIONS AND MAINTENANCE DATA

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Submittal requirements for equipment and facility Operations and Maintenance (O&M) Manuals.

1.02 RELATED SECTIONS

- A. Section 01292 – Schedule of Values
- B. Section 01330 – Submittal Procedures

1.03 MEASUREMENT AND PAYMENT

- A. Refer to Section 01292 - Schedule of Values, for payment.

1.04 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittal Procedures. Submit a list of O&M Manuals and parts manuals for equipment to be incorporated into the Work.
- B. Submit documents with 8-1/2 x 11-inch text pages, bound in 3-ring/D binders with durable plastic covers.
- C. Print "OPERATION AND MAINTENANCE INSTRUCTIONS", Project title, volume number and subject matter on the cover of each binder. Label the spine of the binder with the project title, volume number and subject matter identical to the cover.
- D. Subdivide contents with permanent page dividers, logically organized according to the Table of Contents, with tab titles clearly printed under reinforced laminated plastic tabs.
- E. O&M Manual contents: Prepare a Table of Contents for each volume, with each Product or system description identified.
 - 1. Part 1 - Directory: Listing of names, addresses, and telephone numbers of Design Consultant, Contractor, Subcontractors, and major equipment Suppliers.
 - 2. Part 2 - O&M instructions arranged by system. For each category, identify names, addresses, and telephone numbers of Subcontractors and Suppliers and include the following:

- a. Significant design criteria.
 - b. List of equipment.
 - c. Parts list for each component.
 - d. Operating instructions.
 - e. Maintenance instructions for equipment and systems.
 - f. Maintenance instructions for special finishes, including recommended cleaning methods and materials and special precautions identifying detrimental agents.
3. Part 3 - Project documents and certificates including:
- a. Shop Drawings and relevant data.
 - b. Air and water balance reports.
 - c. Certificates.
 - d. Photocopies of warranties.
- F. Submit two copies of O&M Manuals and parts manuals, for review, no less than one month prior to placing the equipment or facility in service.
- G. Submit one copy of completed volumes in final form 10 days prior to Substantial Completion or partial Substantial Completion inspection. One copy with Project Manager comments will be returned after final inspection. Revise content of documents based on Project Manager's comments prior to final submittal.
- H. Submit final volumes to the Project Manager within ten (10) days after Substantial Completion or partial Substantial Completion inspection. Provide three (3) hard copies and one electronic file in PDF format.

1.05 EQUIPMENT O&M DATA

- A. Furnish O&M Manuals, prepared by manufacturers for all equipment. Manuals must contain, as a minimum, the following:
1. Equipment functions, normal operating characteristics, and limiting conditions.
 2. Assembly, Installation, alignment, adjustment, and checking instructions.
 3. Operating instructions for start-up, normal operation, regulation and control, normal shutdown, and emergency shutdown.

4. Detailed drawings showing the location of each maintainable part and lubrication point with detailed instructions on disassembly and reassembly of the equipment.
 5. Troubleshooting guide.
 6. Spare parts list, predicted life of parts subject to wear, lists of spare parts recommended to be on hand for both initial start-up and for normal operating inventory, and local or nearest source of spare parts availability.
 7. Outline, cross-section, and assembly drawings with engineering data and wiring diagrams.
 8. Test data and performance curves.
- B. Furnish parts manuals for all equipment, prepared by the equipment manufacturer, which contain, as a minimum, the following:
1. Detailed drawings giving the location of each maintainable part.
 2. Spare parts list with predicted life of parts subject to wear, lists of spare parts recommended on hand for both initial start-up and for normal operating inventory, and local or nearest source of spare parts availability.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

SECTION 01785

PROJECT RECORD DOCUMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Maintenance and submittal of record documents and Samples.

1.02 RELATED SECTIONS

- A. Document 00700 – General Conditions

1.03 MAINTENANCE OF DOCUMENTS AND SAMPLES

- A. Maintain one record copy of documents at the site in accordance with Document 00700 - General Conditions.
- B. Store record documents and Samples in field office, if a field office is required by the Contract, or in a secure location. Provide files, racks, and secure storage for record documents and Samples.
- C. Label each document "PROJECT RECORD" in neat, large, printed letters.
- D. Maintain record documents in a clean, dry, and legible condition. Do not use record documents for construction purposes. Do not use permit drawings to record Modifications to the Work.
- E. Keep record documents and Samples available for inspection by Project Manager.
- F. Bring record documents to progress review meetings for viewing by Project Manager and, if applicable, Design Consultant.

1.04 RECORDING

- A. Record information legibly with red ink pen on a set of blue-line opaque drawings, concurrently with construction progress. Maintain an instrument on site at all times for measuring elevations accurately. Do not conceal work until required information is recorded
- B. Contract Drawings and Shop Drawings: Mark each item to record completed Modifications, or when minor deviations exist, the actual construction including:
 - 1. Measured depths of elements of foundation in relation to finish first floor datum.

2. Measured horizontal locations and elevations of Underground Facilities and appurtenances, referenced to permanent surface improvements.
 3. Elevations of Underground Facilities referenced to City of Houston benchmark utilized for the Work.
 4. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
 5. Dimensions and details of field changes
 6. Changes made by Modifications.
 7. Details not on original Drawings.
 8. References to related Shop Drawings and Modifications.
- C. Survey all joints of water mains at the time of construction. Record on Drawings, water main invert elevation, elevation top of manway, and centerline horizontal location relative to baseline.
- D. For large diameter water mains, mark specifications and addenda to record:
1. Manufacturer, trade name, catalog number and Supplier of each Product actually Installed.
 2. Changes made by Modification or field order.
 3. Other matters not originally specified.
- E. Annotate Shop Drawings to record changes made after review.
- 1.05 SUBMITTALS
- A. At closeout of the Contract, deliver Project record documents to Project Manager.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION